

April 5, 1994

CANCELLED

MEMORANDUM FOR: David B. Matthews, Director
Project Directorate II-3
Division of Reactor Projects - I/II

FROM: Robert E. Martin, Senior Project Manager
Project Directorate II-3
Division of Reactor Projects - I/II

SUBJECT: FORTHCOMING MEETING WITH DUKE POWER COMPANY ON RESIDUAL HEAT
REMOVAL SYSTEM - CATAWBA NUCLEAR STATION, UNITS 1 AND 2

DATE & TIME: Friday, April 15, 1994
10 a.m. - 5 p.m.

LOCATION: One White Flint North
11555 Rockville Pike, Room 1F-19
Rockville, Maryland

PURPOSE: Duke will make a presentation on the actions and the lessons
learned associated with the inoperability of one of the two
residual heat removal pumps during the Catawba Unit 1
refueling outage in December 1993. An agenda is enclosed.

**TO BE
RESCHEDULED**

PARTICIPANTS*:

NRC

R. Jones, NRR
W. Jones, AEOD
T. Collins, NRR
G. Lainas, NRR
D. Matthews, NRR
R. Martin, NRR

DPC

D. L. Rehn (Site VP)
W. R. McCollum (Site Mgr)
J. S. Forbes
M. E. Patrick
Z. L. Taylor

/s/
Robert E. Martin, Senior Project Manager
Project Directorate II-3
Division of Reactor Projects - I/II

Enclosure:
Agenda

cc w/enclosure:
See next page

CONTACT: R. Martin, NRR
504-1493

*Meetings between NRC technical staff and applicants or licensees are open for interested members of the public, petitioners, intervenors, or other parties to attend as observers pursuant to "Open Meeting Statement of NRC Staff Policy," 43 Federal Register 28058, 6/28/78

OFF	LA:PD23:DRPE	PM:PD23:DRPE	D:PD23:DRPE	
NAME	LBerry	RMartin:dt	DMatthews	
DATE	4/4/94	4/5/94	4/5/94	

OFFICIAL RECORD COPY
Document Name: G:\CATAWBA\MEETING2.NOT

9404180263 940405
PDR ADDCK 05000413
PDR

NRC FILE CENTER COPY

DFD1



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

April 5, 1994

Docket Nos. 50-413
and 50-414

MEMORANDUM FOR: David B. Matthews, Director
Project Directorate II-3
Division of Reactor Projects - I/II

FROM: Robert E. Martin, Senior Project Manager
Project Directorate II-3
Division of Reactor Projects - I/II

SUBJECT: FORTHCOMING MEETING WITH DUKE POWER COMPANY ON RESIDUAL HEAT
REMOVAL SYSTEM - CATAWBA NUCLEAR STATION, UNITS 1 AND 2

DATE & TIME: Friday, April 15, 1994
10 a.m. - 5 p.m.

LOCATION: One White Flint North
11555 Rockville Pike, Room 1F-19
Rockville, Maryland

PURPOSE: Duke will make a presentation on the actions and the lessons
learned associated with the inoperability of one of the two
residual heat removal pumps during the Catawba Unit 1
refueling outage in December 1993. An agenda is enclosed.

PARTICIPANTS*:

NRC	DPC
R. Jones, NRR	D. L. Rehn (Site VP)
W. Jones, AEOD	W. R. McCollum (Station Mgr)
T. Collins, NRR	J. S. Forbes
G. Lainas, NRR	M. E. Patrick
D. Matthews, NRR	Z. L. Taylor
R. Martin, NRR	

Robert E. Martin
Robert E. Martin, Senior Project Manager
Project Directorate II-3
Division of Reactor Projects - I/II

Enclosure:
Agenda

cc w/enclosure:
See next page

CONTACT: R. Martin, NRR
504-1493

*Meetings between NRC technical staff and applicants or licensees are open for interested members of the public, petitioners, intervenors, or other parties to attend as observers pursuant to "Open Meeting Statement of NRC Staff Policy," 43 Federal Register 28058, 6/28/78.

Mr. David L. Rehn
Duke Power Company

Catawba Nuclear Station

cc:

Mr. Z. L. Taylor
Regulatory Compliance Manager
Duke Power Company
4800 Concord Road
York, South Carolina 29745

Mr. Marvin Sinkule, Chief
Project Branch #3
U. S. Nuclear Regulatory Commission
101 Marietta Street, NW. Suite 2900
Atlanta, Georgia 30323

A. V. Carr, Esquire
Duke Power Company
422 South Church Street
Charlotte, North Carolina 28242-0001

North Carolina Electric Membership
Corporation
P. O. Box 27306
Raleigh, North Carolina 27611

J. Michael McGarry, III, Esquire
Winston and Strawn
1400 L Street, NW
Washington, DC 20005

Senior Resident Inspector
Route 2, Box 179 N
York, South Carolina 29745

North Carolina Municipal Power
Agency Number 1
1427 Meadowood Boulevard
P. O. Box 29513
Raleigh, North Carolina 27626-0513

Regional Administrator, Region II
U. S. Nuclear Regulatory Commission
101 Marietta Street, NW. Suite 2900
Atlanta, Georgia 30323

Mr. T. Richard Puryear
Nuclear Technical Services Manager
Westinghouse Electric Corporation
Carolinas District
2709 Water Ridge Parkway, Suite 430
Charlotte, North Carolina 28217

Max Batavia, Chief
Bureau of Radiological Health
South Carolina Department of
Health and Environmental Control
2600 Bull Street
Columbia, South Carolina 29201

County Manager of York County
York County Courthouse
York, South Carolina 29745

Mr. G. A. Copp
Licensing - EC050
Duke Power Company
P. O. Box 1006
Charlotte, North Carolina 28201-1006

Richard P. Wilson, Esquire
Assistant Attorney General
South Carolina Attorney General's
Office
P. O. Box 11549
Columbia, South Carolina 29211

Saluda River Electric
P. O. Box 929
Laurens, South Carolina 29360

Piedmont Municipal Power Agency
121 Village Drive
Greer, South Carolina 29651

Ms. Karen E. Long
Assistant Attorney General
North Carolina Department of Justice
P. O. Box 629
Raleigh, North Carolina 27602

Dayne H. Brown, Director
Division of Radiation Protection
N.C. Department of Environment,
Health and Natural Resources
P. O. Box 27687
Raleigh, North Carolina 27611-7687

Elaine Wathen, Lead REP Planner
Division of Emergency Management
116 West Jones Street
Raleigh, North Carolina 27603-1335

DUKE POWER COMPANY
CATAWBA NUCLEAR STATION
RESIDUAL HEAT REMOVAL PUMP VIBRATION

I. INTRODUCTION

- Brief overview of main points to be covered in presentation

II. BACKGROUND

- Background information on the subject RHR pump and the CNS vibration monitoring program
- Discussion on the CNS Shutdown Risk Program

III. TIMELINE

- Chronological description of activities focusing on critical points in the sequence

IV. LESSONS LEARNED

- Discussion of areas where weaknesses were identified
- Corrective actions to prevent recurrence
- Discussion of positive aspects

V. SUMMARY

- Summary of key points

April 5, 1994

Docket File
NRC & Local PDRs
PDII-3 Reading
D. Matthews
R. Martin
L. Berry
A. Chaffee, OEAB, 11A1
OGC, 15B18
E. Jordan, MNBB3701
Receptionist, White Flint
ACRS (10), P-315
OPA, 2G5
NRR Mailroom, PMAS, 12/G/18
G. Zech, RPEB, 10A19
L. Plisco, EDO (RII Plants) 17G21
J. Johnson, RII (Acting)
K. Clark, Region II
J. Johnson, PSAB
B. Grimes
A. Thadani
M. Virgilio
G. Holahan
W. R. Jones
R. Jones
G. Lainas
T. Collins