



Commonwealth Edison

Quad Cities Nuclear Power Station
22710 206 Avenue North
Cordova, Illinois 61242-9740
Telephone 309/654-2241

GCC-94-061

April 11, 1994

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, DC 20555

Reference: Quad Cities Nuclear Power Station
Docket Number 50-254, DPR-29, Unit One

Enclosed is Licensee Event Report (LER) 94-005, Revision 00, for Quad Cities Nuclear Power Plant Station.

This report is submitted in accordance with the requirements of the Code of Federal Regulations, Title 10, Part 50.73(a)(2)(ii)(b). Any event or condition that resulted in the condition of the nuclear power plant, including its principal safety barriers being seriously degraded or that resulted in the nuclear plant being in a condition that was outside the design basis of the plant.

The following commitments are being made by this letter:

A supplemental report will be issued which will document the valves and penetrations that had excessive leakage, what caused the leakage, and the corrective actions taken to bring all excessive primary containment leakages below the required LLRT limits.

If there are any questions or comments concerning this letter, please refer them to Nick Chrissotimos, Regulatory Assurance Administrator at 309-654-2241, ext. 3100.

Respectfully,

COMMONWEALTH EDISON COMPANY
QUAD CITIES NUCLEAR POWER STATION

G. G. Campbell
Station Manager

GCC/TB/plm

Enclosure

cc: J. Schrage
C. Miller
INPO Records Center
NRC Region III

9404180345 940411
PDR NJOCK 05000254
S PDR

JE22