



Illinois Power Company
Clinton Power Station
P.O. Box 678
Clinton, IL 61727
Tel 217 935-8881

U-602273
L30-94(04-12)-LP
8E,100c

April 12, 1994

10CFR50.36

Docket No. 50-461

U.S. Nuclear Regulatory Commission
Document Control Desk
Washington, D.C. 20555

Subject: Clinton Power Station, Unit 1
Facility Operating License NPF-62
March 1994 Monthly Operating Report

Dear Sir:

Please find in Attachment 1 the Monthly Operating Report for Clinton Power Station, Unit 1, for the period ending March 31, 1994.

Sincerely yours,

R. F. Phares
Director - Licensing

MCH/krm

Attachment

cc: NRC Region III Regional Administrator
NRC Resident Office
Illinois Department of Nuclear Safety

1
9404180393 940331
PDR ADDCK 05000461
R PDR

JE24

CHALLENGES TO MAIN STEAM SAFETY/RELIEF VALVES

Month March 1994

None

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-461
UNIT Clinton 1
DATE 03/31/94
COMPLETED BY M. C. Hollon
TELEPHONE (217) 935-8881 X3537

MONTH March 1994

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1	<u>928</u>
2	<u>928</u>
3	<u>929</u>
4	<u>930</u>
5	<u>930</u>
6	<u>927</u>
7	<u>929</u>
8	<u>928</u>
9	<u>928</u>
10	<u>928</u>
11	<u>930</u>
12	<u>930</u>
13	<u>930</u>
14	<u>925</u>
15	<u>926</u>
16	<u>927</u>

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

17	<u>927</u>
18	<u>928</u>
19	<u>929</u>
20	<u>927</u>
21	<u>928</u>
22	<u>928</u>
23	<u>929</u>
24	<u>929</u>
25	<u>928</u>
26	<u>929</u>
27	<u>903</u>
28	<u>927</u>
29	<u>927</u>
30	<u>927</u>
31	<u>927</u>

OPERATING DATA REPORT

DOCKET NO. 50-461
UNIT Clinton 1
DATE 03/31/94
COMPLETED BY M. C. Hollon
TELEPHONE (217) 935-8881 X3537

OPERATING STATUS

1. REPORTING PERIOD: March 1994 GROSS HOURS IN REPORTING PERIOD: 744
2. CURRENTLY AUTHORIZED POWER LEVEL (MWt): 2894
MAX. DEPEND. CAPACITY (MDC) (MWe-Net): 930
DESIGN ELECTRICAL RATING (MWe-Net): 933
3. POWER LEVEL TO WHICH RESTRICTED (IF ANY) (MWe-Net): None
4. REASONS FOR RESTRICTION (IF ANY): N/A

	THIS MONTH	YR TO DATE	CUMULATIVE
5. NUMBER OF HOURS REACTOR WAS CRITICAL...	<u>744.0</u>	<u>2,160.0</u>	<u>39,603.6</u>
6. REACTOR RESERVE SHUTDOWN HOURS.....	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
7. HOURS GENERATOR ON LINE.....	<u>744.0</u>	<u>2,160.0</u>	<u>38,366.1</u>
8. UNIT RESERVE SHUTDOWN HOURS.....	<u>0.0</u>	<u>0.0</u>	<u>4.0</u>
9. GROSS THERMAL ENERGY GENERATED (MWH)...	<u>2,159,683</u>	<u>6,248,894</u>	<u>101,306,229</u>
10. GROSS ELECTRICAL ENERGY GENERATED (MWH)	<u>717,226</u>	<u>2,072,835</u>	<u>33,491,699</u>
11. NET ELECTRICAL ENERGY GENERATED (MWH)...	<u>690,614</u>	<u>1,992,221</u>	<u>31,858,064</u>
12. REACTOR SERVICE FACTOR.....	<u>100.0%</u>	<u>100.0%</u>	<u>71.1%</u>
13. REACTOR AVAILABILITY FACTOR.....	<u>100.0%</u>	<u>100.0%</u>	<u>71.1%</u>
14. UNIT SERVICE FACTOR.....	<u>100.0%</u>	<u>100.0%</u>	<u>68.9%</u>
15. UNIT AVAILABILITY FACTOR.....	<u>100.0%</u>	<u>100.0%</u>	<u>68.9%</u>
16. UNIT CAPACITY FACTOR (Using MDC).....	<u>99.8%</u>	<u>99.2%</u>	<u>61.5%</u>
17. UNIT CAPACITY FACTOR (Using Design MWe)	<u>99.5%</u>	<u>98.9%</u>	<u>61.3%</u>
18. UNIT FORCED OUTAGE RATE.....	<u>0.0%</u>	<u>0.0%</u>	<u>10.5%</u>

19. SHUTDOWNS SCHEDULED OVER NEXT SIX MONTHS (TYPE, DATE, DURATION OF EACH):

A ten-day planned maintenance outage (PO-6) is scheduled to begin April 16, 1994.

20. IF SHUT DOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: NA

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-461
UNIT Clinton 1
DATE 03/31/94
COMPLETED BY M. C. Hollon
TELEPHONE (217) 935-8881 X3537

REPORT MONTH March 1994

NO.	DATE	TYPE	DURATION (HOURS)	REASON(1)	METHOD OF	
		F: FORCED S: SCHEDULED			SHUTTING DOWN THE REACTOR OR REDUCING POWER(2)	CORRECTIVE ACTIONS/COMMENTS
None						

- (1) Reason
A-Equipment Failure (explain), B-Maintenance or Test, C-Refueling, D-Regulatory Restriction,
E-Operator Training & License Examination, F-Administrative, G-Operational Error (explain),
H-Other (explain)
- (2) Method
1-Manual, 2-Manual Scram, 3-Automatic Scram, 4-Other (explain)