



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

September 29, 1982

JAMES P. McGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Inoperable Sample Pump for Noble
Gas Activity Monitor
Reference: LER 82-062/03 L-0
AECM-82/429

02 OCT 1 1982 58

USNRC REGION II
ATLANTA, GEORGIA

On September 1, 1982, a sample pump for the Noble Gas Activity Monitor in the Turbine Building Vent Radiation Monitoring System was found to be inoperable. A Limiting Condition for Operation was entered per GCNS Technical Specification 3.3.7.12. Attached is LER 82-062/03 L-0.

Yours truly,

J.P. McGaughey
for J.P. McGaughey

JPM:sap
Attachment

- cc: Mr. N. L. Stampley (w/a)
- Mr. R. B. McGehee (w/o)
- Mr. T. B. Conner (w/o)
- Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

8210060201 820929
PDR ADOCK 05000416
S PDR

OFFICIAL COPY