

DCS

APR 12 1994

Docket Nos. 50-336
50-423

Mr. John F. Opeka
Executive Vice President - Nuclear
Northeast Nuclear Energy Company
P. O. Box 270
Hartford, Connecticut 06141-0270

Dear Mr. Opeka:

SUBJECT: COMBINED INSPECTION REPORT NOS. 50-336/94-10 AND 50-423/94-10

This letter transmits the findings of the safety inspection of preventive maintenance activities conducted by Mr. J. H. Williams of this office from March 7-11, 1994, at Millstone Units 2 and 3, Waterford, CT. At the conclusion of the inspection, the inspector discussed the findings with Mr. Rothen and members of your staff.

The inspector found that plant management was adequately involved in the preventive maintenance programs (PM). The PM program was managed and implemented by experienced personnel. We noted that your staff has several maintenance initiatives underway. These include use of system engineers, use of reliability centered maintenance, and the use of common station procedures.

The need for a PM task on a safety-significant manual valve was questioned in this inspection and your staff indicated they would assess this need. We will inspect their assessment in a future report.

No response to this letter is required. In accordance with 10 CFR 2.790 of the Commission's regulations, a copy of this letter and the enclosed report will be placed in the NRC Public Document Room. Should you have any questions, please contact me at (610) 337-5211.

Sincerely,

(original signed by)

Glenn W. Meyer, Chief
BWR & PWR Section
Operations Branch
Division of Reactor Safety

9404190019 940412
PDR ADOCK 05000336
G PDR

180003

1E01 / 1

Mr. John F. Opeka

2

APR 12 1994

Enclosure: Inspection Report Nos. 50-336/94-10 and
50-423/94-10

cc w/encl:

J. P. Stetz, Vice President, Haddam Neck Station
D. B. Miller, Senior Vice President, Millstone Station, Unit 3
S. E. Scace, Vice President - Nuclear, Operations Services
G. H. Bouchard, Nuclear Unit Director, Unit 2
R. M. Kacich, Director, Nuclear Licensing
J. Solymossy, Director, Nuclear Quality and Assessment Services
Gerald Garfield, Esquire
Nicholas Reynolds, Esquire
K. Abraham, PAO (2)
NRC Resident Inspector
Public Document Room (PDR)
Local Public Document Room (LPDR)
Nuclear Safety Information Center (NSIC)
State of Connecticut SLO Designee

bcc w/encl:

Region I Docket Room (with concurrences)

bcc w/encl (VIA E-MAIL) (w/o SGI):

W. Dean, OEDO, Unit 2
G. Vissing, PM, NRR, Unit 2
J. Stolz, NRR/PD I-4
V. McCree, OEDO, Unit 3
V. Rooney, PM, NRR, Unit 3
M. Shannon, NRR/ILPB, Unit 3

RI:DRS
Williams/dmg

dm
04/06/94

RI:DRS
Meyer

[Signature]
04/06/94

OFFICIAL RECORD COPY A:M23-1010.INS