



Consumers
Power
Company

David J VandeWalle
Nuclear Licensing Administrator

General Offices: 1945 West Parnell Road, Jackson, MI 49201 • (517) 788-1636

September 30, 1982

Dennis M Crutchfield, Chief
Operating Reactors Branch No 5
Nuclear Reactor Regulation
US Nuclear Regulatory Commission
Washington, DC 20555

DOCKET 50-155 - LICENSE DPR-6 -
BIG ROCK POINT PLANT - SEP TOPIC
III-2, WIND AND TORNADO LOADINGS

Enclosed is Consumers Power Company response to the NRC staff request for additional information regarding SEP Topic III-2, "Wind and Tornado Loadings", for the Big Rock Point Plant. The attached report replies to three (3) staff questions. Please note that the attached Appendix C, which incorporates part of question #1 response, has been revised due to results of a recent re-evaluation of the capability of the ventilation-stack to resist wind loadings, and therefore supersedes the previous Appendix C transmitted in our August 3, 1982 correspondence.

One (1) copy of a Specification and drawing for the reinforced concrete ventilation stack is also enclosed (questions #1 and 2).

It should be noted that the information requested by the staff on the cross-section of the south end of the control room wall (question #3) are shown on a security drawing which is exempt from public disclosure; therefore, the drawing is not enclosed. However, the Systematic Evaluation Program Branch staff indicated that such information can be retrieved from the NRC's office of the Nuclear Material Safety and Safeguards.

David J VandeWalle
Nuclear Licensing Administrator

CC Administrator, Region III, USNRC
NRC Resident Inspector-Big Rock Point

Attachment

oc0982-0017a142

8210060239 820930
PDR ADOCK 05000155
P FDR

A035

Consumers Power Company
Big Rock Point Plant
Docket 50-155

SEP TOPIC III-2,
WIND AND TORNADO LOADINGS

21 pages

ic0982-0017b142

Consumers Power Company
Big Rock Point Plant
Docket 50-155

SEP TOPIC III-2,
WIND AND TORNADO LOADINGS

21 pages

ic0982-0017b142

BIG ROCK POINT
SEP TOPIC III-2
WIND AND TORNADO LOADINGS

Request For Additional Information

1. Define the thickness of the shell for the ventilation stack (concrete chimney) and identify the size and location of reinforcing steel in the stack.

Answer

The thickness of the 240 ft. high ventilation stack decreases with increasing height. The following table identifies the thickness profile:

<u>Height Above Foundation</u>	<u>Thickness</u>
0 ft.	8"
7.8 ft.	7 ½"
16.3 ft.	7"
56.3 ft.	6 ½"
116.3 ft.	6"
236.3 ft.	6"
240.0 ft.	9 ½"

The size and location of the reinforcing steel in the stack is shown on Custouis Construction Co., Inc. Drawing No C-1-279-61 enclosed.

Subsequent to our responses to SEP Topic III-2, Wind and Tornado Loadings, dated August 3, 1982 and to a later NRC request for additional information dated August 30, 1982, we have re-evaluated the resistance of the 240 ft.

concrete chimney against wind and tornado loadings. A recently located Gustouis Construction Co., Inc. drawing shows the "as built" reinforcement for the stack, whereas our original evaluation (discussed in our response dated August 3, 1982) used steel ratios found in the vendors design calculations (design ratios were 10% to 25% less than the "as built" ratios).

The results of our recent re-evaluation indicate that the 240 ft. concrete chimney has a capacity to resist the wind loading from a 200 mph tornado. This loading is greater than the one calculated in our original response due to the different steel ratios used.

Because of our re-evaluation above, you will find enclosed a revised Appendix C for our response dated August 3, 1982. This revision reflects the "as built" steel ratios for the concrete chimney.

2. Provide a copy of Bechtel Specification No. 3159-C-21 Reinforced Concrete Chimney (Ventilation Stack).

Answer

Enclosed is a copy of Bechtel Specification No. 3159-C-21.

3. List the drawings which show the cross-section (dimensional and material data) for the south masonry wall of the control room.

Answer

The south wall of the control room consists of a 1/2-inch thick steel plate cover over a partition wall which contains two windows and a door. Details of this wall are shown on a drawing located in the security files of Consumers Power Company, which are confidential and not to be released for public scrutiny.

APPENDIX C

EVALUATION OF THE 240-FOOT-HIGH STACK

The analysis of the 240-foot-high stack was performed using ACI 307-69 and ASCE paper 3269 with the following exception: in lieu of using the allowable stresses identified in the ACI code for normal wind loading, the values for the extreme tornado wind loading were:

$$\begin{aligned} \text{Maximum concrete stress} &= 0.8f'_c = 2,800 \text{ psi} \\ \text{Maximum reinforcing steel stress} &= 0.9f_y = 36,000 \text{ psi} \end{aligned}$$

These values are consistent with the values used by D'Appolonia in analyzing the 240-foot stack under extreme earthquake loading. (C-1)

The critical sections of the stack were determined by reviewing the original calculation and were found to be 56'-4" above the base for maximum reinforcing steel stresses and at the base for maximum concrete stresses.

The following outlines the method used in analyzing the stack when subjected to a 200 mph wind:

$$\begin{aligned} P &= qC_D = .00256 (200)^2 (.55) \\ &= 56.3 \text{ lbs/ft}^2 \end{aligned}$$

In determining the stresses at 56'-4" above the base, the following information was used:

$$\begin{aligned} \text{Moment at 56'-4" above the base} &= 6,558 \text{ ft-kips} \\ W &= \text{weight} = 364 \text{ kips} \\ n &= 8 \\ B &= 0^\circ \\ \rho &= .0058 \\ \rho n &= .0466 \\ \alpha &= 55^\circ \quad (\text{based upon } e/r = 2.77) \end{aligned}$$

Stress at mean diameter of chimney shell:

$$\begin{aligned} f'_{cw} &= \frac{W(1-\cos \alpha)}{2rt [(1-\rho)(\sin \alpha - \alpha \cos \alpha) - \rho n \pi \cos \alpha]} \\ &= 120.8 \text{ k/ft}^2 = 840 \text{ psi} < 2,800 \text{ psi} \end{aligned}$$

Stress at outside diameter of chimney shell:

$$\begin{aligned} f_{cw} &= f'_{cw} \left[1 + \frac{t}{2r(1-\cos \alpha)} \right] \\ &= 921 \text{ psi} < 2,800 \text{ psi} \end{aligned}$$

Maximum stress in vertical reinforcement

$$f_{sw} = nf'_{cw} \left[\frac{1 + \cos \alpha}{1 - \cos \alpha} \right]$$

$$= 24,800 \text{ psi} < 36,000 \text{ psi}$$

In determining the stresses at the base, the following information was used:

$$\begin{aligned} \text{Moment} &= 13,404 \text{ ft-kips} \\ W &= \text{weight} = 597.2 \text{ kips} \\ n &= 8 \\ B &= 19^\circ \\ \rho &= .01 \\ \rho n &= .08 \\ \alpha &= 65^\circ \text{ (based upon } e/r = 2.06) \end{aligned}$$

Stress at mean diameter of chimney shell:

$$f_{cw}' = \frac{W (\cos B - \cos \alpha)}{[2rt (1-\rho)(\sin \alpha - \alpha \cos \alpha) - (1-\rho+\rho n)(\sin B - B \cos \alpha) - \rho n \pi \cos \alpha]}$$
$$= 235 \text{ k/ft}^2 = 1,632 \text{ psi} < 2,800 \text{ psi}$$

Stress at outside diameter of chimney shell:

$$f_{cw} = f_{cw}' \left[1 + \frac{t}{2r \cos B (\cos B - \cos \alpha)} \right]$$
$$= 1,766 \text{ psi} < 2,800 \text{ psi}$$

Maximum stress in vertical reinforcement:

$$f_{sw} = nf'_{cw} \left[\frac{1 + \cos \alpha}{\cos B - \cos \alpha} \right]$$

$$= 35,500 \text{ psi} < 36,000 \text{ psi}$$

The foundation was checked for 200 mph wind as follows:

Total load on the soil (including stack, foundation, soil, and buoyancy)
= 1,970 kips

Moment at the bottom of the foundation = 15,557 ft-kips

Since $\frac{M}{W} = \frac{15,557}{1,970} = 7.9$ ft is larger than $1/6$ of the base, dimension (5.72 ft) full surface contact does not exist.

Maximum soil pressure is determined by: (C-2)

$$p = \left\{ \frac{2W}{3a (b/2 - e)} \right\} = 5.84 \text{ k/ft}^2$$

where

- p = soil pressure
- W = weight = 1,970 kips
- a = width
- b = length
- e = M/W

The maximum allowable soil pressure for loadings including wind or seismic, in accordance with the original design criteria (C-3) is $5 \text{ k/ft}^2 \times 1.33 = 6.65 \text{ k/ft}^2$, which is greater than the calculated maximum soil pressure.

Factor of safety (FS) against overturning:


$$FS = \left\{ \frac{1,970 (24.27/2)}{15,557} \right\} = 1.54 < 1.5$$

APPENDIX C

References

- C-1 D'Appolonia Report Volume IV Appendix E "Seismic Safety Margin Evaluation, Reinforced Concrete Stack"
- C-2 F.S. Merritt, Standard Handbook for Civil Engineers, 2nd edition
- C-3 Design Criteria, Big Rock Point Plant - Consumers Power Company, Job 3159 (Civil, Structural, Architectural)

REQUISITION



BECHTEL CORPORATION POWER AND INDUSTRIAL DIVISION

MATERIAL: CONCRETE VENTILATION CHIMNEY

SEP 7 1982

ATTACHMENTS: SPECIFICATION NO. 3159 C-21

CONSUMERS POWER

COST CODE

~~8088, 8-315, 8-316, 8X-1060~~

CO. JACKSON, MICH.

7,242

REQUIRED FOR: CONSUMERS POWER COMPANY - BIG ROCK POINT PLANT

MATERIAL REQUIRED AT JOB SITE NOT LATER THAN See Below

SHOP INSPECTION: REQUIRED NOT REQUIRED

FURNISH AND DELIVER TO: BECHTEL CORPORATION, c/o CONSUMERS POWER COMPANY, CH RLEVOIX, MICHIGAN

ITEM NO.	QUANTITY AND UNIT	DESCRIPTION
1	1 lot	Design and erect a 240' reinforced concrete chimney. Design of foundation. (Concrete and concrete testing to be supplied by the Contractor). Appurtenances to include embedded material, platform, ladder to platform, port and sleeve for probe.
2	1 lot	Additive item - Aircraft obstruction lighting and ladder Access probe port platforms to top of chimney.
		Time Schedule: Design calculations and preliminary drawings shall be submitted within three weeks after award of subcontract. Construction to begin July 15, 1961 and to be completed on or before September 30, 1961. Any requests for revising the time schedule shall be submitted in writing with the proposal.

SUBCONTRACTOR:
 CANTONIS CONSTRUCTION CO., INC.
 22 WEST HOWARD ST
 CHICAGO 8, ILLINOIS

 VENDOR:
 C.C. MOORE & CO. ENGINEERS, INC.
 450 MISSION STREET
 SAN FRANCISCO 5, CALIF.

8/23/61	Issued for Contract Item No. 3	U/S	BWR	JOB NO. 3159
7/27/61	Issued for Bids Item No. 3	U/S		
5/13/61	Issued for Contract Item No. 3	U/S	ARE	REQUISITION NO. 3159 C-21
4/19/61	Issued for Contract Item No. 3	U/S	ARE	REV 4
3/10/61	Issued for Bids	U/S	DW/ARE	SHEET 1 of 2 SHEETS

REQUISITION

ITEM NO	QUANTITY AND UNIT	DESCRIPTION
3	Lot	<p>Furnish labor, materials and equipment necessary to paint the top 140 ft. of the chimney in accordance with the directions set forth in "Obstruction Marking and Lighting" issued by Civil Aeronautics Administration. The painting shall consist of seven bands of international orange and white. Each band shall be 20 ft. in height. The top and bottom band shall be international orange.</p> <p>The presence of objectionable alkalinity in the concrete shall be checked by using pink litmus paper or by phenolphthalein indicator solution. If surface condition is found to be alkaline, treat with a solution of 3% phosphoric acid and zinc chloride in water and allow to dry 24 hours. Related areas shall be sealed with an iron stone or carbonyl brick.</p> <p>Paint System: First Coat - Par's Paint & Varnish - PVA Second Coat - Miltly & Fria Enamel</p> <p>The paint manufacturer's instructions shall be followed.</p> <p>When painting is applied, it shall be performed within 10 days after forms are removed. Painting shall be applied in dry weather when the ambient temperature is below 50° Fahrenheit.</p>
		REQUISITION NO. 315 SHEET 2 OF 4 SHEETS