Docket Nos. 50-272 and 50-311

> Mr. Steven E. Miltenberger Vice President and Chief Nuclear Officer Public Service Electric & Gas Company Post Office Box 236 Hancocks Bridge, New Jersey 08038

Dear Mr. Miltenberger:

EMERGENCY DIESEL GENERATOR SURVEILLANCE TESTS, SAFETY EVALUATION CLARIFICATION, SALEM NUCLEAR GENERATING STATION, UNITS 1 AND 2 (TAC

NOS. M79960 AND M79961)

By letter dated November 30, 1993. Amendment Nos. 148 and 126 were issued to Facility Operating License Nos. DPR-70 and DPR-75, respectively. Subsequent to that issuance, your staff identified some inconsistencies in the safety evaluation that accompanied the amendments. The inconsistencies are as follows:

- 1. Page 3, Change 7, it should be clarified that there are two 30,000-gallon storage tanks per unit for a total of four tanks.
- Page 8, Change 24, the quotation of the change is incorrect. After "i.e.," the words "other than" were left out.
- Page 10, Change 33, the changes were characterized as editorial. However, by deleting an exception statement, a requirement to load the diesel generators while performing surveillance tests in Mode 5 and 6 was added.

Enclosed are replacement pages for the safety evaluation. The pages have been revised to incorporate the changes described above. These changes only affect the safety evaluation and not the technical specification pages that were included in the Amendments. If you have any questions concerning this letter, please contact me.

Sincerely.

9404190099 940404 PDR ADOCK 05000272 James C. Stone, Senior Project Manager Project Directorate I-2 Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

Enclosure: Safety Evaluation Replacement Pages 3, 8 and 10

cc w/enclosure: See next page

DISTRIBUTION

Docket File MO'Brien(2) NRC & Local PDRs JStone PDI-2 Reading OGC

SVarga DHagan, 3206 JCalvo GHill(4), P1-22 CGrimes, 11E21 CMcCracken CBerlinger JStrosnider

NRC FILE CENTER COPY

ACRS(10) OPA OC/LFDCB

3	CMiller	EWenzinger, RGN-I	JWhite, RGN-I
7.0	OFFICE	PPIAZZA PDI-2/PM	PDI-2/D
	NAME	Mo Brien JStone:rb	CMiller
	DATE	13/8/94 13/28/94	4/4/94



UNITED STATES NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001 April 4, 1994

Docket Nos. 50-272 and 50-311

> Mr. Steven E. Miltenberger Vice President and Chief Nuclear Officer Public Service Electric & Gas Company Post Office Box 236 Hancocks Bridge, New Jersey 08038

Dear Mr. Miltenberger:

SUBJECT: EMERGENCY DIESEL GENERATOR SURVEILLANCE TESTS, SAFETY EVALUATION CLARIFICATION, SALEM NUCLEAR GENERATING STATION, UNITS 1 AND 2 (TAC NOS. M79960 AND M79961)

By letter dated November 30, 1993, Amendment Nos. 148 and 126 were issued to Facility Operating License Nos. DPR-70 and DPR-75, respectively. Subsequent to that issuance, your staff identified some inconsistencies in the safety evaluation that accompanied the amendments. The inconsistencies are as follows:

- Page 3, Change 7, it should be clarified that there are two 30,000-gallon storage tanks per unit for a total of four tanks.
- Page 8, Change 24, the quotation of the change is incorrect. After "i.e.," the words "other than" were left out.
- Page 10, Change 33, the changes were characterized as editorial. However, by deleting an exception statement, a requirement to load the diesel generators while performing surveillance tests in Mode 5 and 6 was added.

Enclosed are replacement pages for the safety evaluation. The pages have been revised to incorporate the changes described above. These changes only affect the safety evaluation and not the technical specification pages that were included in the Amendments. If you have any questions concerning this letter, please contact me.

Sincerely,

James C. Stone, Senior Project Manager

Project Directorate I-2

Division of Reactor Projects - I/II Office of Nuclear Reactor Regulation

Enclosure: Safety Evaluation Replacement Pages 3, 8 and 10

cc w/enclosure: See next page Mr. Steven E. Miltenberger Public Service Electric & Gas Company

cc:

Mark J. Wetterhahn, Esquire Winston & Strawn 1400 L Street NW Washington, DC 20005-3502

Richard Fryling, Jr., Esquire Law Department - Tower 5E 80 Park Place Newark, NJ 07101

Mr. Calvin A. Vondra General Manager - Salem Operations Salem Generating Station P.O. Box 236 Hancocks Bridge, NJ 08038

Mr. J. Hagan Vice President - Nuclear Operations Nuclear Department P.O. Box 236 Hancocks Bridge, New Jersey 08038

Mr. Charles S. Marschall, Senior Resident Inspector Salem Generating Station U.S. Nuclear Regulatory Commission Drawer I Hancocks Bridge, NJ 08038

Dr. Jill Lipoti, Asst. Director Radiation Protection Programs NJ Department of Environmental Protection and Energy CN 415 Trenton, NJ 08625-0415

Maryland People's Counsel American Building, 9th Floor 231 East Baltimore Street Baltimore, Maryland 21202

Mr. J. T. Robb, Director Joint Owners Affairs PECO Energy Company 955 Chesterbrook Blvd., 51A-13 Wayne, PA 19087

Mr. S. LaBruna Vice President - Nuclear Engineering Nuclear Department P.O. Box 236 Hancocks Bridge, New Jersey 08038 Salem Nuclear Generating Station, Units 1 and 2

Richard Hartung Electric Service Evaluation Board of Regulatory Commissioners 2 Gateway Center, Tenth Floor Newark, NJ 07102

Regional Administrator, Region I U. S. Nuclear Regulatory Commission 475 Allendale Road King of Prussia, PA 19406

Lower Alloways Creek Township c/o Mary O. Henderson, Clerk Municipal Building, P.O. Box 157 Hancocks Bridge, NJ 08038

Mr. Frank X. Thomson, Jr., Manager Licensing and Regulation Nuclear Department P.O. Box 236 Hancocks Bridge, NJ 08038

Mr. David Wersan Assistant Consumer Advocate Office of Consumer Advocate 1425 Strawberry Square Harrisburg, PA 17120

Mr. J. A. Isabella MGR. - Generation Department Atlantic Electric Company P.O. Box 1500 1199 Black Horse Pike Pleasantville, NJ 08232

Carl D. Schaefer
External Operations - Nuclear
Delmarva Power & Light Company
P.O. Box 231
Wilmington, DE 19899

Public Service Commission of Maryland Engineering Division Chief Engineer 6 St. Paul Centre Baltimore, MD 21202-6806