

Or 2 pm Jll

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE--PNO-V-90-44A Date 11/7/90

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information presented is as initially received without verification or evaluation and is basically all that is known by Region V staff on this date.

FACILITY: SOUTHERN CALIFORNIA EDISON
SONGS UNIT 1/2/3
DOCKET NO. 50-206/361/362
SAN CLEMENTE, CA

Emergency Classification
 Notification of Unusual Event
 Alert
 Site Area Emergency
 General Emergency
 Not Applicable

SUBJECT: LARGE BRUSH FIRE IN VICINITY OF SITE - UPDATE

The Unusual Event declared at 12:47 a.m. PST on November 7, 1990, was terminated by the licensee at 2:30 p.m. PST today.

The fire is currently decreasing and moving away from the power lines serving the San Onofre Plant. It is expected that the fire will continue to diminish and burn itself out. Highway I-5 has been reopened to traffic.

The licensee did consider deenergizing three of the four power lines to the south which feed the San Diego Gas and Electric system, but this action now appears unnecessary. The Unit 3 emergency diesel generator which was reported out of service has been restored to operation and is currently running for surveillance testing.

Region V will continue to monitor the licensee's followup and close-out of this event.

This information is current as of 3:45 p.m. PST, November 7, 1990.

CONTACT: A. Hon P. Morrill
(714)492-2641 FTS 463-3740

D. Proulx
Fil. 463-3767

DISTRIBUTION BY 5520:

Date 11/7/90 Time 4:30 Pm
Chairman Carr EDO RI
Comm. Curtiss AEOD RII
Comm. Rogers OPA RIII
Comm. Remick SLITP RIV
RES
CA NRR
OGC NMSS
OE IRM
ACRS OIG
GPA ASLAP

FAX TO:

Date _____ Time _____
INPO
NSAC
LICENSEE
RESIDENT INSPECTOR

HQS. OPERATIONS OFFICER
PDR (202)634-3343

MAIL TO:
DCS (Original)
DOT:(Trans. Only, Applicable State)

9011150123 901107
PDR IVE
PNO-V-90-044A PDC

*IE-34
1/0*