

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 M I D C C 2 0 0 - 10 0 0 0 0 - 0 0 3 4 1 1 1 0 4 _____ 5
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T
01 REPORT SOURCE 1 6 0 5 0 0 0 3 1 6 7 0 9 1 5 8 2 8 0 9 2 9 8 2 9
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 DURING A ROUTINE TURBINE BUILDING TOUR A SECURITY OFFICER DISCOVERED AB DIESEL ROOM
03 CO₂ SYSTEM ISOLATED WITH NO PERSONNEL IN ROOM. THIS IS CONTRARY TO T.S. 3.7.9.3 AS
04 NO FIRE WATCH WAS POSTED WITHIN 1 HOUR. PREVIOUS OCCURRENCES WERE REPORTED VIA
05 315/82-037, 044, 045, 068 AND 316/82-054. FIRE DETECTION SYSTEM (THERMISTORS)
06 REMAINED OPERABLE. NO PROBABLE CONSEQUENCES RESULTED.
07 _____
08 _____

09 A B 11 A 12 B 13 I N S T R U 14 S 15 Z 16
7 8 9 10 11 12 13 14 15 16 17 18 19 20
17 LER/RO REPORT NUMBER 18 21 22 23 24 26 27 28 29 30 31 32 REVISION NO.
ACTION TAKEN 18 H 19 H 20 Z 21 Z 22 0 0 0 0 23 N 24 N 25 N 26 C 1 2 5 27
33 34 35 36 37 40 41 42 43 44 47
EVENT YEAR 21 22 SEQUENTIAL REPORT NO. 24 26 OCCURRENCE CODE 28 29 REPORT TYPE 30 31

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 THE RESPONSIBLE AUXILIARY EQUIPMENT OPERATOR WAS CONTACTED AND THE SYSTEM WAS
11 RETURNED TO NORMAL. APPROPRIATE ADMINISTRATIVE ACTION WAS TAKEN. SIGNS HAVE BEEN
12 POSTED IN DESIGNATED AREAS CAUTIONING PERSONNEL TO RESTORE THE CO₂ SYSTEM WHEN
13 LEAVING. A VIDEO FILM ON THE SUBJECT IS IN THE PROCESS OF BEING VIEWED BY ALL
14 PLANT PERSONNEL.

15 F 28 1 0 0 29 NA 30 A 31 SECURITY GUARD TOUR 32
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

16 Z 33 Z 34 NA 35 NA 36 NA
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

17 0 0 0 37 Z 38
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

18 0 0 0 40
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

19 Z 42 NA 43
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

20 N 44 NA 45
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

NAME OF PREPARER M. J. CAMP PHONE (616) 465-5901 ext 1490

8210060313 820929
PDR ADOCK 05000316
S PDR