SGTB:NLO 50-322

MEMORANDUM FOR: The Files

FROM: Nancy L. Osgood, SGTB, SGTR, NMSS

SUBJECT: SUMMARY OF TELEPHONE CONFERENCE CALL REGARDING TRANSPORTING

SHOREHAM REACTOR PRESSURE VESSEL

Participants

NRC
Stewart Brown (part time)
Marissa Garcia
Henry Lee
Nancy Osgood
LILCO
Sheldon Schreiner
Gary Gisonda
MYPA
Siva Kumar

Siva Kumar Fred Shar

## Introduction

A telephone conference call was held on November 7, 1990, at the request of Long Island Lighting Co. (LILCo), to discuss transporting the Shoreham reactor pressure vessel (RPV). LILCo stated that they were exploring several options for removing the RPV from the plant. One option was to remove the RPV whole and to transport it intact to a disposal site. To further evaluate this option, LILCo was requesting that the NRC Transportation Branch discuss the requirements that apply to qualifying the reactor vesse as a radioactive materials transport package. It was emphasized that no decision had yet been made on the disposition of the RPV.

## Discussion

The discussion centered on the attached handout. The handout was transmitted by facsimile to NRC staff on November 6, 1990.

## 1. Package Description

The fuel has been removed from the RPV. Other components which may have high concentrations of radioactivity may also be removed. Most reactor internals would remain in the vessel. The head would be removed from the vessel, and a cover plate bolted over the vessel opening. Other nozzles would be cut off close to the vessel, and would also have cover plates. The head would not be part of the package. Pipes acting as an impact limiter would be used in some areas around the vessel. The vessel dimensions are approximately 20 feet in diameter by 67 feet long. The vessel wall thickness is approximately 5.5 to 6.5 inches. The total package weight is estimated at 800 tons.

9011160202 901115 PDR ADOCK 05000322 Pro1

## 2. Radioactivity

The estimate of radioactivity is included in the handout. The estimates indicate that the vessel and its internals may qualify as low specific activity radioactive material. It was suggested that if an application is submitted, that the neutron flux levels and neutron energy spectrum be described in the application, and that benchmarking radiation measurements be reported. Sufficient information should be provided so that NRC staff can perform independent verification calculations of radioactivity and radioactivity concentration.

## 3. Structural Evaluation

The structural issues discussed are included in the handout. The structural analyses would consider two oblique drops at shallow angles. One drop would look at impact at the vessel flange, and one at the bottom head. Some type of impact limiters will be used. The current concept is to place pipes at particular points to absorb impact energy. Impact limiters would also be used to prevent nozzle stubs from direct impact. NRC staff stated that force-deformation information would be required for any impact limiters. NRC staff recommended that elastic analysis be used for drops. Load combinations should include stresses due to impact, pressure and thermal loads. NRC staff stated that fracture toughness of the package should be inherent in the majerial. NRC staff stated that it will not be necessary to evaluate crack initiation and propagation if the material itself can be shown to have adequate fracture toughness. Operational controls, such as confining the shipment to summer months, could possibly be considered in the evaluation of fracture toughness in extremely low temperatures.

Original Signed by

Nancy L. Osgood Transportation Branch Division of Safeguards and Transportation, NMSS

Attachment: Handout

DISTRIBUTION:
NRC File Center
NRC PDR


NMSS r/f - w/out att. SGTB r/f - w/out att. Participants - w/out att.
Meeting Notebook - w/out att.
CRChappell - w/out att.
CEMacDonald - w/out att.

OFC :SGTB NOO	:SGTB	
OFC :SGTB NXD	:CRChappell	
DATE:11/14/90	:11/4/90	

## SHOREHAM NUCLEAR POWER STATION UNIT 1

# RPV SHIPPING PACKAGE

**LONG ISLAND LIGHTING COMPANY** 



TYPICAL BOILING WATER REACTOR WITH JET PUMPS

## COMPONENTS REMOVED BEFORE SHIPMENT

**RPV Head Fuel Control Rod Blades Control Rod Drives Fuel Support Castings Low Power Range Monitors Intermediate Range Monitors Source Range Monitors Antimony Pins Beryllium Sleeves** Californium **Blade Guides Traversing Incore Probe** 

## RPV INTERNALS IN PACKAGE

Steam Dryer
Steam Separator
Shroud
Top fuel guide
Core Plate
Jet Pumps
CRD Guide Tubes
Internal piping (Spargers, etc.)
Instrument dry tubes

## REACTOR ACTIVATION ANALYSIS RESULTS

Reactor Internals

Average Specific Activity [mCi/qm]

			<u>Average</u>	Specific	ACTIVITY	mc/gm	
Isotope	A <sub>2</sub>	Top Fuel Guide	Core Shroud	Jet Pumps	Core Support	Vessel Clad	Inner 1/2 Vessel Wall
<sup>55</sup> Fe	1000	1.73E-01	7.39E-03	9.27E-04	3.86E-03	2.74E-05	4.69E-06
60Co	7	9.57E-02	2.95E-03	3.70E-04	2.14E-03	1.10E-05	1.64E-07
63Ni	100	5.55E-03	2.43E-04	3.05E-05	1.24E-04	9.02E-07	6.12E-09
54Mn	20	6.97E-03	0.00	0.00	1.56E-04	0.00	1.91E-07
<sup>59</sup> Ni	900	4.05E-05	1.76E-06	2,21E-07	9.06E-07	6.54E-09	4.44E-11
Totals	•	2.81E-01	1.06E-02	1.33E-03	6.28E-03	3.93E-05	5.06E-06

Allowable concentration for LSA is 3.00E-01 mCi/gm

## ESTIMATED RADIONUCLIDE INVENTORY IN THE RPV AND INTERNALS

Curies <sup>2</sup>	
-	
•	
_	
_	
Bester	
400	
PAGE 1	
1	
2	
=	
it	
F	
vity	
vity	
ivity	
tivity	
tivity	
ctivity	
ctivity	
Letivity	
Activity	

			į	ACHAILY, CUITES	3			
Component	F	ş	F	ş	7	ř	Others'	Total Curies
Core Shroud	0.0381	0.0043	118.6620	47.3915	0.0283	3.9026		170.0263
Jet Pumps	0.0018	0 0000	5.5189	2.2041	0.0013	0.1815	•	7.9077
Top Guide Plate	0.0744	0.0084	232.1502	93.6200	0.0553	1.6298	0.2349	333.7731
Core Support	0.0017	0.0002	5.2119	2.0816	0.0012	0.1714	•	7.4680
Spray Header			0.0010	0.0004				0.0015
SPRAMENT Dry Tubes	•	0.0023	90.7000	21.4000	0.0107	1.55	1.7600	75.4230
CRD Guide Tubes		0.0002	3.9600	1.6800	90000	0.121	0.1370	5.9000
Vessel Cladding			0.0921	8960'0		0.0030		0.1319
Vessed Wall	0.0002		0.3272	9.0114		0.0004	0.0133	0.3525
Total by Isotope	0.1162	0.0156	416.6235	168.4257	1160.0	13.5592	2.1452	. 600.4830
Percent of total	0.02%	0.00%	69.32%	28.03%	0.02%	226%	0.36%	

<sup>1)</sup> Calculated neutron iduced activities as of July 1990.

The activities of the core shroud, top guide plate, STBM/RBM dry tabes, and CRD guide tabes have been normalized to ext R


includes "Win for the dry tubes and guide tubes. For other components, include isotopes with less than 0.01% contribution to total 8

## PREPARATION FOR SHIPMENT


Remove specified components
Cut-back nozzles (piping & CRD)
Plug and shield nozzles
Add cribbing to support shroud
Add closure plate at top of RPV
Attach lifting rig
Lift and lower
Attach upender (outside containment)
Add impact limiters (Selected areas)

## STEPS IN TRANSPORTING SHOREHAM RPV


**Seal Package** Lift from containment Attach upender **Up-end to horizontal position Add impact limiters** Transfer to land transporter Travel on site to dock Transfer to barge Barge transport to near burial site Transfer to land transporter Travel on public roads at very low speed Transfer for burial



# LAND TRANSPORTER (TYPICAL)



## BARGE (TYPICAL)



## **PACKAGE EVALUATION**

## LSA package Lifting

Evaluate vessel (Initial lift, subsequent jacking)
Evaluate attachments
Lift rig to RPV flange bolt circle
Upender to RPV skirt
Consider limiting orientations
Stresses < 1/3 yield

## Tie-Down

Saddle supports, strap, and upender
No structural attachment to vessel except skirt
10g axial load on vessel produces low stress in skirt
In case of excessive load, skirt will fail w/o impairing vessel

## **Transport**

Described in detail on subsequent pages

## TRANSPORT LOADS

Deadweight
Tie-down strap tension
Thermal

Uneven solar heating @ 100°F ambient Sudden temperature drop (-20°F to -40°F)

**Pressure** 

11.2 psig internal, 5.3 psig external

Vibration/Shock

Considered negligible due to low transport speeds

**Drop impact (1 foot)** 

Side Impact, two cases (Top closure, lower vessel)

**Penetration** 

1-1/4 diameter, 13 lb. mass dropped through 40 in.

## ACCEPTANCE CRITERIA

ASME analysis criteria will be used for convenience Deadweight, strap-tension, thermal, pressure Stress intensity less than ASME III Service Level A

**Drop Impact** 

Plastic deformation of impact limiters and vessel
No breach of vessel boundary
Meet ASME Appendix F

Penetration
Meet BRL formula

## **METHODS OF EVALUATION**

## **Manual Evaluation**

Pressure per ASME rules (Vessel, closure plates, nozzle reinforcement)

Strap tension

**Penetration** 

## **Finite Element Evaluation**

Deadweight

**Pressure** 

**Thermal** 

Drop Impact

## **Load Combinations**

Deadweight + Pressure + Thermal Impact

## BRITTLE FRACTURE PREVENTION

Linear-elastic and elastic-plastic fracture mechanics
Similar to NUREG/CR-3826
Review fracture toughness data or requirements
Review NDE data to establish flaw size
Envelop transport loads (including drop)
Evaluate crack initiation
Evaluate crack propagation