Docket No. 50-155

Mr. William L. Beckman, Plant Manager Big Rock Point Plant 10269 U. S. 31 North Charlevoix, Michigan 49720

Dear Mr. Beckman:

SUBJECT: NRC BULLETIN 90-02. "LOSS OF THERMAL MARGIN CAUSED BY CHANNEL BOX BOW" (TAC NO. 76319)

By letter dated April 20, 1990, Consumers Power Company provided a response to NRC Bulletin 90-02 for Big Rock Point. In your response you stated that analyses evaluating the effects of channel box bow on Minimum Critical Power Ratio would be submitted prior to the start of the next cycle. The at lyses were submitted by letter dated August 3, 1990.

The NRC staff has performed an evaluation of the August 3, 1990, submittal. The results of our evaluation are provided in the enclosed Safety Evaluation. The staff finds that your response satisfactorily resolves the issues discussed in NRC Bulletin 90-02 for the upcoming cycle and future cycles. However, any deviation from the approved methodology for future channel box reuse must be evaluated and approved by the staff on a cycle specific basis, prior to the start of the cycle.

We appreciate your cooperation in resolving this issue.

Sincerely,

151

Armando Masciantonio, Project Manager Project Directorate III-1 Division of Reactor Projects - III, IV, V & Special Projects Office of Nuclear Reactor Regulation

Enclosure: Safety Evaluation

cc w/enclosure: See next page

DISTRIBUTION DOCKET FILE PD31 R/F OGC

ACRS(10) AMASCIANTONIO WLONG NRC & LOCAL PDRs SMEADOR AATTARD

EJORDAN JZWOLINSKI

SMEADOR POR 11/6/90

PM/PD31:DRSP 20m AMASCIANTONIO 11/6/90 D/PD31:DRS
RPIERSON
11/7/90

DFOI

Docket No. 50-155

Mr. William L. Beckman, Plant Manager Big Rock Point Plant 10269 U. S. 31 North Charlevoix, Michigan 49720

Dear Mr. Beckman:

SUBJECT: NRC BULLETIN 90-02, "LOSS OF THERMAL MARGIN CAUSED BY CHANNEL BOX BOW" (TAC NO. 76319)

By letter dated April 20, 1990, Consumers Power Company provided a response to NRC Bulletin 90-02 for Big Rock Point. In your response you stated that analyses evaluating the effects of channel box bow on Minimum Critical Power Ratio would be submitted prior to the start of the next cycle. The analyses were submitted by letter dated August 3, 1990.

The NRC staff has performed an evaluation of the August 3, 1990, submittal. The results of our evaluation are provided in the enclosed Safety Evaluation. The staff finds that your response satisfactorily resolves the issues discussed in NRC Bulletin 90-02 for the upcoming cycle and future cycles. However, any deviation from the approad methodology for future channel box reuse must be evaluated and approved by the staff on a cycle specific basis, prior to the start of the cycle.

We appreciate your cooperation in resolving this issue.

Sincerely.

181

Armando Masciantonio, Project Manager Project Directorate III-1 Division of Reactor Projects - III, IV, V & Special Projects Office of Nuclear Reactor Regulation

Enclosure: Safety Evaluation

cc w/enclosure: See next page

DISTRIBUTION DOCKET FILE PD31 R/F OGC

ACRS(10) AMASCIANTONIO WLONG NRC & LOCAL PDRs SMEADOR AATTARD EJORDAN JZWOLINSKI

SMEADOR PARTITION OF THE PROPERTY OF THE PROPE

PM/PD31:DRSP 20m AMASCIANTONIO 11/6/90 D/PD31:DRSP
RPIERSON
11/8/90



NUCLEAR REGULATORY COMMISSION WASHINGTON D. C. 20555

November 8, 1990

Docket No. 50-155

Mr. William L. Beckman, Plant Manager Big Rock Point Plant 10269 U. S. 31 North Charlevoix, Michigan 49720

Dear Mr. Beckman:

SUBJECT: NRC BULLETIN 90-02, "LOSS OF THERMAL MARGIN CAUSED BY CHANNEL BOX

BOW" (TAC NO. 76319)

Ey letter dated April 20, 1990, Consumers Power Company provided a response to NRC Eulletin 90-02 for Big Rock Point. In your response you stated that analyses evaluating the effects of channel box bow on Minimum Critical Power Ratio would be submitted prior to the start of the next cycle. The analyses were submitted by letter dated August 3, 1990.

The NRC staff has performed an evaluation of the August 3, 1990, submittal. The results of our evaluation are provided in the enclosed Safety Evaluation. The staff finds that your response satisfactorily resolves the issues discussed in NRC Bulletin 90-02 for the upcoming cycle and future cycles. However, any deviation from the approved methodology for future channel box reuse must be evaluated and approved by the staff on a cycle specific basis, prior to the start of the cycle.

We appreciate your cooperation in resolving this issue.

Sincerely,

a.s. month

Armando Masciantonio, Project Manager Project Directorate III-1 Division of Reactor Projects - III, IV, V & Special Projects Office of Nuclear Reactor Regulation

Enclosure: Safety Evaluation

cc w/enclosure: See next page cc:

Mr. Thomas A. McNish, Secretary Consumers Power Company 212 West Michigan Avenue Jackson, Michigan 49201

Judd L. Bacon, Esquire Consumers Power Company 212 West Michigan Avenue Jackson, Michigan 49201

Mr. Thomas C. Bordine Consumers Power Company 212 West Michigan Avenue Jackson, Michigan 49201

County Building Charlevoix, Michigan 49720

Office of the Governor Room 1 - Capitol Building Lansing, Michigan 48913

Regional Administrator, Region III U.S. Nuclear Regulatory Connission 799 Roosevel' Road Glen Ellyn, Illinois 60137

Nuclear Facilities and Environmental Munituring Section Office Division of Radiological Health P. O. Box 30035 Lansing, Michigan 48909

U.S. Nuclear Regulatory Commission Resident Inspector Office Big Rock Point Plant 10253 U.S. 31 North Charlevoix, Michigan 49720