

April 6, 1994

Docket No. 50-382

Mr. Ross P. Barkhurst
Vice President Operations
Entergy Operations, Inc.
Post Office Box B
Killona, Louisiana 70066

Dear Mr. Barkhurst:

SUBJECT: WATERFORD STEAM ELECTRIC STATION, UNIT 3 - PARTIAL WITHDRAWAL OF AN AMENDMENT REQUEST (TAC NO. M88326)

By letter dated November 16, 1993, you applied for an amendment to the Waterford Steam Electric Station, Unit 3, Facility Operating License No. NPF-38. The amendment revised the Technical Specifications to provide acceptable conditions for operation when (1) the core operating limits supervisory system is in service and neither control element assembly calculator is operable and (2) the supervisory system is out of service and either or both assembly calculators are operable. Subsequently, by supplemental letter dated April 5, 1994, you withdrew a portion of the application pertaining to the increase of the required power operating limit reduction from 13 percent to 16 percent.

The Commission has filed the enclosed Notice of Partial Withdrawal of Application for Amendment to Facility Operating License with the Office of the Federal Register for publication.

Sincerely,

ORIGINAL SIGNED BY:
David L. Wigginton, Senior Project Manager
Project Directorate IV-1
Division of Reactor Projects - III/IV
Office of Nuclear Reactor Regulation

Enclosure:
Notice of Withdrawal

cc w/enclosure:
See next page

DISTRIBUTION:

Docket File	NRC & Local PDRs	PD4-1 r/f
J. Roe	E. Adensam	W. Beckner
P. Noonan	D. Wigginton	OGC
<i>NDA Noonan</i>	ACRS (10)	OPA
OC/LFDCB	A. B. Beach, DRP	

OFC	LA:PD4-1 <i>JRN</i>	PM:PD4-1 <i>DW</i>	D:PD4-1 <i>WDO</i>
NAME	PNoonan	DWigginton/pk	WBeckner
DATE	4/6/94	4/6/94	4/6/94
COPY	YES/NO	YES/NO	YES/NO

OFFICIAL RECORD COPY

Document Name: WAT88326.WIL

9404190291 940406
PDR ADOCK 05000382
P PDR

140039

NRC FILE CENTER COPY

*LF01
11*

April 6, 1994

Docket No. 50-382

Mr. Ross P. Barkhurst
Vice President Operations
Entergy Operations, Inc.
Post Office Box B
Killona, Louisiana 70066

Dear Mr. Barkhurst:

SUBJECT: WATERFORD STEAM ELECTRIC STATION, UNIT 3 - PARTIAL WITHDRAWAL OF AN AMENDMENT REQUEST (TAC NO. M88326)

By letter dated November 16, 1993, you applied for an amendment to the Waterford Steam Electric Station, Unit 3, Facility Operating License No. NPF-38. The amendment revised the Technical Specifications to provide acceptable conditions for operation when (1) the core operating limits supervisory system is in service and neither control element assembly calculator is operable and (2) the supervisory system is out of service and either or both assembly calculators are operable. Subsequently, by supplemental letter dated April 5, 1994, you withdrew a portion of the application pertaining to the increase of the required power operating limit reduction from 13 percent to 16 percent.

The Commission has filed the enclosed Notice of Partial Withdrawal of Application for Amendment to Facility Operating License with the Office of the Federal Register for publication.

Sincerely,

ORIGINAL SIGNED BY:
David L. Wigginton, Senior Project Manager
Project Directorate IV-1
Division of Reactor Projects - III/IV
Office of Nuclear Reactor Regulation

Enclosure:
Notice of Withdrawal

cc w/enclosure:
See next page

DISTRIBUTION:

Docket File	NRC & Local PDRs	PD4-1 r/f
J. Roe	E. Adensam	W. Beckner
P. Noonan	D. Wigginton	OGC
D. Hagan	ACRS (10)	OPA
OC/LFDCB	A. B. Beach, DRP	

OFC	LA:PD4-1 <i>gjh</i>	PM:PD4-1 <i>DW</i>	D:PD4-1 <i>WBeckner</i>
NAME	PNoonan	DWigginton/pk	WBeckner
DATE	4/16/94	4/16/94	4/16/94
COPY	YES/NO	YES/NO	YES/NO

OFFICIAL RECORD COPY

Document Name: WAT88326.WIL



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D. C. 20555-0001

April 6, 1994

Docket No. 50-382

Mr. Ross P. Barkhurst
Vice President Operations
Entergy Operations, Inc.
Post Office Box B
Killona, Louisiana 70066

Dear Mr. Barkhurst:

SUBJECT: WATERFORD STEAM ELECTRIC STATION, UNIT 3 - PARTIAL WITHDRAWAL OF AN
AMENDMENT REQUEST (TAC NO. M88326)

By letter dated November 16, 1993, you applied for an amendment to the Waterford Steam Electric Station, Unit 3, Facility Operating License No. NPF-38. The amendment revised the Technical Specifications to provide acceptable conditions for operation when (1) the core operating limits supervisory system is in service and neither control element assembly calculator is operable and (2) the supervisory system is out of service and either or both assembly calculators are operable. Subsequently, by supplemental letter dated April 5, 1994, you withdrew a portion of the application pertaining to the increase of the required power operating limit reduction from 13 percent to 16 percent.

The Commission has filed the enclosed Notice of Partial Withdrawal of Application for Amendment to Facility Operating License with the Office of the Federal Register for publication.

Sincerely,

A handwritten signature in cursive script, appearing to read "D. L. Wigginton".

David L. Wigginton, Senior Project Manager
Project Directorate IV-1
Division of Reactor Projects - III/IV
Office of Nuclear Reactor Regulation

Enclosure:
Notice of Partial Withdrawal

cc w/enclosure:
See next page

Mr. Ross P. Barkhurst
Entergy Operations, Inc.

Waterford 3

cc:

Mr. William H. Spell, Administrator
Radiation Protection Division
Office of Air Quality and Nuclear Energy
Post Office Box 82135
Baton Rouge, Louisiana 70884-2135

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

Mr. Jerrold G. Dewease
Vice President, Operations
Support
Entergy Operations, Inc.
P. O. Box 31995
Jackson, Mississippi 39286

Resident Inspector/Waterford NPS
Post Office Box 822
Killona, Louisiana 70066

William A. Cross
Bethesda Licensing Office
3 Metro Center
Suite 610
Bethesda, Maryland 20814

Parish President Council
St. Charles Parish
P. O. Box 302
Hahnville, Louisiana 70057

Mr. Robert B. McGehee
Wise, Carter, Child & Caraway
P.O. Box 651
Jackson, Mississippi 39205

Mr. Harry W. Keiser, Executive Vice-
President and Chief Operating Officer
Entergy Operations, Inc.
P. O. Box 31995
Jackson, Mississippi 39286-1995

Mr. D. F. Packer
General Manager Plant Operations
Entergy Operations, Inc.
P. O. Box B
Killona, Louisiana 70066

Chairman
Louisiana Public Service Commission
One American Place, Suite 1630
Baton Rouge, Louisiana 70825-1697

Mr. L. W. Laughlin, Licensing Manager
Entergy Operations, Inc.
P. O. Box B
Killona, Louisiana 70066

Mr. R. F. Burski, Director
Nuclear Safety
Entergy Operations, Inc.
P. O. Box B
Killona, Louisiana 70066

Winston & Strawn
Attn: N. S. Reynolds
1400 L Street, N.W.
Washington, DC 20005-3502



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D. C. 20555-0001

April 6, 1994

Docket No. 50-382

Mr. Ross P. Barkhurst
Vice President Operations
Entergy Operations, Inc.
Post Office Box B
Killona, Louisiana 70066

Dear Mr. Barkhurst:

SUBJECT: WATERFORD STEAM ELECTRIC STATION, UNIT 3 - PARTIAL WITHDRAWAL OF AN
AMENDMENT REQUEST (TAC NO. M88326)

By letter dated November 16, 1993, you applied for an amendment to the Waterford Steam Electric Station, Unit 3, Facility Operating License No. NPF-38. The amendment revised the Technical Specifications to provide acceptable conditions for operation when (1) the core operating limits supervisory system is in service and neither control element assembly calculator is operable and (2) the supervisory system is out of service and either or both assembly calculators are operable. Subsequently, by supplemental letter dated April 5, 1994, you withdrew a portion of the application pertaining to the increase of the required power operating limit reduction from 13 percent to 16 percent.

The Commission has filed the enclosed Notice of Partial Withdrawal of Application for Amendment to Facility Operating License with the Office of the Federal Register for publication.

Sincerely,

A handwritten signature in cursive script, appearing to read "D. L. Wigginton".

David L. Wigginton, Senior Project Manager
Project Directorate IV-1
Division of Reactor Projects - III/IV
Office of Nuclear Reactor Regulation

Enclosure:
Notice of Partial Withdrawal

cc w/enclosure:
See next page