



UNITED STATES  
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

April 11, 1994

Docket Nos. 50-498  
and 50-499

Mr. William T. Cottle  
Group Vice-President, Nuclear  
Houston Lighting & Power Company  
South Texas Project Electric  
Generating Station  
P. O. Box 289  
Wadsworth, Texas 77483

Dear Mr. Cottle:

SUBJECT: RESOLUTION OF NRC BULLETIN 88-08, "THERMAL STRESSES IN PIPING  
CONNECTED TO REACTOR COOLANT SYSTEMS," FOR SOUTH TEXAS PROJECT,  
UNITS 1 AND 2 (TAC NOS. M69689 AND M69690)

In a letter dated September 28, 1988, Houston Lighting & Power Company (HL&P) responded to NRC Bulletin 88-08, "Thermal Stresses in Piping Connected to Reactor Coolant Systems." Supplemental information was provided by HL&P in letters dated February 23, 1989, November 20, 1989, September 21, 1990, and November 5, 1990. The September 21, 1990, letter, informed the staff that HL&P had decided to delete temperature monitoring instrumentation that had been previously installed to address Action 3 of the bulletin. The decision was based primarily on an engineering evaluation performed by Westinghouse for the licensee. The staff reviewed the Westinghouse evaluation, and concluded in a September 23, 1992, letter, that the conclusions stated in the Westinghouse evaluation may not have been based on fully-supported assumptions, and that the decision to remove the temperature monitoring instrumentation may have been premature.

On November 8-9, 1993, a meeting between the NRC staff, the licensee, and Westinghouse, was held at the Westinghouse corporate engineering office in Pittsburgh, Pennsylvania, for the purpose of resolving the technical issues surrounding HL&P's responses to the bulletin. A summary of the discussions held during the meeting were documented in a December 13, 1993, meeting summary. During the meeting, a resolution to the bulletin was discussed. The staff stated, and HL&P agreed, that if the fatigue life of critical components could be shown to be reasonably long, assuming worst-case expected temperature distribution and cycling period, the licensee would have provided an acceptable plant-specific resolution for an interim period.

By letter dated November 30, 1993, the licensee provided Supplement 1 to WCAP-12598, "NRC Bulletin 88-08 Evaluation of Auxiliary Piping for South Texas Project Units 1 And 2." This report formally documents the material presented by HL&P and Westinghouse during the November 8-9, 1993, meeting. In addition,

9404190367 940411  
PDR ADDCK 05000498  
PDR

150049

NRC FILE CENTER COPY

DFE1 / 0

the report states that a fatigue evaluation, assuming a worst-case scenario for valve leakage and cycling, was performed for the normal and alternate charging line piping. Based on these assumptions, the evaluation showed the fatigue adequacy of these lines to be on the order of ten years.

The staff, with assistance from our consultant, Brookhaven National Laboratory, has reviewed the results of the licensee's response. The staff concludes that the piping integrity of the normal and alternate charging piping is ensured for near-term operation, and finds that the licensee has adequately addressed the bulletin.

The staff will continue to review this issue on a generic basis as it relates to the postulated phenomenon known as "turbulence penetration," and its relationship to the subject of thermal cycling. It should be noted that turbulence penetration has yet to be adequately demonstrated to be a mitigating effect of the thermal cycling concern that is the subject of Bulletin 88-08. Supplement 1 to WCAP-12598 will be further studied during the generic review process. Upon completion of the generic review, the staff may provide a plant-specific safety evaluation on this issue, if necessary, regarding long-term operation.

This completes our review efforts for TAC Nos. M69689 and M69690.

Sincerely,

Original Signed By

Lawrence E. Kokajko, Senior Project Manager  
Project Directorate IV-2  
Division of Reactor Projects III/IV  
Office of Nuclear Reactor Regulation

cc: See next page

DISTRIBUTION:

Docket                   ACRS (10)  
NRC PDR                 JNorberg  
Local PDR               BMosafari  
PDIV-2 Reading         WJohnson, Region IV  
JRoe  
EAdensam  
LKokajko  
EPeyton  
OGC

\*See Previous Sheet for Concurrence

OFFICE	PDIV-2/LA	PDIV-2/PM	EMEB*	PDIV-2/D	
NAME	EPeyton	LKokajko	JNorberg	SBlack	
DATE	4/11/94	4/11/94	4/7/94	4/11/94	

cc:

Mr. David P. Loveless  
Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
P. O. Box 910  
Bay City, Texas 77414

Mr. J. C. Lanier/M. B. Lee  
City of Austin  
Electric Utility Department  
721 Barton Springs Road  
Austin, Texas 78704

Mr. K. J. Fiedler  
Mr. M. T. Hardt  
Central Public Service Board  
P. O. Box 1771  
San Antonio, Texas 78296

Mr. G. E. Vaughn  
Mr. T. M. Puckett  
Central Power and Light Company  
P. O. Box 2121  
Corpus Christi, Texas 78403

INPO  
Records Center  
700 Galleria Parkway  
Atlanta, Georgia 30339-3064

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 1000  
Arlington, Texas 76011

Mr. Joseph M. Hendrie  
50 Bellport Lane  
Bellport, New York 11713

Judge, Matagorda County  
Matagorda County Courthouse  
1700 Seventh Street  
Bay City, Texas 77414

Mr. James J. Sheppard  
General Manager, Nuclear Licensing  
Houston Lighting and Power Company  
P. O. Box 289  
Wadsworth, Texas 77483

Jack R. Newman, Esq.  
Newman & Holtzinger, P.C.  
1615 L Street, N.W.  
Washington, D.C. 20036

Licensing Representative  
Houston Lighting and Power Company  
Suite 610  
Three Metro Center  
Bethesda, Maryland 20814

Bureau of Radiation Control  
State of Texas  
1101 West 49th Street  
Austin, Texas 78756

Rufus S. Scott  
Associate General Counsel  
Houston Lighting and Power Company  
P. O. Box 61867  
Houston, Texas 77208

Joseph R. Egan, Esq.  
Shaw, Pittman, Potts & Trowbridge  
2300 N Street, N.W.  
Washington, D.C. 20037