LICENSEE EVENT REPORT

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)
0 1 M D C C N 1 2 0 0 - 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5 6 5 TYPE 30 57 CAT 58
CON'T O 1 8 REPORT SOURCE L 6 0 5 0 0 0 3 1 7 7 0 0 9 1 0 8 2 8 0 9 2 7 8 2 9 EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10 O 2 At 1045 during normal plant operations, plant chemistry personnel while
conducting the initial training exercise changed the calibration adjust-
ment of the hydrogen analyzer 0-AE-6519 (common to both reactor plants)
rendering the only operable unit inoperable (T.S. 3.6.5.1). The instru-
[0]6] ment was recalibrated and returned to service at 1125 terminating the
[0 7] event.
Similar events: none.
7 8 9 SYSTEM CAUSE CAUSE COMP. VALVE
TODE SUBCODE S
Type No. Type Type No. Type Type No. Type
The cause of the event was an erroneous calibration adjustment step in a
chemistry procedure. This procedure has been revised to correct the
error. This information has been distributed to plant chemistry person-
1 3 nel.
7 8 9 OTHER STATUS 30 METHOD OF DISCOVERY DESCRIPTION 32 1 5 E 28 0 9 0 29 N/A B 31 Instrument Personnel Observation 7 8 9 10 12 13 44 45 46 89
ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY 35 1 6 Z 33 Z 34 N/A 7 8 9 10 11 N/A PERSONNEL EXPOSURES AMOUNT OF ACTIVITY 35 N/A 44 45 80
NUMBER TYPE DESCRIPTION (39) 7 8 9 11 12 13 PERSONNEL INJURIES NUMFER DESCRIPTION (41)
1 8 0 0 0 0 40 N/A 7 8 9 11 12 80
LOSS OF OR DAMAGE TO FACILITY (43) TYPE DESCRIPTION N/A PUBLICITY ISSUED DESCRIPTION (45) NRC USE ONLY NRC USE ONLY PDR ADOCK 05000317
2 0 N 44 N/A PDR 68 69 80.5
NAME OF REFERENCE J. M. Bills PHONE 301-269-4795