

NRC OPERATIONS CENTER USAGE

Date (Time)	Site	Licensee Emergency Action Level*	NRC Emergency Action Level**	Reason Reference
1/4/81	Dresden 50-237	--	Standby	Release of radioactive material during test of isolation condenser (PNO-III-81-01)
2/11/81 (1940CST)	Sequoyah 50-327	Alert	Standby	Loss of RCS coolant due to inadvertent opening of valve by worker (14 employees slightly contaminated) (PNO-II-81-15, 15A)
2/16/81 (1315CST)	Sequoyah 50-327	Alert	Standby	Loss of Control Room Panel Annunciation for 50 minutes (PNO-II-81-16)
3/11/81 (0820)	Salem 1 50-272	Alert	Standby	Off-gas release in auxiliary building (PNO-I-81-35)
5/22/81 (0035 CDT)	Brown Ferry 3 50-296	Alert	Normal	Leakage into drywell (PNO-II-81-37)
7/3/81	North Anna 50-339	Alert	Normal	Fire in transformer
8/7/81	D. C. Cook 50-315	Unusual Event	Standby	Toxic Chemical Plume From Train Derailment (PNO-II-81-69)

A226

(1 & 2)