

APPENDIX A

NOTICE OF VIOLATION

Omaha Public Power District
Fort Calhoun Station

Docket: 50-285
License: DPR-40

During an NRC inspection conducted on February 13 through March 26, 1994, a violation of NRC requirements was identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," 10 CFR Part 2, Appendix C, the violation is listed below:

Technical Specification 5.8.1 states, in part, that "Written procedures and administrative policies shall be established, implemented, and maintained that meet or exceed . . . Appendix A of U.S. NRC Regulatory Guide 1.33 . . ."

Section 7.e.(1) of Regulatory Guide 1.33 lists radiation protection procedures governing access control to radiation areas, including a radiation work permit system.

Section 5.1.10 of Procedure RP-AD-200, "Radiation Protection Administration Procedure," requires that all personnel shall log in and out of the access control system for each radiologically controlled access entry. Section 5.3.2.A requires that personnel entering the radiologically controlled area wear approved personnel monitoring equipment.

Radiation Work Permit 94-3015 required that individuals have a thermoluminescent dosimeter and an alarming dosimeter.

Contrary to the above, on March 15, 1994, an individual, working in accordance with Radiation Work Permit 94-3015, entered the radiologically controlled area without logging into the access control system and without his alarming dosimeter turned on.

This is a Severity Level IV violation (Supplement IV) (285/9407-03).

Pursuant to the provisions of 10 CFR 2.201, Omaha Public Power District is hereby required to submit a written statement or explanation to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, D.C. 20555 with a copy to the Regional Administrator, Region IV, 611 Ryan Plaza Drive, Suite 400, Arlington, Texas 76011, and a copy to the NRC Resident Inspector at the facility that is the subject of this Notice, within 30 days of the date of the letter transmitting this Notice of Violation (Notice). This reply should be clearly marked as a "Reply to a Notice of Violation" and should include for each violation: (1) the reason for the violation, or, if contested, the basis for disputing the violation, (2) the corrective steps that have been taken and the results achieved, (3) the corrective steps that will be taken to avoid further violations, and (4) the date when full compliance will be achieved. If an adequate reply is not received within the time specified in this Notice, an order or a Demand for Information may be issued to show cause why the license should not be modified, suspended, or

9404200220 940413
PDR ADOCK 05000285
G PDR

revoked, or why such other action as may be proper should not be taken. Where good cause is shown, consideration will be given to extending the response time.

Dated at Arlington, Texas,
this *13th* day of *April* 1994