

Georgia Power Company
40 Inverness Center Parkway
Post Office Box 1295
Birmingham, Alabama 35201
Telephone: 205 877-7122



Georgia Power

the southern electric system

C. K. McCoy
Vice President, Nuclear
Vogtle Project

April 15, 1994

LCV- 0340

Docket Nos. 50-424
50-425

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Ladies and Gentlemen:

VOGTLE ELECTRIC GENERATING PLANT
SAFEGUARDS EVENT LOG FOR FIRST QUARTER 1994

In accordance with 10 CFR 73.71 (c)(2), Georgia Power Company hereby submits the safeguards event log for Vogtle Electric Generating Plant for the first quarter of 1994.

This log has been reviewed and determined not to contain safeguards information. Therefore, this log can be placed in the Public Document Room.

Please contact this office if you have any questions.

Sincerely,

C.K.M.'9
C. K. McCoy

CKM/AFS

Enclosure: Safeguards Event Log - First Quarter 1994

xc: Georgia Power Company
Mr. J. B. Beasley, Jr.
Mr. M. Sheibani
NORMS

U. S. Nuclear Regulatory Commission
Mr. S. D. Ebnetter, Regional Administrator
Mr. D. S. Hood, Licensing Project Manager, NRR
Mr. B. R. Bonser, Senior Resident Inspector, Vogtle

9404200235 940415
PDR ADDCK 05000424
F PDR

*2222
All Above
distribution*

VOGTLE ELECTRIC GENERATING PLANT
SECURITY INFORMATION MANAGEMENT SYSTEM
INCIDENT LOG (73.71)
Sorted by Incident Number
01/01/94 Thru 03/31/94

INCIDENT NUMBER	DATE OF EVENT	TIME OF EVENT	DATE OF REPORT	TIME OF REPORT	EVENT	RESPONSE
1321-94	01/01/94	21:26	01/10/94	23:16	73.71/ ACAD OUT OF CONTROL ANSO (BADGES)	ACAD INACTIVATED/ SUBJECT ESCORTED OUT OF PA/ TRACE CONDUCTED
1323-94	01/04/94	08:31	01/04/94	17:30	73.71/ CPU FAILURE LT-SNS (COMPUTER)	COMPENSATORY MEASURES ESTABLISHED/ PRIME SWAP CONDUCTED
1324-94	01/08/94	06:29	01/08/94	07:38	73.71/ MW ZONE INOPERATIVE ANSO (ALARM)	COMPENSATORY MEASURES ESTABLISHED/ OPERATIONAL TEST CONDUCTED
1327-94	01/14/94	11:16	01/14/94	12:47	73.71/ MW ZONE INOPERATIVE ANSO (ALARM)	COMPENSATORY MEASURES ESTABLISHED/ OPERATIONAL TEST CONDUCTED
1329-94	01/17/94	00:54	01/17/94	01:17	73.71/ AUTOMATIC LOOP RECONFIGURATION ANSO (COMPUTER)	ALARM CAPABILITY VERIFIED
1331-94	01/19/94	15:53	01/19/94	16:26	73.71/ AUTOMATIC LOOP RECONFIGURATION ANSO (COMPUTER)	ALARM CAPABILITY VERIFIED
1332-94	01/20/94	09:03	01/20/94	11:42	73.71/ AUTOMATIC LOOP RECONFIGURATION ANSO (COMPUTER)	ALARM CAPABILITY VERIFIED
1334-94	01/21/94	17:01	01/21/94	18:36	73.71/ MW ZONE INOPERATIVE ANSO (ALARM)	COMPENSATORY MEASURES ESTABLISHED
1338-94	01/28/94	09:08	01/28/94	10:27	73.71/ MW ZONE INOPERATIVE ANSO (ALARM)	COMPENSATORY MEASURES ESTABLISHED/ WRT ISSUED
1339-94	01/28/94	12:30	01/28/94	13:13	73.71/ INADEQUATE CAMERA COVERAGE ANSO (CCTV FAILURES)	COMPENSATORY MEASURES ESTABLISHED
1340-94	01/28/94	13:44	01/28/94	14:34	73.71/ TAILGATING ANSO (NON-SECURITY FORCE ERROR)	SUBJECT ESCORTED OUT OF AREA/ NO MALEVOLENT INTENT
1341-94	01/29/94	06:25	01/29/94	15:38	73.71/ MUX FAILURE ANSO (COMPUTER)	COMPENSATORY MEASURES ESTABLISHED/ TESTING OF AFFECTED POINTS CONDUCTED
1342-94	01/29/94	22:42	01/29/94	22:45	73.71/ AUTOMATIC LOOP RECONFIGURATION ANSO (COMPUTER)	ALARM CAPABILITY VERIFIED
1344-94	01/31/94	11:03	01/31/94	11:35	73.71/ UNSECURE VITAL AREA DOOR ALARM (UNSECURE DOOR)	DOOR SECURED/ VADC CONDUCTED/ SEARCH CONDUCTED
1371-94	02/03/94	20:50	02/03/94	20:55	73.71/ MW ZONE INOPERATIVE ANSO (ALARM)	COMPENSATORY MEASURES ESTABLISHED

VOGTLE ELECTRIC GENERATING PLANT
SECURITY INFORMATION MANAGEMENT SYSTEM
INCIDENT LOG (73.71)
Sorted by Incident Number
01/01/94 Thru 03/31/94

INCIDENT NUMBER	DATE OF EVENT	TIME OF EVENT	DATE OF REPORT	TIME OF REPORT	EVENT	RESPONSE
1352-94	02/04/94	15:32	02/04/94	17:23	73.71/ AUTOMATIC LOOP RECONFIGURATION ANSO (COMPUTER)	ALARM CAPABILITY VERIFIED
1353-94	02/04/94	20:13	02/04/94	20:30	73.71/ AUTOMATIC LOOP RECONFIGURATION ANSO (COMPUTER)	ALARM CAPABILITY VERIFIED
1354-94	02/07/94	09:22	02/07/94	13:00	73.71/ MUX FAILURE ANSO (COMPUTER)	COMPENSATORY MEASURES ESTABLISHED/ TESTING CONDUCTED
1355-94	02/09/94	08:32	02/09/94	09:33	73.71/ UNSECURE VITAL AREA DOOR ALARM (UNSECURE DOOR)	DOOR SECURED/ VADC CONDUCTED/ SEARCH CONDUCTED
1356-94	02/09/94	07:29	02/09/94	13:03	73.71/ INCOMPLETE BACKGROUND SCREENING INFORMANT (ACCESS CONTROL/AUTHORIZATION)	ACAD INACTIVATED/ TRACE CONDUCTED
1357-94	02/09/94	12:41	02/09/94	13:16	73.71/ IMPROPER ACCESS LEVELS GRANTED TO BLUE BADGE EMPLOYEE CLERK-BADGING (OTHER SECURITY FORCE ERROR)	ACAD INACTIVATED/ BADGE RE-PROGRAMMED CORRECTLY/ TRACE CONDUCTED
1359-94	02/10/94	16:00	02/10/94	16:07	73.71/ FAILURE TO MAINTAIN MINIMUM STAFFING (OTHER SECURITY FORCE ERROR)	ADDITIONAL PERSONNEL CALLED IN
1360-94	02/14/94	08:59	02/14/94	11:50	73.71/ UNSECURE VITAL AREA DOOR ALARM (UNSECURE DOOR)	DOOR SECURED/ VADC CONDUCTED/ SEARCH CONDUCTED
1361-94	02/14/94	09:09	02/14/94	11:50	73.71/ UNSECURE VITAL AREA DOOR ALARM (UNSECURE DOOR)	DOOR SECURED/ VADC CONDUCTED/ SEARCH CONDUCTED
1363-94	02/14/94	17:25	02/14/94	18:18	73.71/ MICROWAVE ZONE INOPERATIVE ANSO (ALARMS)	COMPENSATORY MEASURES ESTABLISHED/ OPERATIONAL TEST CONDUCTED
1366-94	02/14/94	18:04	02/15/94	06:22	73.71/ MICROWAVE ZONE INOPERATIVE ASO (ALARMS)	COMPENSATORY MEASURES ESTABLISHED/ OPERATIONAL TEST CONDUCTED
1367-94	02/15/94	12:02	02/15/94	15:00	73.71/ AUTOMATIC LOOP RECONFIGURATION ANSO (COMPUTER)	ALARM CAPABILITY VERIFIED/ TESTING CONDUCTED/ WRT ISSUED
1368-94	02/15/94	15:31	02/15/94	17:00	73.71/ AUTOMATIC LOOP RECONFIGURATION ASO (COMPUTER)	ALARM CAPABILITY VERIFIED/ TESTING CONDUCTED/ WRT ISSUED
1369-94	02/15/94	17:42	02/15/94	20:27	73.71/ AUTOMATIC LOOP RECONFIGURATION ASO (COMPUTER)	TESTING CONDUCTED/ ALARM CAPABILITY VERIFIED

VOGTLE ELECTRIC GENERATING PLANT
SECURITY INFORMATION MANAGEMENT SYSTEM
INCIDENT LOG (73.71)
Sorted by Incident Number
01/01/94 Thru 03/31/94

INCIDENT NUMBER	DATE OF EVENT	TIME OF EVENT	DATE OF REPORT	TIME OF REPORT	EVENT	RESPONSE
1370-94	02/16/94	10:22	02/16/94	11:09	73.71/ UNSECURE VITAL AREA DOOR ALARM (UNSECURE DOOR)	DOOR SECURED/ VADC CONDUCTED/ SEARCH CONDUCTED
1371-94	02/17/94	14:19	02/17/94	15:17	73.71/ UNSECURE VITAL AREA DOOR ALARM (UNSECURE DOOR)	DOOR SECURED/ VADC CONDUCTED/ SEARCH CONDUCTED
1372-94	02/17/94	15:45	02/17/94	17:09	73.71/ UNSECURE VITAL AREA DOOR ALARM (UNSECURE DOOR)	DOOR SECURED/ VADC CONDUCTED/ SEARCH CONDUCTED
1374-94	02/18/94	11:53	02/18/94	13:05	73.71/ AUTOMATIC LOOP RECONFIGURATION NSS (COMPUTER)	ALARM CAPABILITY VERIFIED
1376-94	02/21/94	09:25	02/21/94	09:56	73.71/ AUTOMATIC LOOP RECONFIGURATION ASO (COMPUTER)	ALARM CAPABILITY VERIFIED
1378-94	02/25/94	15:40	02/25/94	16:43	73.71/ UNCONTROLLED SAFEGUARDS INFORMATION EMPLOYEE (SAFEGUARDS)	DOCUMENTS PROPERLY SECURED/ DOCUMENTS REVIEWED FOR SIGNIFICANCE
1379-94	02/26/94	01:25	02/26/94	01:25	73.71/ LOST ACAD ANSO (BADGES)	ACAD INACTIVATED/ TRACE CONDUCTED
1383-94	03/08/94	23:45	03/09/94	02:29	73.71/ UNSECURE VITAL AREA DOOR ANSO (DOOR)	PLANT PERSONNEL STOOD BY DOOR/ COMPENSATORY MEASURES ESTABLISHED/ SEARCH COMPLETED
1386-94	03/12/94	12:05	03/12/94	12:26	73.71/ MICROWAVE ZONE INOPERATIVE NSS (ALARMS)	COMPENSATORY MEASURES ESTABLISHED/ OPERATIONAL TEST CONDUCTED
1387-94	03/14/94	16:40	03/14/94	16:40	73.71/ IMPROPERLY CONTROLLED SAFEGUARDS INFORMATION EMPLOYEE (SAFEGUARDS)	DOCUMENTS WERE PROPERLY SECURED/ APERTURE CARDS FOR ASSOCIATED DRAWINGS PULLED/ DOCUMENTS WERE DECLASSIFIED
1389-94	03/17/94	00:12	03/17/94	00:36	73.71/ ACAD OUT OF CONTROL EMPLOYEE (BADGES)	ACAD INACTIVATED/ SUBJECT ESCORTED OUT OF PA/ TRACE CONDUCTED
1390-94	03/17/94	09:54	03/17/94	11:24	73.71/ CPU FAILURE ANSO (COMPUTER)	COMPENSATORY MEASURES ESTABLISHED/ CPU SWAP INITIATED/ TESTING CONDUCTED
1391-94	03/23/94	09:09	03/23/94	09:48	73.71/ MW ZONE INOPERATIVE ANSO (ALARMS)	COMPENSATORY MEASURES ESTABLISHED/ OPERATIONAL TEST CONDUCTED
1392-94	03/25/94	14:15	03/25/94	19:30	73.71/ UNSECURE VITAL AREA DOOR ANSO (DOOR)	COMPENSATORY MEASURES ESTABLISHED/ DOOR REPAIRED/ VADC CONDUCTED

April 7, 1994

VOGTLE ELECTRIC GENERATING PLANT
SECURITY INFORMATION MANAGEMENT SYSTEM
INCIDENT LOG (73.71)
Sorted by Incident Number
01/01/94 Thru 03/31/94

PAGE 4

INCIDENT NUMBER	DATE OF EVENT	TIME OF EVENT	DATE OF REPORT	TIME OF REPORT	EVENT	RESPONSE
1393-94	03/26/94	19:00	03/26/94	20:00	73.71/ INOPERATIVE VA DOOR ANSO (DOOR)	DOOR SECURED/ VADC CONDUCTED/ SEARCH CONDUCTED
1394-94	03/28/94	08:04	03/28/94	09:19	73.71/ AUTOMATIC LOOP RECONFIGURATION ASO (COMPUTER)	ALARM CAPABILITY VERIFIED
1395-94	03/28/94	09:40	03/28/94	13:52	73.71/ INCOMPLETE EMPLOYEE SCREENING (ACCESS AUTHORIZATION CONTROL)	ACCESS AUTHORIZATION WITHDRAWN PENDING COMPLETION OF SCREENING
1396-94	03/28/94	14:32	03/28/94	15:28	73.71/ UNSECURE VITAL AREA DOOR ANSO (UNSECURE DOOR)	DOOR SECURED/ VADC CONDUCTED/ SEARCH CONDUCTED