

November 26, 1990

Docket No. 50-302

DISTRIBUTION

Docket File

RScholl 13'E/4

Mr. Percy M. Beard, Jr.
Senior Vice President,
Nuclear Operations
Florida Power Corporation
ATTN: Manager, Nuclear Operations
Licensing
P. O. Box 219-NA-2I
Crystal River, Florida 32629

NRC & Local PDRs
PD22 Rdg
SVarga
GLainas
HBerkow
HSilver
DMiller
RScholl
EJordan
OGC
ACRS (10)
MSinkule, RII

Dear Mr. Beard:

SUBJECT: UNIMPLEMENTED GENERIC SAFETY ISSUES AT CRYSTAL RIVER UNIT 3

On April 25, 1990 the staff issued Generic Letter 90-04 which requested information concerning the implementation status of certain generic safety issues (GSIs) at your facility. Based on your response to this Generic Letter, dated June 21, 1990, our own records and discussions with your staff, we have updated our database on GSI implementation status. The results of this effort were presented to the Commission at a meeting on October 25, 1990.

The enclosure to this letter summarizes the staff's understanding of the current status of those GSIs which remain unimplemented at Crystal River Unit 3. We appreciate the assistance you provided in responding to Generic Letter 90-04 and we encourage your timely completion of those GSIs listed in the enclosure.

Please contact me if you have any questions or comments about the enclosed information.

Sincerely,

(Original Signed By)

Harley Silver, Project Manager
Project Directorate II-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosure:
As stated

cc w/enclosure:
See next page

OFC	: LA:PD22	: <i>PM:PD22</i>	: <i>D:PD22</i>	:	:
NAME	: <i>DMiller</i>	: HSilver	: HBerkow	:	:
DATE	: 11/26/90	: 11/26/90	: 11/26/90	:	:

OFFICIAL RECORD COPY
Document Name: CRYSTAL GSI LETTER

9012050316 901126
PDR ADOCK 05000302
PDC

11-01
11

Mr. Percy M. Beard, Jr.
Florida Power Corporation

Crystal River Unit No. 3 Nuclear
Generating Plant

cc:

Mr. A. H. Stephens
General Counsel
Florida Power Corporation
MAC - A5D
P. O. Box 14042
St. Petersburg, Florida 33733

State Planning and Development
Clearinghouse
Office of Planning and Budget
Executive Office of the Governor
The Capitol Building
Tallahassee, Florida 32301

Mr. P. F. McKee, Director
Nuclear Plant Operations
Florida Power Corporation
P. O. Box 219-NA-2C
Crystal River, Florida 32629

Chairman
Board of County Commissioners
Citrus County
110 North Apopka Avenue
Inverness, Florida 32650

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Generation Division
1700 Rockville Pike, Suite 525
Rockville, Maryland 20852

Mr. Rolf C. Widell, Director
Nuclear Operations Site Support
Florida Power Corporation
P.O. Box 219-NA-2I
Crystal River, Florida 32629

Senior Resident Inspector
Crystal River Unit 3
U.S. Nuclear Regulatory Commission
6745 N. Tallahassee Road
Crystal River, Florida 32629

Mr. Gary L. Bolt
Vice President, Nuclear Production
Florida Power Corporation
P. O. Box 219-SA-2C
Crystal River, Florida 32629

Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta Street N.W., Suite 2900
Atlanta, Georgia 30323

Mr. Jacob Daniel Nash
Office of Radiation Control
Department of Health and
Rehabilitative Services
1317 Winewood Blvd.
Tallahassee, Florida 32399-0700

Administrator
Department of Environmental Regulation
Power Plant Siting Section
State of Florida
2600 Blair Stone Road
Tallahassee, Florida 32301

Attorney General
Department of Legal Affairs
The Capitol
Tallahassee, Florida 32304

ENCLOSURE

UNIMPLEMENTED GSIs AT CRYSTAL RIVER UNIT 3

<u>GSI NO.</u>	<u>TITLE</u>	<u>PROJECTED IMPLEMENTATION DATE</u>	<u>REMARKS</u>
43	Reliability of Air Systems	December 31, 1990	Complete except for testing HVAC dampers
75	Salem ATWS Item 2.2.2, Vendor Interface for Safety-Related Components	April 26, 1991	Complete except for revision of B&W program to include revised test procedures and updated replacement parts information, and to identify list of key vendors.
75	Item 4.3, Reactor Trip System Reliability-TS Changes	TBD	Shunt trip TS to handled under TSIP.
75	Item 4.4, Reactor Trip System Reliability	TBD	Complete except for SCR tests, to handled under TSIP.
124	Auxiliary Feedwater System Reliability	October 30, 1992	
A-35	Adequacy of Offsite Power Supplies	TBD	Design modification complete. TS to be handled under TSIP.