



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D. C. 20555-0001

Docket file

April 13, 1994

Docket No. 50-423

Mr. John F. Opeka
Executive Vice President, Nuclear
Connecticut Yankee Atomic Power Company
Northeast Nuclear Energy Company
Post Office Box 270
Hartford, Connecticut 06141-0270

Dear Mr. Opeka:

SUBJECT: GENERIC LETTER (GL) 92-01, REVISION 1, "REACTOR VESSEL STRUCTURAL INTEGRITY," MILLSTONE, UNIT 3 (TAC NO. M8384)

By letter dated July 6, 1992, Northeast Nuclear Energy Company (NNECO) provided its response to GL 92-01, Revision 1. The NRC staff has completed its review of your response. Based on its review, the staff has determined that NNECO has provided the information requested in GL 92-01.

The GL is part of the staff's program to evaluate reactor vessel integrity for Pressurized Water Reactors (PWRs) and Boiling Water Reactors (BWRs). The information provided in response to GL 92-01, including previously docketed information, is being used to confirm that licensees satisfy the requirements and commitments necessary to ensure reactor vessel integrity for their facilities.

A substantial amount of information was provided in response to GL 92-01, Revision 1. These data have been entered into a computerized data base designated Reactor Vessel Integrity Database (RVID). The RVID contains the following tables: A pressurized thermal shock (PTS) table for PWRs, a pressure-temperature limit table for BWRs and an upper-shelf energy (USE) table for PWRs and BWRs. Enclosure 1 provides the PTS and/or pressure temperature table, Enclosure 2 provides the USE table for Millstone 3, and Enclosure 3 provides a key for the nomenclature used in the tables. The tables include the data necessary to perform USE, pressure-temperature limit, and RT_{pts} evaluations. These data were taken from your response to GL 92-01 and previously docketed information. The information in the RVID for Millstone 3 will be considered accurate at this point in time and will be used in the staff's assessments related to vessel structural integrity. References to the specific source of the data are provided in the tables.

We request that you verify the information you have provided for Millstone 3 has been accurately entered in the data base. No response is necessary unless an inconsistency is identified. If no comments are received within 30 days from the date of this letter, the staff will consider your actions related to GL 92-01, Revision 1, to be complete.

150045

NRC FILE CENTER COPY

9404210016 940413
PDR ADOCK 05000423
P PDR

DF01

The information requested by this letter is within the scope of the overall burden estimated in GL 92-01, Revision 1, "Reactor Vessel Structural Integrity, 10 CFR 50.54(f)." The estimated average number of burden hours is 200 person hours for each addressee's response. This estimate pertains only to the identified response-related matters and does not include the time required to implement actions required by the regulations. This action is covered by the Office of Management and Budget Clearance Number 3150-0011, which expires June 30, 1994.

Sincerely,

Original signed by:

Vernon L. Rooney, Senior Project Manager
Project Directorate I-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosures:

- 1. Pressurized Thermal Shock or Pressure-Temperature Limit Table
- 2. Upper-Shelf Energy Table
- 3. Nomenclature Key

cc w/enclosures:
See next page

DISTRIBUTION:

| | |
|------------------|-----------------|
| Docket File | VRooney |
| NRC & Local PDRs | OGC |
| PDI-4 Plant | ACRS (10) |
| SVarga | LDoerflein, RGI |
| JCalvo | DMcDonald |
| SNorris | Belliot |

| | | | | | |
|--------|----------|------------|---------|-----|-----|
| OFFICE | LA:PDI-4 | PM:PDI-4 | D:PDI-4 | | |
| NAME | SNorris | VRooney:bp | JStolz | | |
| DATE | 4/13/94 | 4/13/94 | 4/13/94 | / / | / / |


OFFICIAL RECORD COPY

Document Name: G:\ROONEY\M87863.AMD

April 13, 1994

The information requested by this letter is within the scope of the overall burden estimated in GL 92-01, Revision 1, "Reactor Vessel Structural Integrity, 10 CFR 50.54(f)." The estimated average number of burden hours is 200 person hours for each addressee's response. This estimate pertains only to the identified response-related matters and does not include the time required to implement actions required by the regulations. This action is covered by the Office of Management and Budget Clearance Number 3150-0011, which expires June 30, 1994.

Sincerely,



Vernon L. Rooney, Senior Project Manager
Project Directorate I-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosures:

1. Pressurized Thermal Shock or
Pressure-Temperature Limit
Table
2. Upper-Shelf Energy Table
3. Nomenclature Key

cc w/enclosures:
See next page

Mr. John F. Opeka
Northeast Nuclear Energy Company

Millstone Nuclear Power Station
Unit 3

cc:

Gerald Garfield, Esquire
Day, Berry and Howard
Counselors at Law
City Place
Hartford, Connecticut 06103-3499

R. M. Kacich, Director
Nuclear Planning, Licensing & Budgeting
Northeast Utilities Service Company
Post Office Box 270
Hartford, Connecticut 06141-0270

J. M. Solymosy, Director
Nuclear Quality & Assessment Services
Northeast Utilities Service Company
Post Office Box 270
Hartford, Connecticut 06141-0270

J. P. Stetz, Vice President
Haddam Neck Plant
Connecticut Yankee Atomic Power Company
362 Injun Hollow Road
East Hampton, Connecticut 06424-3099

Kevin T. A. McCarthy, Director
Monitoring and Radiation Division
Department of Environmental Protection
79 Elm Street
Hartford, Connecticut 06106-5127

Regional Administrator
Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

Allan Johanson, Assistant Director
Office of Policy and Management
Policy Development and Planning Division
80 Washington Street
Hartford, Connecticut 06106

First Selectmen
Town of Waterford
Hall of Records
200 Boston Post Road
Waterford, Connecticut 06385

S. E. Scace, Vice President
Nuclear Operations Services
Northeast Utilities Service Company
Post Office Box 270
Hartford, Connecticut 06141-0270

P. D. Swetland, Resident Inspector
Millstone Nuclear Power Station
c/o U.S. Nuclear Regulatory Commission
Post Office Box 513
Niantic, Connecticut 06357

F. R. Dacimo, Nuclear Unit Director
Millstone Unit No. 3
Northeast Nuclear Energy Company
Post Office Box 128
Waterford, Connecticut 06385

M. R. Scully, Executive Director
Connecticut Municipal Electric
Energy Cooperative
30 Stott Avenue
Norwich, Connecticut 06360

Burlington Electric Department
c/o Robert E. Fletcher, Esq.
271 South Union Street
Burlington, Vermont 05402

David W. Graham
Fuel Supply Planning Manager
Massachusetts Municipal Wholesale
Electric Company
Post Office Box 426
Ludlow, Massachusetts 01056

Nicholas S. Reynolds
Winston & Strawn
1400 L Street, NW
Washington, DC 20005-3502

Donald B. Miller, Jr.
Senior Vice President
Millstone Station
Northeast Nuclear Energy Company
Post Office Box 128
Waterford, Connecticut 06385

Summary File for Pressurized Thermal Shock

| Plant Name | Beltline Ident. | Heat No. Ident. | ID Weut. Fluence at EOL/EPY | IRT _{max} | Method of Determin. IRT _{max} | Chemistry Factor | Method of Determin. CF | %Cu | %Ni |
|--|---------------------|-----------------|-----------------------------|--------------------|--|------------------|------------------------|------|------|
| Millstone Unit 3 EOL: 11/25/2025 | Int. Shell B9805-1 | C4039-2 | 3.397E19 | 60°F | Plant Specific | 31 | Table | 0.05 | 0.62 |
| | Int. Shell B9805-2 | C4068-1 | 3.397E19 | 10°F | Plant Specific | 31 | Table | 0.05 | 0.62 |
| | Int. Shell B9805-3 | C4028-1 | 3.397E19 | 0°F | Plant Specific | 26 | Table | 0.04 | 0.62 |
| | Lower Shell B9820-1 | B8961-1 | 3.397E19 | 10°F | Plant Specific | 44 | Table | 0.07 | 0.62 |
| | Lower Shell B9820-2 | D1242-2 | 3.397E19 | 40°F | Plant Specific | 37 | Table | 0.06 | 0.6 |
| | Lower Shell B9820-3 | D1242-1 | 3.397E19 | 20°F | Plant Specific | 31 | Table | 0.05 | 0.58 |
| | Welds | 4P6052 | 3.397E19 | -50°F | Plant Specific | 49.25 | Table | 0.07 | 0.15 |

Reference for Millstone 3

Fluence, chemical composition, and IRT_{max} data are from July 6, 1992, Letter from J. F. Opeka (NNECo) to USNRC Document Control Desk, subject: Haddam Neck Plant; Millstone Power Station, Units 1, 2, and 3: Reactor Vessel Structural Integrity, 10CFR50.54(f), (Generic Letter 92-01, Revision 1)

Summary File for Upper Shelf Energy

| Plant Name | Beltline Ident. | Heat No. | Material Type | 1/4T USE at EOL/EPFY | 1/4T Neutron Fluence at EOL/EPFY | Unirrad. USE | Method of Determin. Unirrad. USE |
|-----------------------------------|---------------------|----------|----------------|----------------------|----------------------------------|--------------|----------------------------------|
| Millstone 3 EOL: 11/25/2025 | Int. Shell B9805-1 | C4039-2 | A 533B-1 | 72 | 2.04E19 | 93 | Direct |
| | Int. Shell B9805-2 | C4068-1 | A 533B-1 | 70 | 2.04E19 | 90 | Direct |
| | Int. Shell B9805-3 | C4028-1 | A 533B-1 | 83 | 2.04E19 | 107 | Direct |
| | Lower Shell B9820-1 | B8961-1 | A 533B-1 | 60 | 2.04E19 | 77 | Direct |
| | Lower Shell B9820-2 | D1242-2 | A 533B-1 | 59 | 2.04E19 | 76 | Direct |
| | Lower Shell B9820-3 | D1242-1 | A 533B-1 | 62 | 2.04E19 | 80 | Direct |
| | Welds | 4P6052 | Linde 0091 SAW | 107 | 2.04E19 | 143 | Direct |

Reference

Fluence, chemical composition, and USE data are from July 6, 1992, letter from J. F. Opeka (NNECo) to USNRC Document Control Desk, subject: Middletown Neck Plant; Millstone Power Station, Units 1, 2, and 3: Reactor Vessel Structural Integrity, 10CFR50.54(f), (Generic Letter 92-01, Revision 1)

WCAP-11878, June 1988 indicates all plate data are transverse

PRESSURIZED THERMAL SHOCK TABLES AND USE TABLES FOR ALL PWR PLANTSNOMENCLATURE

Pressurized Thermal Shock Table

- Column 1: Plant name and date of expiration of license.
 Column 2: Beltline material location identification.
 Column 3: Beltline material heat number; for some welds that a single-wire or tandem-wire process has been reported, (S) indicates single wire was used in the SAW process, (T) indicates tandem wire was used in the SAW process.
 Column 4: End-of-life (EOL) neutron fluence at vessel inner wall; cited directly from inner diameter (ID) value or calculated by using Regulatory Guide (RG) 1.99, Revision 2, neutron fluence attenuation methodology from the quarter thickness (T/4) value reported in the latest submittal (GL 92-01, PTS, or P/T limits submittals).
 Column 5: Unirradiated reference temperature.
 Column 6: Method of determining unirradiated reference temperature (IRT).

Plant-Specific

This indicates that the IRT was determined from tests on material removed from the same heat of the beltline material.

MTEB 5-2

This indicates that the unirradiated reference temperature was determined from following MTEB 5-2 guidelines for cases where the IRT was not determined using American Society of Mechanical Engineers Boiler and Pressure Vessel Code, Section III, NB-2331, methodology.

Generic

This indicates that the unirradiated reference temperature was determined from the mean value of tests on material of similar types.

- Column 7: Chemistry factor for irradiated reference temperature evaluation.
 Column 8: Method of determining chemistry factor.

Table

This indicates that the chemistry factor was determined from the chemistry factor tables in RG 1.99, Revision 2.

Calculated

This indicates that the chemistry factor was determined from surveillance data via procedures described in RG 1.99, Revision 2.

Column 9: Copper content; cited directly from licensee value except when more than one value was reported. (Staff used the average value in the latter case.)

No Data

This indicates that no copper data has been reported and the default value in RG 1.99, Revision 2, will be used by the staff.

Column 10: Nickel content; cited directly from licensee value except when more than one value was reported. (Staff used the average value in the latter case.)

No Data

This indicates that no nickel data has been reported and the default value in RG 1.99, Revision 2, will be used by the staff.

Upper Shelf Energy Table

- Column 1: Plant name and date of expiration of license.
Column 2: Beltline material location identification.
Column 3: Beltline material heat number; for some welds that a single-wire or tandem-wire process has been reported, (S) indicates single wire was used in the SAW process. (T) indicates tandem wire was used in the SAW process.
Column 4: Material type; plate types include A 533B-1, A 302B, A 302B Mod., and forging A 508-2; weld types include SAW welds using Linde 80, 0091, 124, 1092, ARCOS-B5 flux, Rotterdam welds using Graw Lo, SMIT 89, LW 320, and SAF 89 flux, and SMAW welds using no flux.
Column 5: EOL upper-shelf energy (USE) at T/4; calculated by using the EOL fluence and either the copper value or the surveillance data. (Both methods are described in RG 1.99, Revision 2.)

EVA

This indicates that the USE issue may be covered by the approved equivalent margins analysis in a topical report.

- Column 6: EOL neutron fluence at T/4 from vessel inner wall; cited directly from T/4 value or calculated by using RG 1.99, Revision 2, neutron fluence attenuation methodology from the ID value reported in the latest submittal (GL 92-01, PTS, or P/T limits submittals).

Column 7: Unirradiated USE.

EMA

This indicates that the USE issue may be covered by the approved equivalent margins analysis in a topical report.

Column 8: Method of determining unirradiated USE.

Direct

For plates, this indicates that the unirradiated USE was from a transverse specimen. For welds, this indicates that the unirradiated USE was from test date.

65%

This indicates that the unirradiated USE was 65% of the USE from a longitudinal specimen.

Generic

This indicates that the unirradiated USE was reported by the licensee from other plants with similar materials to the beltline material.

NRC generic

This indicates that the unirradiated USE was derived by the staff from other plants with similar materials to the beltline material.

10, 30, 40, or 50 °F

This indicates that the unirradiated USE was derived from Charpy test conducted at 10, 30, 40, or 50 °F.

Surv. Weld

This indicates that the unirradiated USE was from the surveillance weld having the same weld wire heat number.

Equip. to Surv. Weld

This indicates that the unirradiated USE was from the surveillance weld having different weld wire heat number.

Sister Plant

This indicates that the unirradiated USE was derived by using the reported value from other plants with the same weld wire heat number.

Blank

Indicates that there is insufficient data to determine the unirradiated USE.