



231 W Michigan, PO Box 2046, Milwaukee, WI 53201-2046

(414) 221-2345

April 15, 1994

NPL 94-0146

Document Control Desk
U.S. NUCLEAR REGULATORY COMMISSION
Mail Station P1-137
Washington, DC 20555

Gentlemen:

DOCKETS 50-266 AND 50-301
RESOLUTION OF COMMITMENT IMPLEMENTATION
INSTRUMENTATION TO FOLLOW THE COURSE OF AN ACCIDENT
REGULATORY GUIDE 1.97
POINT BEACH NUCLEAR PLANT, UNITS 1 AND 2

Your letter dated November 30, 1993, titled "Instrumentation To Follow The Course Of An Accident (Regulatory Guide 1.97)," discussed requests from pressurized water reactor (PWR) licensees to relax the environmental qualification requirement for accumulator level and pressure monitoring instrumentation. In that letter you also indicated that we had not finalized our commitment regarding installation of instrumentation to monitor accumulator level and requested that we notify you of the actions we plan to take along with our schedule for implementation.

Upon review of our Regulatory Guide 1.97 documentation, we verified that you approved the environmental qualification of our accumulator tank level and pressure instrumentation in your safety evaluation dated July 11, 1986. This letter is to confirm that in a meeting on April 6, 1994, with a member of your staff, you agreed that the issue described in the November 30, 1993, letter regarding accumulator level has been adequately addressed. Therefore, we consider this issue resolved and no further action is necessary.

Please contact us if any further information is required.

Sincerely,

A handwritten signature in cursive script, appearing to read 'G. M. Krieser'.

G. M. Krieser
Manager
Industry & Regulatory Services

cc: NRC Resident Inspector
NRC Regional Administrator

9404210052 940415
PDR ADDCK 05000301
PDR

ADD3 1/0