



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

October 13, 1982

JAMES P. McGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Fire Door Open - No Fire Watch
Stationed
Reference: LER 82-075/99 X-0
AECM-82/475

During routine surveillance in preparing for non nuclear heatup, it was discovered that the Steam Tunnel Fire Door 1A230 was open. The door could not be closed due to cables (being used for maintenance activity in the Steam Tunnel) installed in the doorway. This is being submitted as a special report per Technical Specification 3.7.7 and 6.9.2. Attached is LER 82-075/99 X-0.

Yours truly,

JPM:sap
Attachment

- cc: Mr. N. L. Stampley (w/a)
- Mr. R. B. McGehee (w/o)
- Mr. T. B. Conner (w/o)
- Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

IE22

OFFICIAL COPY

8210190561 821013
PDR ADOCK 05000416
S PDR

USNRC REGION II
ATLANTA, GEORGIA

92 OCT 14 A 9:30