	LICENSEE EVENT REPORT Attachment to AECM-82/475
	CONTROL BLOCK: Page 1 of 1 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)
0 1 7 8	M S G G S 1 2 0 0 - 0 0 0 0 - 0 0 3 4 1 1 1 1 1 4 5 5 S LICENSE CODE 14 15 LICENSE NUMBER 26 LICENSE TYPE 30 57 CAT 58
0 1 7 8	REPORT L 6 0 5 0 0 0 4 1 6 0 9 1 5 8 2 8 1 0 1 3 8 2 9 EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10 [During routine surveillance in preparing for non nuclear heatup (Reactor Recirculation)
0 3	Pump for Heatup), it was discovered that Steam Tunnel Fire Door 1A230 was open with no
0 4	fire watch stationed. The door could not be closed due to the cables (being used for
0 5	maintenance activity in the Steam Tunnel) installed in the doorway. T.S.3.7.7 requires
06	all fire rated assemblies to be operational at all times or a fire watch stationed
0 7	[until the fire rated assemblies are operational. There was no release of radioactivity,]
08	effect upon public health or safety, or a threat to plant safety.
0 9 7 8	SYSTEM CAUSE CAUSE SUBCODE SUS
	CAUSE DESCRIPTION AND CORRECTIVE ACTIONS COURT C
10	The fire door was required to be open to allow maintenance work in the steam tunnel.
11	An hourly fire watch was established as required by T.S.3.7.7. The fire watch was
1 2	maintained for 13 days and 21 hours until the work was complete. Upon completion of
1 3	the work, the fire door was secured. No further action was required.
14	
7 8	PACILITY STATUS 30 METHOD OF DISCOVERY DESCRIPTION 32 B 30 NA B 31 Routine Surveillance
	CONTENT CONTENT 12 13 44 45 46 10 10 11 12 13 13 14 15 16 16 16 16 16 16 16 16 16 16 16 16 16
1 7	PERSONNEL EXPOSURES NUMBER 10 0 0 37 Z 38 DESCRIPTION 39 NA 0 11 12 13
1 8 7 8	PERSONNE! INJURIES NUMBER DESCRIPTION 41 NA 9 11 12 8210190567 821013
1 9	Z 42 NA S PDR
20	PUBLICITY ISSUED DESCRIPTION (45) NA NA NRC USE ONLY NA 68 69 80 5
	NAME OF PREPARER Original Signed by W. H. Chenault PHONE: