

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 MIDCIC1 2000-000000-000 341111 4 _____ 5

CON'T REPORT SOURCE L 6050000315 7090882 8100882 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10 DURING A ROUTINE TOUR DURING UNIT SHUTDOWN, AN OPERATOR DISCOVERED THE LOW PRESSURE CO2 SYSTEM FOR THE AB DIESEL GENERATOR ROOM ISOLATED WITH NO FIRE WATCH POSTED, CONTRARY TO T.S. 3.7.9.3. FIRE DETECTION SYSTEMS REMAINED OPERABLE. THE CONTROL ROOM WAS NOTIFIED AND THE CO2 SYSTEM WAS UNISOLATED. PUBLIC HEALTH AND SAFETY WERE NOT AFFECTED. PREVIOUS OCCURRENCES: 050/315 - 82-037, 044, 045, AND 068; 50/316 - 82-054 AND 076.

09 SYSTEM CODE AB 11 CAUSE CODE A 12 CAUSE SUBCODE X 13 COMPONENT CODE I N S T R U 14 COMP SUBCODE S 15 VALVE SUBCODE Z 16

17 LER NO REPORT NUMBER 82 21 EVENT YEAR 82 22 SEQUENTIAL REPORT NO. 082 24 OCCURRENCE CODE 03 28 REPORT TYPE L 30 REVISION NO 0 32 ACTION TAKEN H 18 FUTURE ACTION Z 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0000 22 ATTACHMENT SUBMITTED N 23 NPRD-4 FORM SUB. N 24 PRIME COMP. SUPPLIER A 25 COMPONENT MANUFACTURER C11215 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27 THE CO2 SYSTEM WAS APPARENTLY LEFT ISOLATED FOLLOWING A PREVIOUS EXIT. THE RESPONSIBLE INDIVIDUAL COULD NOT BE CONCLUSIVELY DETERMINED. SINCE THIS EVENT, ALL PLANT AND CONSTRUCTION PERSONNEL HAVE BEEN TRAINED IN FIRE DOOR AND CO2 ISOLATION REQUIREMENTS AND PROCEDURES.

15 FACILITY STATUS H 28 % POWER 000 29 OTHER STATUS NA 30 METHOD OF DISCOVERY B 31 DISCOVERY DESCRIPTION OPERATOR OBSERVATION 32

16 RELEASED OF RELEASE Z 33 Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36

17 PERSONNEL EXPOSURES NUMBER 000 37 TYPE Z 38 DESCRIPTION NA 39

18 PERSONNEL INJURIES NUMBER 000 40 DESCRIPTION NA 41

19 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43 8210190588 821009 PDR ADOCK 05000315 S PDR

20 PUBLICITY ISSUED N 44 DESCRIPTION NA 45

NAME OF PREPARER R. H. PIEHL PHONE 616-465-5901