

December 3, 1990

Docket No. 50-333

Distribution

Mr. John C. Brons  
Executive Vice President - Nuclear Generation  
Power Authority of the State of New York  
123 Main Street  
White Plains, New York 10601

Docket File	GH111 (4)
NRC & Local PDRs	Wanda Jones
SVarga	JCalvo
BBoger	ACRS (10)
CVogan	GPA/PA
RACapra	OC/LFMB
OGC	SPLB
CHagan	CMcCracken
JLinville	Plant File
EJordan	

Dear Mr. Brons:

SUBJECT: AMENDMENT NO. 166 TO THE FITZPATRICK TECHNICAL SPECIFICATIONS  
(TAC NO. 76967)

By letter dated June 12, 1990, you requested an amendment to the Technical Specifications (TS) for the FitzPatrick Nuclear Power Plant to incorporate containment isolation valves in the Keep-Full Systems for the Residual Heat Removal (RHR) System and the Core Spray (CS) System. By letter dated October 24, 1990, the NRC issued Amendment Number 166 for this purpose.

A subsequent review of the safety evaluation accompanying the amendment determined that certain clarifications are necessary. The safety evaluation stated that the Keep-Full Systems associated with the CS Systems have not been used in the past. It also stated that the pumps are operable from the Control Room. It is now our understanding that they have been in operation since initial plant startup, and that the pumps are operated from a location outside of the Control Room. Only the Keep-Full Systems associated with the RHR Systems have not yet been operated and have pumps which are operable from the Control Room.

We have evaluated these clarifications and determined that they have no effect on the conclusion reached by the staff that addition of the keep-full pump discharge check valves to the primary containment isolation valve table was satisfactory.

Sincerely,

*David E. LaBarge*  
 David E. LaBarge, Project Manager  
 Project Directorate I-1  
 Division of Reactor Projects - I/II  
 Office of Nuclear Reactor Regulation

cc: See next page

PDI-1:LA  
CVogan  
11/13/90

PDI-1:PM  
DLaBarge:av1  
11/13/90

*11/13/90*  
 SPLB  
 CMcCracken  
 12/13/90

*ROC*  
 D:PDI-1  
 RACapra  
 12/13/90

DOCUMENT NAME: LTR TO BRONS/TAC NO. 76967

9012100092 901203  
PDR ADDCK 05000333  
P PNU

*QF01  
1/0*



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

December 3, 1990

Docket No. 50-333

Mr. John C. Brons  
Executive Vice President - Nuclear Generation  
Power Authority of the State of New York  
123 Main Street  
White Plains, New York 10601

Dear Mr. Brons:

SUBJECT: AMENDMENT NO. 166 TO THE FITZPATRICK TECHNICAL SPECIFICATIONS  
(TAC NO. 76967)

By letter dated June 12, 1990, you requested an amendment to the Technical Specifications (TS) for the FitzPatrick Nuclear Power Plant to incorporate containment isolation valves in the Keep-Full Systems for the Residual Heat Removal (RHR) System and the Core Spray (CS) System. By letter dated October 24, 1990, the NRC issued Amendment Number 166 for this purpose.

A subsequent review of the safety evaluation accompanying the amendment determined that certain clarifications are necessary. The safety evaluation stated that the Keep-Full Systems associated with the CS Systems have not been used in the past. It also stated that the pumps are operable from the Control Room. It is now our understanding that they have been in operation since initial plant startup, and that the pumps are operated from a location outside of the Control Room. Only the Keep-Full Systems associated with the RHR Systems have not yet been operated and have pumps which are operable from the Control Room.

We have evaluated these clarifications and determined that they have no effect on the conclusion reached by the staff that addition of the keep-full pump discharge check valves to the primary containment isolation valve table was satisfactory.

Sincerely,

A handwritten signature in cursive script, appearing to read "D. LaBarge".

David E. LaBarge, Project Manager  
Project Directorate I-1  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

cc: See next page

Mr. John C. Brons  
Power Authority of the State of New York

James A. FitzPatrick Nuclear  
Power Plant

Mr. Gerald C. Goldstein  
Assistant General Counsel  
Power Authority of the State  
of New York  
1633 Broadway  
New York, New York 10019

Ms. Donna Ross  
New York State Energy Office  
2 Empire State Plaza  
16th Floor  
Albany, New York 12223

Resident Inspector's Office  
U. S. Nuclear Regulatory Commission  
Post Office Box 136  
Lycoming, New York 13093

Regional Administrator, Region I  
U.S. Nuclear Regulatory Commission  
475 Allendale Road  
King of Prussia, Pennsylvania 19406

Mr. William Fernandez  
Resident Manager  
James A. FitzPatrick Nuclear  
Power Plant  
Post Office Box 41  
Lycoming, New York 13093

Mr. A. Klausman  
Senior Vice President - Appraisal  
and Compliance Services  
Power Authority of the State  
of New York  
1633 Broadway  
New York, New York 10019

Mr. J. A. Gray, Jr.  
Director Nuclear Licensing - BWR  
Power Authority of the State  
of New York  
123 Main Street  
White Plains, New York 10601

Mr. George Wilverding, Manager  
Nuclear Safety Evaluation  
Power Authority of the State  
of New York  
123 Main Street  
White Plains, New York 10601

Supervisor  
Town of Scriba  
R. D. #4  
Oswego, New York 13126

Mr. R. E. Beedle  
Vice President Nuclear Support  
Power Authority of the State  
of New York  
123 Main Street  
White Plains, New York 10601

Mr. J. P. Bayne, President  
Power Authority of the State  
of New York  
1633 Broadway  
New York, New York 10019  
1633 Broadway

Mr. S. S. Zulla  
Vice President Nuclear Engineering  
Power Authority of the State  
of New York  
123 Main Street  
White Plains, New York 10601

Mr. Richard Patch  
Quality Assurance Superintendent  
James A. FitzPatrick Nuclear  
Power Plant  
Post Office Box 41  
Lycoming, New York 13093

Mr. William Josiger, Vice President  
Operations and Maintenance  
Power Authority of the State  
of New York  
123 Main Street  
White Plains, New York 10601

Charlie Donaldson, Esquire  
Assistant Attorney General  
New York Department of Law  
120 Broadway  
New York, New York 10271