

B 71267

AL IANATONIS

TO: DIRECTOR, OFFICE OF INSPECTION & ENFORCEMENT, REGION II

DUKE POWER COMPANY
OCONEE NUCLEAR STATION
NRC NOTIFICATION OF REPORTABLE OCCURRENCE

82 OCT 15 P 2
USNRC REGION II
ATLANTA, GEORGIA

TIME/DATE OF INCIDENT 1242 10/14/82 TIME/DATE OF DISCOVERY 1242 10/14/82

UNIT(S) 2, 3 UNIT STATUS AT TIME OF INCIDENT U2 100% U3 COLD SD

DESCRIPTION OF INCIDENT: THE UNIT 2 COOL RELIEF VALVES WERE
DECLARED INOPERABLE DUE TO ANALYSIS PERFORMED RESULTING
FROM A BWN PRELIMINARY SAFETY CONCERN. UNIT 3 VALVES
HAD BEEN REMOVED AND SENT OFFSITE FOR VALVE RING ADJUSTMENT.
UNIT 2 BEGAN AN IMMEDIATE SHUTDOWN, IN ACCORDANCE WITH
T.S. 3.0.

HOW INCIDENT WAS DISCOVERED: EVALUATION AND ANALYSIS PERFORMED
AFTER RECEIVING A BWN PRELIMINARY SAFETY CONCERN.

IMMEDIATE CORRECTIVE ACTION: UNIT 2 BEGAN AN IMMEDIATE SHUT
DOWN IN ACCORDANCE WITH THE 12 HOUR ACTION STATEMENT
IN T.S. 3.0. UNIT 3 WAS STILL IN COLD SD. AN
IMMEDIATE T.S. CHANGE WAS APPROVED BY THE NRC
FOR CONTINUED OPERATION OF UNIT 1 UNTIL 10/29/82.

REPORTABLE PURSUANT TO TECHNICAL SPECIFICATION 6.6.2.1 a. 9

DATE REPORT DUE TO NRC/OIE 10/29/82

TIME/DATE TELECOPIED OR OTHERWISE TRANSMITTED TO NRC/OIE _____

PREPARED BY R.R. Ryan PHONE (803) 982-5363

IE 22