

Docket No. 50-423  
B14635

Attachment 1

Millstone Nuclear Power Station, Unit No. 3

Proposed Revision to Technical Specifications  
Area Temperature Monitoring Surveillance Requirements  
Markup Pages

April 1994

PLANT SYSTEMS

3/4.7.14 AREA TEMPERATURE MONITORING

LIMITING CONDITION FOR OPERATION

3.7.14 The temperature limit of each area shown in Table 3.7-6 shall not be exceeded.

APPLICABILITY: Whenever the equipment in an affected area is required to be OPERABLE.

ACTION:

With one or more areas exceeding the temperature limit(s) shown in Table 3.7-6:

- a. By less than 20°F and for less than 8 hours, record the cumulative time and the amount by which the temperature in the affected area(s) exceeded the limit(s).
- b. By less than 20°F and for more than 8 hours, prepare and submit to the Commission within 30 days, pursuant to Specification 6.9.2, a Special Report that provides a record of the cumulative time and the amount by which the temperature in the affected area(s) exceeded the limit(s) and an analysis to demonstrate the continued OPERABILITY of the affected equipment. The provisions of Specification 3.0.3 are not applicable.
- c. With one or more areas exceeding the temperature limit(s) shown in Table 3.7-6 by more than 20°F, prepare and submit a Special Report as required by ACTION b. above and within 4 hours either restore area(s) to within the temperature limit(s) or declare the equipment in the affected area(s) inoperable.

6  
1

SURVEILLANCE REQUIREMENTS

4.7.14 The temperature in each of the areas shown in Table 3.7-6 shall be determined to be within its limit; ~~at least once per 12 hours.~~

- a. At least once per seven days when the alarm is operable, and;
- b. At least once per 12 hours when the alarm is inoperable.

Docket No. 50-423  
B14635

Attachment 2

Millstone Nuclear Power Station, Unit No. 3

Proposed Revision to Technical Specifications  
Area Temperature Monitoring Surveillance Requirements  
Retyped Pages

April 1994

## PLANT SYSTEMS

### 3/4.7.14 AREA TEMPERATURE MONITORING

#### LIMITING CONDITION FOR OPERATION

---

3.7.14 The temperature limit of each area shown in Table 3.7-6 shall not be exceeded.

APPLICABILITY: Whenever the equipment in an affected area is required to be OPERABLE.

#### ACTION:

With one or more areas exceeding the temperature limit(s) shown in Table 3.7-6:

- a. By less than 20°F and for less than 8 hours, record the cumulative time and the amount by which the temperature in the affected area(s) exceeded the limit(s).
- b. By less than 20°F and for more than 8 hours, prepare and submit to the Commission within 30 days, pursuant to Specification 6.9.2, a Special Report that provides a record of the cumulative time and the amount by which the temperature in the affected area(s) exceeded the limit(s) and an analysis to demonstrate the continued OPERABILITY of the affected equipment. The provisions of Specification 3.0.3 are not applicable.
- c. With one or more areas exceeding the temperature limit(s) shown in Table 3.7-6 by more than 20°F, prepare and submit a Special Report as required by ACTION b. above and within 4 hours either restore the area(s) to within the temperature limit(s) or declare the equipment in the affected area(s) inoperable.

#### SURVEILLANCE REQUIREMENTS

---

4.7.14 The temperature in each of the areas shown in Table 3.7-6 shall be determined to be within its limits:

- a. At least once per seven days when the alarm is OPERABLE, and;
- b. At least once per 12 hours when the alarm is inoperable.