NRC FORM 366 U. S. NUCLEAR REGULATORY COMMISSION (7.77) LICENSEE EVENT REPORT CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION) 0 0 0 0 0 - 0 G S (2) 0 0 0 34 LICENSEE CODE LICENSE NUMBER CON'T REPORT 0 1 2 7 0 9 1 2 8 2 L(6) 0 5 0 0 8 1 0 0 6 8 2 74 75 REPORT DATE 0 SOURCE DOCKET NUMBER EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10) On two occasions, on September 12 and September 14, 1982, the pressurizer pressure 0 2 controller was observed to shift to the manual mode with pressure decreasing below the 0 3 Technical Specification limit of 2200 PSIA. In both instances, Action Statement 3.2.5 0 4 was entered, the controller was shifted back to auto, and pressure was increased to 0 5 within limits. The action statement was terminated within the specified 2 hour limit 0 6 on both occasions. The occurrences constituted operation in a degraded mode in 0 7 accordance with Technical Specification 6.9.1.9.b. (82-038, 81-101) 0 8 9 8 80 SYSTEM CAUSE CAUSE COMP VALVE CODE SUBCODE COMPONENT CODE SUBCODE B E (12) (11 G (13) 19 NS C (15) I T R U (14 Z (16) 18 OCCURRENCE SEQUENTIAL REVISION REPORT EVENT YEAR REPORT NO. LER RO CODE TYPE NC. REPORT 0 7 0 0 3 L 0 NUMBER 28 30 32 ACTION NPRD-4 FORM SUB FUTURE EFFECT METHOD ATTACHMENT PRIME COMP. COMPONENT (22 ON PLANT HOURS MANUFACTURER SUPPLIER C Z (19 Z (20 Z (21) Y 24 0 0 0 0 Y (23) 0 2 18) A (25 H 11 (26 CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27 The occurrences were attributed to an intermittant problem in either the pressure 1 0 controller or the manual-auto station. The manual-auto station was replaced and the 1 1 channel was satisfactorily tested; no further problems have been noted. 1 3 1 4 80 FACILITY METHOD OF (30) % POWER OTHER STATUS DISCOVERY DISCOVERY DESCRIPTION (32) E (28 5 0 0 A(31) Operator Observation 80 ACTIVITY CONTENT AMOUNT OF ACTIVITY (35) OF RELEASE LOCATION OF RELEASE (36) RELEASED Z (33) Z (34) N/A N/A 10 80 PERSONNEL EXPOSURES DESCRIPTION (39) NUMBER TYPE 0 0 0 (37) Z (38) N/A 80 PERSONNEL INJURIES DESCRIPTION (41) NUMBER 0 0 (40) N/A 11 12 80 LOSS OF OR DAMAGE TO FACILITY (43) TYPE DESCRIPTION Z (42) 9 N/A 10 8210210144 821006 80 PUBLICITY NRC USE ONLY DESCRIPTION (45 PDR ADOCK 05000272 ISSUED N (44) PDR 0 68 69 80 PHONE: 609/935-6000 Ext 3078 Frahm R. NAME OF PREPARER.