

October 13, 1982

DISTRIBUTION

Docket File

DMB016

NRC PDR
L PDR
ORB#4 Rdg
DEisenhut
OELD
AEOD
EJordan
JTaylor
ACRS-10
RIngram
A De Agazio
Gray File
EBlackwood
HOrnstein

Docket No. 50-346

Mr. Richard P. Crouse
Vice President, Nuclear
Toledo Edison Company
Edison Plaza
300 Madison Avenue
Toledo, Ohio 43652

Dear Mr. Crouse:

SUBJECT: TECHNICAL SPECIFICATION FOR SNUBBER SURVEILLANCE

Our letter dated November 20, 1980 requested that you submit a license amendment application to incorporate the applicable portions of the model Technical Specification which was enclosed with that letter. This model Technical Specification included changes, clarifications, and improvements from the previous version and included surveillance requirements for mechanical snubbers. Your response, dated June 29, 1981 (No. 725), stated that no license amendment application was required since Toledo Edison Company will incorporate ANSI/ASME OM-4 standard, when issued, as an integral part of the Davis-Besse inspection program.

We find this response unacceptable. ANSI/ASME OM-4 is currently under development and its issue date is uncertain. Further, its acceptability to the NRC cannot be determined at this time. Please submit the requested license amendment no later than November 19, 1982.

Sincerely,

"ORIGINAL SIGNED BY

JOHN F. STOLZ"

John F. Stolz, Chief
Operating Reactors Branch #4
Division of Licensing

cc: See next page

8210210225 821013
PDR ADOCK 05000346
P PDR

| | | | | | | |
|---------|----------------|------------|--|--|--|--|
| OFFICE | ORB#4:DL | C-ORB#4:DL | | | | |
| SURNAME | A De Agazio;cf | JStolz | | | | |
| DATE | 10/12/82 | 10/13/82 | | | | |

Toledo Edison Company

cc w/enclosure(s):

Mr. Donald H. Hauser, Esq.
The Cleveland Electric
Illuminating Company
P. O. Box 5000
Cleveland, Ohio 44101

U.S. Nuclear Regulatory Commission
Resident Inspector's Office
5503 N. Stat. Route 2
Oak Harbor, Ohio 43449

Gerald Charnoff, Esq.
Shaw, Pittman, Potts
and Trowbridge
1800 M Street, N.W.
Washington, D. C. 20036

Paul M. Smart, Esq.
Fuller & Henry
300 Madison Avenue
P. O. Box 2088
Toledo, Ohio 43603

Regional Radiation Representative
EPA Region V
230 South Dearborn Street
Chicago, Illinois 60604

Mr. Robert B. Borsum
Babcock & Wilcox
Nuclear Power Generation Division
7910 Woodmont Avenue, Suite 220
Bethesda, Maryland 20814

Ohio Department of Health
ATTN: Radiological Health
Program Director
P. O. Box 118
Columbus, Ohio 43216

President, Board of County
Commissioners of Ottawa County
Port Clinton, Ohio 43452

Attorney General
Department of Attorney General
30 East Broad Street
Columbus, Ohio 43215

Harold Kahn, Staff Scientist
Power Siting Commission
361 East Broad Street
Columbus, Ohio 43216

Mr. James G. Keppler, Regional Administrator
U. S. Nuclear Regulatory Commission, Region III
799 Roosevelt Road
Glen Ellyn, Illinois 60137

Mr. Ted Myers
Manager, Nuclear Licensing
Toledo Edison Company
Edison Plaza
300 Madison Avenue
Toledo, Ohio 43652



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

October 13, 1982

Docket No. 50-346

Mr. Richard P. Crouse
Vice President, Nuclear
Toledo Edison Company
Edison Plaza
300 Madison Avenue
Toledo, Ohio 43652


Dear Mr. Crouse:

SUBJECT: TECHNICAL SPECIFICATION FOR SNUBBER SURVEILLANCE

Our letter dated November 20, 1980 requested that you submit a license amendment application to incorporate the applicable portions of the model Technical Specification which was enclosed with that letter. This model Technical Specification included changes, clarifications, and improvements from the previous version and included surveillance requirements for mechanical snubbers. Your response, dated June 29, 1981 (No. 725), stated that no license amendment application was required since Toledo Edison Company will incorporate ANSI/ASME OM-4 standard, when issued, as an integral part of the Davis-Besse inspection program.

We find this response unacceptable. ANSI/ASME OM-4 is currently under development and its issue date is uncertain. Further, its acceptability to the NRC cannot be determined at this time. Please submit the requested license amendment no later than November 19, 1982.

Sincerely,


John F. Stolz, Chief
Operating Reactors Branch #4
Division of Licensing

cc: See next page