

Robert C. Hagan Vice President Nuclear Assurance

April 19, 1994

NA 94-0050

U. S. Nuclear Regulatory Commission ATTN: Document Control Desk Mail Station P1-137 Washington, D. C. 20555

Subject: Docket No. 50-482: Revision to Technical Specification Table 3.6-1

Gentlemen:

This letter transmits an application for amendment to Facility Operating License No. NPF-42 for Wolf Creek Generating Station (WCGS). This license amendment request proposes revising Technical Specification Table 3.6-1, "Containment Isolation Valves," to delete two valves from the table. A design modification is being implemented to remove the Containment Air Cooler Essential Service Water return line isolation valve bypass valves and associated piping.

Attachment I provides a safety evaluation including a description of the proposed change. Attachment II provides a no significant hazards consideration determination and Attachment III provides an environmental impact determination. The specific change to the technical specification proposed by this request is provided in Attachment IV.

In accordance with 10 CFR 50.91, a copy of this application, with attachments, is being provided to the designated Kansas State Official. This proposed revision to the WCGS to "cal specifications will be fully implemented prior to startup from the seventh refueling outage, following formal Nuclear Regulatory Commission approval.

256058

A001 1

If you have any questions concerning this matter, please contact me at (316) 364-8831, extension 4553, or Mr. Kevin J. Moles, at extension 4565.

Very truly yours,

Robert C. Hagan

RCH/jra

Attachments I - Safety Evaluation

II - No Significant Hazards Consideration Determination

III - Environmental Impact Determination

IV - Proposed Technical Specification Change

cc: G. W. Allen (KDHE), w/a

L. J. Callan (NRC), w/a

G. A. Pick (NRC), w/a

W. D. Reckley (NRC), w/a

L. A. Yandell (NRC), w/a