

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | P | A | S | E | S | | 1 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | | | 5
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33
LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT

CON'T

0 1 | R | P | O | T | | L | 6 | 0 | 5 | 0 | 0 | 0 | 3 | 8 | 7 | 7 | 0 | 9 | 2 | 0 | 8 | 2 | 8 | 1 | 0 | 1 | 1 | 8 | 2 | 9
7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33
REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | While in Operational Condition 2 at approximately 2% power, during power
0 3 | ascent testing, the Turbine Bldg. Vent Monitor Sys. Noble Gas Monitor
0 4 | became inoperable. When the monitor became inoperable, the Mechanical
0 5 | Vacuum Pump (MVP) was left in service in variance to the applicable ACTION
0 6 | statement. This event is reportable per 6.9.1.8.b.

0 7 | _____
0 8 | _____

0 9 H A A P U M P X X B Z	11	12	13	14	15	16
SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE	
LER/RO REPORT NUMBER	EVENT YEAR	SEQUENTIAL REPORT NO.	OCCURRENCE CODE	REPORT TYPE	REVISION NO.	
X	8 2	0 1 6	0 1	T	1	
ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.
X	H	Z	Z	0 0 0 0	Y	M
					PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
					A	N O 1 0

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | The MVP was inadvertently left in service due to the operators not noting
1 1 | all parts of the action statements pertaining to the L.C.O. Upon discovery,
1 2 | The MVP was stopped and the Steam Jet Air Ejectors were placed in service.
1 3 | Operators were instructed to list all applicable action statements in the
1 4 | L.C.O. log, to prevent recurrence of a similar event.

1 5 | B | 0 | 0 | 2 | NA | A | operator observation
FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION

1 6 | Z | Z | NA | NA
ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE

1 7 | 0 | 0 | 0 | Z | NA
PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION

1 8 | 0 | 0 | 0 | NA
PERSONNEL INJURIES NUMBER DESCRIPTION

1 9 | Z | NA
LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION

2 0 | N | NA
PUBLICITY ISSUED DESCRIPTION

8210210436 E-011
PDR ADOCK 05000387
S PDR

NRC USE ONLY

LER 82-016/01T-0

Attachment

The Turbine Building Ventilation Monitoring System Noble Gas Monitor was determined inoperable on 9-18-82. The applicable action statement was entered and appropriate samples were taken. However, the Mechanical Vacuum Pump was not taken out of operation. This was in violation of the action statement in effect and was therefore reportable per 6.9.1.8.b. The MVP was placed in operation at 1650 on 9-17-82. Upon realization of the error on 9/20/82, actions were initiated to remove the MVP from service and the Steam Jet Air Ejectors were placed in service.

The MVP was inadvertently left in operation because the on shift operators did not make note of the sentence in the action statement prohibiting operation of the MVP. To prevent recurrence of an event of this nature, the shift personnel have been instructed to read all portions of the action statements and assure that L.C.O. log book is properly and accurately updated to reflect plant conditions. Further, the L.C.O. log will be reviewed shiftly to keep abreast of limiting conditions.