

APPENDIX A

NOTICE OF VIOLATION

Public Service Electric and Gas Company  
Sale Units 1 and 2

Docket/License: 50-272/DPR-70  
Docket/License: 50-311/DPR-75

During inspection on September 1-27, 1982, the following violations were identified and categorized under the NRC Enforcement Policy, 10 CFR 2 Appendix C (47FR9987, March 9, 1982).

- A.1 Technical Specification 6.9.1.9.b requires the submittal of a written report within 30 days of operation in a degraded mode permitted by a limiting condition for operation. Technical Specification 3.3.3.5 permits operation for up to seven days with a steam generator level channel at the hot shutdown panel out of service.

Contrary to the above no report was submitted by September 22, 1982 for a failure of Steam Generator 23 Wide Range Level instrumentation at the hot shutdown panel which was discovered on July 27, 1982 and repaired on July 28, 1982.

This is a Severity Level V Violation, (Supplement 1), applicable to DPR-75.

- A.2 Technical Specification 3.0.4 and 3.3.1.1 prohibit closing the reactor trip breakers unless both source range nuclear instrument channels are operable.

Contrary to the above, on August 9, 1982, with source range channel N31 inoperable in Mode III, the trip breakers were shut for testing. No rods were withdrawn.

This is a Severity Level IV Violation, (Supplement 1), applicable to DPR-70.

Pursuant to the provisions of 10 CFR 2.201, Public Service Electric and Gas Company is hereby required to submit to this office within thirty days of the date of the letter that transmits this Notice, a written statement or explanation in reply, including: (1) the corrective steps which have been taken and the results achieved; (2) corrective steps which will be taken to avoid further violations; and (3) the date when full compliance will be achieved. Where good cause is shown, consideration will be given to extending your response time.

8210210469 821006  
PDR ADOCK 05000272  
G PDR