



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

April 19, 1994

Docket No. 52-003

APPLICANT: Westinghouse Electric Corporation
FACILITY: AP600
SUBJECT: SUMMARY OF MEETING TO DISCUSS THE EVALUATION OF CONTAINMENT PERFORMANCE

On March 28 and 29, 1994, representatives of the U.S. Nuclear Regulatory Commission (NRC) and its contractors, and Westinghouse Electric Corporation (Westinghouse) and its contractors, met in the Westinghouse office in Monroeville, Pennsylvania, to discuss the evaluation of containment performance for the AP600, and to obtain information needed for an NRC confirmatory analysis. Enclosure 1 is a list of attendees.

Westinghouse began the meeting with a presentation on the operation of, and design basis for, the passive containment cooling system. Next, Westinghouse presented preliminary information pertaining to the containment severe accident function. Westinghouse ended the meeting on March 28 with a presentation on the containment design specification and the containment structural design and analysis.

On March 29, Westinghouse completed its presentation on the containment structural design and analysis, and discussed the analyses of capacity for severe accidents and the seismic margin. At this time, the attendees discussed the information that would be required for the staff's contractors to perform a confirmatory analyses of containment buckling and severe accident responses. During the meeting, some proprietary information was presented and discussed. Enclosure 2 contains the nonproprietary version of the information presented by Westinghouse.

The following actions will be taken as a result of the meeting:

1. Westinghouse will review the proprietary classification of the drawings of the containment vessel and provide the results of their review to the staff.
2. Westinghouse will provide additional details on the containment design transients, associated with the passive containment function, in Appendix D to the SSAR.

9404260394 940419
PDR ADOCK 05200003
A PDR

220010

NRC FILE CENTER COPY

DF03/11

April 19, 1994

- 4. For the buckling evaluation of the containment shell, Westinghouse should consider the residual stress effect on the tangent modules.

Original Signed

Kristine M. Shembarger, Project Manager
 Standardization Project Directorate
 Associate Directorate for Advanced Reactors
 and License Renewal, NRR

Enclosures:
 As stated

cc w/enclosures:
 See next page

DISTRIBUTION w/enclosures:

Docket File	PDST R/F	DCrutchfield	KShembarger
PDR	PShea	RBorchardt	RArchitzel
FHasselberg	TKenyon	EJordan, 3701	JMoore, 15B18
WDean, EDO	ACRS(11)(w/o enc)	GBagchi, 7H15	DTerao, 7H15
TCheng, 7H15			

OFF: LA:PDST:ADAR	PM:PDST:ADAR	PM:PDST:ADAR	SC:PDST:ADAR
NAME: PShea <i>PS</i>	KShembarger:tz	TKenyon	RArchitzel
DATE: 04/16/94	04/16/94 <i>KMS</i>	04/14/94	04/19/94

OFFICIAL RECORD COPY: W0328CON.KMS

Westinghouse Electric Corporation

Docket No. 52-003

cc: Mr. Nicholas J. Liparulo
Nuclear Safety and Regulatory Analysis
Nuclear and Advanced Technology Division
Westinghouse Electric Corporation
P.O. Box 355
Pittsburgh, Pennsylvania 15230

Mr. Victor G. Snell, Director
Safety and Licensing
AECL Technologies
9210 Corporate Boulevard
Suite 410
Rockville, Maryland 20850

Mr. B. A. McIntyre
Advanced Plant Safety & Licensing
Westinghouse Electric Corporation
Energy Systems Business Unit
Box 355
Pittsburgh, Pennsylvania 15230

Mr. Raymond N. Ng, Manager
Technical Division
Nuclear Management and
Resources Council
1776 Eye Street, N.W.
Suite 300
Washington, D.C. 20006-3706

Mr. John C. Butler
Advanced Plant Safety & Licensing
Westinghouse Electric Corporation
Energy Systems Business Unit
Box 355
Pittsburgh, Pennsylvania 15230

Mr. M. D. Beaumont
Nuclear and Advanced Technology Division
Westinghouse Electric Corporation
One Montrose Metro
11921 Rockville Pike
Suite 350
Rockville, Maryland 20852

Mr. Sterling Franks
U.S. Department of Energy
NE-42
Washington, D.C. 20585

Mr. S. M. Modro
EG&G Idaho Inc.
Post Office Box 1625
Idaho Falls, Idaho 83415

Mr. Steve Goldberg
Budget Examiner
725 17th Street, N.W.
Room 8002
Washington, D.C. 20503

Mr. Frank A. Ross
U.S. Department of Energy, NE-42
Office of LWR Safety and Technology
19901 Germantown Road
Germantown, Maryland 20874

WESTINGHOUSE AP600
CONTAINMENT PERFORMANCE MEETING
MEETING ATTENDEES
MARCH 28 and 29, 1994

<u>Name</u>	<u>Organization</u>
R. Orr	Westinghouse
D. McDermott	Westinghouse
J. Wills	Westinghouse
D. Lingren	Westinghouse
J. Scobe?	Westinghouse
T. Ahl	CBI (Westinghouse consultant)
K. Shembarger	NRC/NRR
T. Cheng	NRC/NRR
D. Smith	NRC/NRR
G. Bagchi	NRC/NRR
D. Terao	NRC/NRR
F. Fanous	Ames (NRC consultant)
L. Greimann	Ames (NRC consultant)



AP600 Containment Meeting

Meeting with the NRC

March 28 and 29, 1994



AP600 Containment Meeting
March 28 and 29, 1994
Agenda

Introduction	R. Orr
Purpose of meeting	
Transmittal of design information to NRC consultants	
SSAR and RAI status for Section 3.8.2	
Containment Design Basis Function	D. McDermott
Containment Severe Accident Function	J. Scobel
Containment Design Specification	R. Orr
Containment Structural Design and analysis	T. Ahl
Analyses of capacity for severe accidents	T. Ahl
Seismic Margin	R. Orr
Information for independent analyses	

WESTINGHOUSE AP600 CONTAINMENT VESSEL

CONTAINMENT DESIGN AND ANALYSIS PERFORMED BY CBI

- CBI CONTAINMENT CONFIGURATION SKETCHES
- MATERIAL PROPERTIES
- CONTAINMENT SHELL - FREE FIELD AND GROSS
STRUCTURAL DISCONTINUITIES ANALYSIS
- LOCAL EFFECTS ANALYSIS AT MAJOR
PENETRATIONS AND ATTACHMENTS

CONTAINMENT SHELL - FREE FIELD AND GROSS
STRUCTURAL DISCONTINUITIES ANALYSIS

- DESIGN CASE - 45 PSIG at 280 DEGREES F.
- SERVICE LEVEL C CASE at 320 DEGREES F.
- SEVERE ACCIDENT CAPACITY ASSESSMENT at 70 DEGREES F
- STRESS EVALUATION DUE TO REPRESENTATIVE THERMAL GRADIENTS
- BUCKLING ANALYSIS AT SEVERE ACCIDENT PRESSURE
- SEISMIC MODELING

3. DESIGN OF STRUCTURES, COMPONENTS, EQUIPMENT AND SYSTEMS

Revision: 1

Effective: 01/13/94




Table 3.8.2-1

Load Combinations and Service Limits For Containment Vessel

Load Description		Load combination and service limit										
		Test	Design	A	A	C	C	C	D	A	C	
Dead	D	X	X	X	X	X	X	X	X	X	X	X
Live	L	X	X	X	X	X	X	X	X	X	X	X
Wind	W			X								
SSE	E _s					X	X		X			
Tornado	W _t							X				
Test pressure	P _t	X										
Test temperature	T _t	X										
Operating pressure	P _o			X								
Normal reaction	R _o			X			X	X		X	X	
Normal thermal	T _o			X			X	X		X	X	
Design pressure	P _d		X		X	X			X			
External pressure (2.5 psid)	P _e									X		
External pressure (3.0 psid)	T _o											X
Accident thermal	T _a		X		X	X			X			
Accident thermal reactions	R _a		X		X	X			X			
Accident pipe reactions	Y _r								X			
Jet impingement	Y _j								X			
Pipe impact	Y _m								X			

Notes:

1. Service limit levels are per ASME-NB.

2. Where any load reduces the effects of other loads, that load shall be taken as zero, unless it can be demonstrated that the load is always present or occurs simultaneously with the other loads.

STRESS-STRAIN CURVE (UNIAXIAL)

Assume elastic-perfectly plastic material properties.
Ignoring strain-hardening is conservative.

$$\text{Yield strain, } \epsilon_Y = \frac{\sigma_Y}{E} = \frac{60000}{29.5 \times 10^6} = 2.0339 \times 10^{-3} \text{ in/in.}$$




FIG. 3-2: STRESS-STRAIN CURVE FOR ANALYSIS

NOTE:

Effective stress at data point 3 has been modified by 'BOSORS' program internally in order to obtain a minimum tangent modulus of $0.001E = 29500$ psi. (σ_{eff} at data point 3 used in 'BOSORS' is $60382 = 60000 + 29500[0.015 - 0.0020339]$.) This is normally done to improve the rate of convergence. This 'negligible' strain hardening will not have any significant effect on the results.

SUBJECT BUCKLING CAPACITY EVALUATION TASK #3, CBI PHASE 3 STUDY AP600, WESTINGHOUSE	OFFICE NOE-A		REVISION		REFERENCE NO 902657
	MADE BY RSR	VERIFIED BY TJA	MADE BY	VERIFIED BY	3-5 SHT ___ OF ___
	DATE 12/17/91	DATE 2/18/92	DATE	DATE	

AP600 CONTAINMENT VESSEL




FIGURE 2 CONTAINMENT VESSEL RESPONSE TO INTERNAL DESIGN PRESSURE OF 45 PSIG - MEMBRANE STRESSES (SPHI = MERIDIONAL, STHT = CIRCUMFERENTIAL)

SUBJECT TASK #1992-2, AP600, WESTINGHOUSE	OFFICE NOE-A		REVISION	REFERENCE NO 902657
	MADE BY RGR	VERIFIED BY TJA	MADE BY	VERIFIED BY 2B-15
	DATE 5/15/92	DATE 5/20/92	DATE	DATE
	SHT ___ OF ___			




FIGURE 20
 MEMBRANE PRINC. STRESS DIF. ALONG MERIDIAN -- \square : S1-S2, Δ : S1-S3, X: S2-S3
 902657 AP600 WESTINGHOUSE. PR: INTERNAL PRESSURE OF 45 PSI 9/19/91
 MAXIMA 21718. 18644. 22723. PSI

SUBJECT ASME LEVEL C PRESSURE TASK # 1, CBI PHASE 3 STUDY AP600, WESTINGHOUSE	OFFICE GHI NOE-A		REVISION		REFERENCE NO 902657
	MADE BY RSD	VERIFIED BY TJA	MADE BY	VERIFIED BY	1-36 SHT OF
	DATE 9/30/91	DATE 10/15/91	DATE	DATE	

BUCKLING STRESS EVALUATION

AT THE BOTTOM T. L. (EL. 104'-1 1/2)

THE LOAD COMBINATION, 'D + L - SSE' RESULTS INTO MERIDIONAL COMPRESSION AND TANGENTIAL SHEAR. (SET 1: $\sigma_{\phi} = -2.7$ KSI AND $\tau_{\phi\theta} = 0.4$ KSI; SET 2: $\sigma_{\phi} = -1.7$ KSI AND $\tau_{\phi\theta} = 1.1$ KSI)

BUCKLING EVALUATION IS PERFORMED USING ASME III CODE CASE N-284 (PROPOSED REVISION). ALLOWABLES: $\sigma_{\phi a} = -5.5$ KSI AND $\tau_{\phi\theta a} = 6.0$ KSI.

MAXIMUM VALUE OF THE INTERACTION EQUATION FOR COMBINED 'AXIAL COMPRESSION + SHEAR' IS 0.5 (SET 1 CONTROLS), THE ALLOWABLE VALUE IS 1.0.

IN THE KNUCKLE

THE LOAD COMBINATION, ' $P_d + T_a$ ' = ' P_d ' RESULTS INTO MERIDIONAL TENSION AND CIRCUMFERENTIAL COMPRESSION. (DUE TO P_d^a : $\sigma_{\phi} = 11.0$ KSI AND $\sigma_{\theta} = -10.5$ KSI; DUE TO T_a^b : $\sigma_{\phi} = 0.0$ AND $\sigma_{\theta} = -0.1$ KSI, NOTE THAT STRESSES DUE TO T_a ARE VERY SMALL)

BUCKLING EVALUATION IS PERFORMED BY BOSOR5 ANALYSIS USING INTERNAL PRESSURE ONLY AND A FACOR OF SAFETY FROM ASME III CODE CASE N-284.

THEORETICAL BUCKLING INTERNAL PRESSURE IS 174 PSIG. USING A FACTOR OF SAFTY OF 2.0, THE ALLOWABLE DESIGN PRESSURE IS 87 PSIG. ACTUAL DESIGN PRESSURE IS 45 PSIG.

^aDESIGN PRESSURE OF 45 PSIG (INTERNAL).

^bACCIDENT THERMAL (SHELL BELOW EL. 132'-3, 70°F AND SHELL ABOVE EL. 132'-3 AND STIFFENERS, -40°F, AND CRANE GIRDER AT 50°F).

SUBJECT STRESS EVALUATION AT THE MAJOR STRUCTURAL DISCONTINUITIES FOR THE DESIGN LOADS AP600, WESTINGHOUSE	OFFICE NO. A		REVISION		REFERENCE NO. 902657
	MADE BY	VERIFIED BY	MADE BY	VERIFIED BY	SHT ____ OF ____
	DATE	DATE	DATE	DATE	

**STRESS COMPONENTS AND STRESS INTENSITY EVALUATION AT THE BASE
(EL. 100'-0)**

P_d DESIGN PRESSURE OF 45 PSIG (INTERNAL)
 T_a ACCIDENT THERMAL (SHELL BELOW EL. 100'-0, 70°F AND SHELL ABOVE EL. 100'-0, 280°F)

NOTE: STRESSES DUE TO D, L, AND SSE ARE NOT REPORTED HERE AS THEY ARE NOT EXPECTED TO BE CRITICAL FOR BUCKLING IN COMPARISON WITH THE STRESSES DUE TO T_a .

LOAD	LOCATION	TYPE	σ_ϕ	σ_θ	$\tau_{\phi\theta}$		
P_d	$\theta = 0^\circ$ AND 90°	I	-6.2	-1.9	0		
		M	10.8	3.3	0		
		O	27.9	8.4	0		
T_a	$\theta = 0^\circ$ AND 90°	I	67.2	-16.8	0		
		M	0.3	-36.9	0		
		O	-66.7	-57.0	0	σ_1	σ_2
P_d	$\theta = 0^\circ$ AND 90°	M	10.8	3.3	0	10.8	33a
		I/O	27.9	8.4	0	27.9	80b
$P_d + T_a$	$\theta = 0^\circ$ AND 90°	M	11.1	-33.6	0	44.7	80b,c
		I/O	61.0	-18.7	0	79.7	80b

- a 1.5 TIMES S_{mc} FOR 'PL' OR 'PL + Pb'.
- b 3.0 TIMES S_{m1} FOR 'PL + Pb + Q'.
- c BUCKLING EVALUATION IS NOT YET COMPLETE.

SUBJECT STRESS EVALUATION AT THE MAJOR STRUCTURAL DISCONTINUITIES FOR THE DESIGN LOADS AP600, WESTINGHOUSE	OFFICE NOE-A		REVISION		REFERENCE NO 902657
	MADE BY	VERIFIED BY	MADE BY	VERIFIED BY	SHT ____ OF ____
	DATE	DATE	DATE	DATE	



Table 3.8.2-2

Containment Vessel Pressure Capabilities

Containment Element	Pressure Capability at Ambient Temperature	
	Deterministic Severe Accident Capacity ⁽¹⁾	Minimum Specified Yield ⁽²⁾
Cylinder	125 psig ①	144 psig ②
Ellipsoidal Head	104 psig ③	146 psig ④ 174
22 foot equipment hatch	117 psig ⑤	196 psig ⑥
16 foot equipment hatch	96 psig ⑦	161 psig ⑧
Personnel airlocks ⁽³⁾	>163 psig ⑨ Test W	>300 psig ⑩ Test S

for buckling
F.S. = 1.0

F.S. =

- (1) The buckling capacity of the ellipsoidal head is taken as sixty percent of the critical buckling pressure calculated by the BOSOR-5 non-linear analyses. Evaluations of the other elements are according to ASME Service Level C and include use of Code Case N284.
- (2) The estimated maximum pressure capability is based on minimum specified material properties.
- (3) The capacities of the personnel airlock are estimated from test results.

① Based on tensile stress $P = \frac{St}{R} = \frac{60000 \times 1.625}{740} = 125 \text{ psi}$

② Based on von Mises - tensile stress $P = \frac{St}{R} \frac{2}{\sqrt{3}} = 144 \text{ psi}$

③ Based on buckling $P = \frac{173}{1.67} = 104 \text{ psi}$ 1.67 = $\frac{2}{1.2}$

④ Based on tensile stress at crown (von Mises) $P = \frac{2St}{R} = \frac{60000 \times 1.625}{1847} = 146 \text{ Based}$
145 longhand


⑤ N-284 F.S. = 1.67

⑥ N-284 F.S. = 1.00


⑦ N-284 F.S. = 1.67

⑧ N-284 F.S. = 1.0

⑨ Based on $\frac{St}{Fy} = \frac{70000}{38000} = 1.84 \frac{100}{1.84} = 163$



BOSOR-5 Model of Containment Vessel Head






FIG. 3-5: INTERNAL PRESSURE - MAXIMUM DISPLACEMENT CURVE

902657; BUCKLING OF TOP HEAD 12/17/91
 DEFORMED STRUCTURE
 LOAD STEP 42. LOAD = 1.738E+02 PRESTRESS
 PSIG




FIG. 3-6: PREBUCKLING DISPLACEMENTS AT $P_{crmin} = 173.8$ PSIG (BOSORS)

SUBJECT BUCKLING CAPACITY EVALUATION TASK #3, CBI PHASE 3 STUDY AP600, WESTINGHOUSE	OFFICE NOE-6		REVISION		REFERENCE NO. 902657
	MADE BY RSR	VERIFIED BY DA	MADE BY	VERIFIED BY	3-12 SHT OF
	DATE 12/17/91	DATE 2/18/96	DATE	DATE	

**STRESS COMPONENTS AND STRESS INTENSITY EVALUATION AT THE TOP T. L.
(EL. 218'-8 1/2)**

P_d DESIGN PRESSURE OF 45 PSIG (INTERNAL)
 T_a ACCIDENT THERMAL (SHELL BELOW EL. 132'-3, 70°F AND SHELL ABOVE EL. 132'-3 AND STIFFENERS, -40°F, AND CRANE GIRDER AT 50°F)



ASSUMPTION: STRESSES DUE TO D, L, AND SSE ARE SMALL.

LOAD	LOCATION	TYPE	σ_ϕ	σ_θ	$\tau_{\phi\theta}$		
P_d	$\theta = 0^\circ \text{ AND } 90^\circ$	I	11.2	5.8	0		
		M	10.8	5.6	0		
		O	10.4	5.5	0		
T_a	$\theta = 0^\circ \text{ AND } 90^\circ$	I	-0.1	-0.2	0		
		M	0.0	-0.1	0		
		O	0.1	-0.1	0	σ_I	σ_B
P_d	$\theta = 0^\circ \text{ AND } 90^\circ$	M	10.8	5.6	0	10.8	33a
		I/O	11.2	5.8	0	11.2	80b
$P_d + T_a$	$\theta = 0^\circ \text{ AND } 90^\circ$	M	10.8	5.5	0	10.8	80b
		I/O	11.1	5.6	0	11.1	80b

a1.5 TIMES S_{mc} FOR 'PL' OR 'PL + Pb'.

b3.0 TIMES S_{m1} FOR 'PL + Pb + Q'.

SUBJECT STRESS EVALUATION AT THE MAJOR STRUCTURAL DISCONTINUITIES FOR THE DESIGN LOADS AP600, WESTINGHOUSE	OFFICE NOE-A		REVISION		REFERENCE NO. 902657
	MADE BY	VERIFIED BY	MADE BY	VERIFIED BY	SHT ____ OF ____
	DATE	DATE	DATE	DATE	



16'-0 I.D. EQUIPMENT MATCH



LOCAL EFFECTS AT MAJOR PENETRATIONS AND ATTACHMENTS

- CRANE GIRDER
- PERSONNEL AIRLOCK
- EQUIPMENT HATCHES
- MAIN STEAM AND FEEDWATER PENETRATIONS
- ROOF CONSTRUCTION SUPPORTS

SEISMIC MODELING

SEVERE ACCIDENT CASE - DETERMINE CAPACITY

- LONGHAND CALCULATIONS BASED ON TENSILE STRESSES REACHING YIELD
- BUCKLING CONSIDERATIONS



AP600

PASSIVE CONTAINMENT COOLING SYSTEM

JANUARY 20, 1994
DAN MCDERMOTT



AP600

PASSIVE CONTAINMENT COOLING SYSTEM DESIGN BASIS

- Limit peak containment pressure to less than 45 psig design pressure for design basis events (large LOCA, steamline break)
- Reduce containment pressure to 1/2 peak pressure within 24 hours
- Cooling water supplied for 3 days with no operator action or outside assistance, provisions for simple actions to replenish water supply within 3 days
- As a goal, limit containment pressure to <45 psig for an indefinite time, even if no action is taken to replenish water supply



AP600


PASSIVE CONTAINMENT COOLING SYSTEM DESIGN BASIS

- Automatically actuated
- Once actuated, operation shall not be dependent on electrical power, continuous operation of mechanical components
- Meets single failure criteria for design basis events
- System reliability consistent with plant CMF and SRF criteria



AP600

PCS - SIMPLIFIED SKETCH





AP600


PASSIVE CONTAINMENT COOLING SYSTEM SYSTEM FEATURES

- Containment wetting for evaporative cooling
 - Water storage tank
 - Integrated into the Shield Building
 - 400,000 gallons useable volume
 - Gravity Drain
 - Parallel Fail Open Isolation Valves
 - Leakage Detection
 - Water distribution bucket (30" Diameter)
 - Water distribution features
 - Two Acceptable Configurations
 - Distribution Arms
 - Weir Water Distributers (Coverage 90% to 35%)
 - Annulus Drains
 - Long Term makeup water (Beyond 72 hours)



AP600

PASSIVE CONTAINMENT COOLING SYSTEM






AP600

PASSIVE CONTAINMENT COOLING SYSTEM WATER DISTRIBUTION

Containment dome plan view





AP600


CONTAINMENT COOLING SCENARIOS

- Loss of Coolant Accident
- Steam Line Break
- Passive Residual Heat Removal Transients
- Negative Pressure Transients



AP600

CONTAINMENT COOLING SCENARIOS LOSS OF COOLANT ACCIDENT



AP600

CONTAINMENT COOLING SCENARIOS LOSS OF COOLANT ACCIDENT - TEMPERATURE PROFILES

Containment Shell Temperature Profiles for Cold Leg Break


Time	Dome		Spring Line		Operating Deck ¹		
	Wet	Dry	Wet	Dry	Wet	Dry	
0.	I] b
	O						
100.	I						
	O						
700.	I						
	O						
1300.	I						
	O						
1900.	I						
	O						
3100.	I						
	O						
7600.	I						
	O						
19600.	I						
	O						
31500.	I						
	O						
86400.	I						
	O						

Notes: 1 w/phenolic coating inside
I - Inside shell
O - Outside shell



AP600

CONTAINMENT COOLING SCENARIOS STEAM LINE BREAK






AP600

CONTAINMENT COOLING SCENARIOS PASSIVE RESIDUAL HEAT REMOVAL TRANSIENTS

PASSIVE RHR OPERATION
Pressure Transient versus Time





AP600

CONTAINMENT COOLING SCENARIOS NEGATIVE PRESSURE TRANSIENTS

- Events Considered
 - PCS actuation
 - IRWST Pumpout
 - Failed Fan Cooler Control
 - Purge System Maloperation
 - Loss of all AC @ Limiting Environmental Conditions

- Environmental Conditions (-40 F/45 mph wind)
- Results (hand calculations) <3.0 psid @ 30 minutes
- Event Termination

AP600

CONTAINMENT COOLING SCENARIOS CONTAINMENT TESTING PROGRAMS

CONTAINMENT WATER DISTRIBUTION TESTS

OBJECTIVES: CHARACTERIZE WATER DISTRIBUTION FOR
RANGE OF FLOWS
VARIETY OF DISTRIBUTION MECHANISMS
WORST CASE SURFACE DEFECTS
ESTABLISHMENT OF WATER DISTRIBUTION DESIGN

LARGE SCALE CONTAINMENT COOLING SYSTEM TESTS

OBJECTIVES: TO PROVIDE DATA TO VERIFY CONTAINMENT COMPUTER
CODES AND MODELS USED TO ASSESS PCS PERFORMANCE OVER
RANGE OF VESSEL PRESSURES
RANGE OF WATER DISTRIBUTIONS
RANGE OF AIR VELOCITIES

WIND TUNNEL TESTS

OBJECTIVES:
DETERMINE WORST CASE PRESSURE DISTRIBUTION DEVELOPED
ACROSS THE AIR BAFFLE

DEMONSTRATE INTERACTIONS OF WIND AND BUILDINGS WILL NOT
CAUSE A DECREASE IN NATURAL CIRCULATION COOLING

INTEGRAL CONTAINMENT COOLING TEST

OBJECTIVE: CONFIRM THE OPERATION AND HEAT REMOVAL CAPABILITY OF
THE PASSIVE CONTAINMENT COOLING DURING ACCIDENT CONDITIONS