

LICENSEE EVENT REPORT

CONTROL BLOCK: 1 6 (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 CTMNS1 200-000000-00 3411111 4 5
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T
01 REPORT SOURCE L 605000245 7091382 8101382 9
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 On September 13, 1982, at 1241 hours, while performing Diesel Generator Operational
03 Readiness Demonstration test, the Diesel Generator tripped. The Diesel Generator was
04 declared inoperable and an investigation initiated. Technical Specification 3.9.a
05 requires the Diesel Generator and Gas Turbine Generator (both emergency power sources)
06 to be operable. There were no consequences. See attached sheet.
07
08

09 SYSTEM CODE EE (11) CAUSE CODE E (12) CAUSE SUBCODE A (13) COMPONENT CODE RELAIYX (14) COMP. SUBCODE D (15) VALVE SUBCODE Z (16)
7 8 9 10 11 12 13 18 19 20
17 LER/RO REPORT NUMBER 82 (21) (22) SEQUENTIAL REPORT NO. 021 (24) (26) OCCURRENCE CODE 03 (28) (29) REPORT TYPE L (30) REVISION NO. 0 (32)
ACTION TAKEN A (18) FUTURE ACTION Z (19) EFFECT ON PLANT Z (20) SHUTDOWN METHOD Z (21) HOURS 0000 (22) ATTACHMENT SUBMITTED Y (23) NPRD-4 FORM SUB. Y (24) PRIME COMP. SUPPLIER N (25) COMPONENT MANUFACTURER T198 (26)
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 A broken ring type wire lug at the current transformer secondary connection caused the
11 trip. It is conjectured that the lug broke because of flexing during installation and
12 vibration during diesel operation. The connection was relugged with a more substantial
13 terminal lug.
14

15 FACILITY STATUS H (28) % POWER 000 (29) OTHER STATUS NA (30) METHOD OF DISCOVERY B (31) DISCOVERY DESCRIPTION Routine Surveillance (32)
7 8 9 10 12 13 44 45 46 80

16 ACTIVITY CONTENT RELEASED OF RELEASE Z (33) Z (34) AMOUNT OF ACTIVITY NA (35) LOCATION OF RELEASE NA (36)
7 8 9 10 11 44 45 80

17 PERSONNEL EXPOSURES NUMBER 000 (37) TYPE Z (38) DESCRIPTION NA (39)
7 8 9 11 12 13 80

18 PERSONNEL INJURIES NUMBER 000 (40) DESCRIPTION NA (41)
7 8 9 11 12 80

19 LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) DESCRIPTION NA (43)
7 8 9 10 80

20 PUBLICITY ISSUED DESCRIPTION N (44) 8210220108 821013 PDR ADOCK 05000245 S PDR (45) NRC USE ONLY
7 8 9 10 68 69 80 91

NAME OF PREPARER Trudy Schweikert Thull PHONE (203) 447-1791