



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

October 7, 1982

JAMES P. McGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
ADS Valve Air Booster
Compressors Not Operating
Reference: LER 82-072/01 T-0
AECM-82/465

During Non-Nuclear Heatup, it was discovered that the ADS Valve Air Booster Compressors were not operating. This resulted in air pressure in the ADS Valve Air receivers having low pressure. Since the plant was in operational mode 3, loss of ADS caused entrance into the LCO per T.S.3.5.1.b.2. Attached is LER-82-072/01 T-0 with supplementary information.

Yours truly,

JPM:sap
Attachment

cc: Mr. N. L. Stampley (w/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

OFFICIAL COPY

8210220196 821007
PDR ADDCK 05000416
S PDR

Member Middle South Utilities System

02 OCT 12 AID: 0
USNRC REGION II
ATLANTA, GEORGIA

IC 22