

ORIGINAL

ACRST 1825

OFFICIAL TRANSCRIPT OF PROCEEDINGS

Agency: Nuclear Regulatory Commission
Advisory Committee on Reactor Safeguards

Title: 368th ACRS General Meeting

Docket No.

LOCATION: Bethesda, Maryland

DATE: Friday, December 7, 1990 PAGES: 288 - 504

ACRS Office Copy - Retain
for the Life of the Committee

ANN RILEY & ASSOCIATES, LTD.

1612 K St. N.W., Suite 300
Washington, D.C. 20006
(202) 293-3950

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

PUBLIC NOTICE BY THE
UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

DATE: December 7, 1990

The contents of this transcript of the proceedings of the United States Nuclear Regulatory Commission's Advisory Committee on Reactor Safeguards, (date) December 7, 1990, as reported herein, are a record of the discussions recorded at the meeting held on the above date.

This transcript has not been reviewed, corrected or edited, and it may contain inaccuracies.

***** TRANSCRIPT DELIVERY RECEIPT *****
U.S. NUCLEAR REGULATORY COMMISSION

Deliver To:

Pat Wilder, ASLBP
4350 East-West Tower
4th Floor
Phone: 492-4898 (Pat)
or 492-5042 (Doris)
or 492-7858 (Jack)

Barbara White, ACRS
7920 Norfolk Avenue
Room 432
Phillips Building
Phone: 492-7288

Hearing Date: 12/7/90 Location: Bethesda, Maryland
Presiding Officer: Fraley Docket No.: _____
Title of Hearing: 368th ACRS General Meeting
Work Order No.: NRC-348-402 288 - 504

Service Requested:

Daily: 2-Day: 5-Day: Floppy Disk:

Original Only & 5 Copies

Gross No. Of Pages: 217

Net No. Of Pages: 216

No. Insert Pages: 127

Notes & Tapes: _____

Received By: Barbara G. White
Signature

12/10/90 7:55 a
Date and Time

ANN RILEY & ASSOCIATES, LTD.
1612 K Street NW, Suite 300
Washington, D. C. 20006
Telephone No. (202) 293-3950
Fax No. (202) 659-0085

1 UNITED STATES OF AMERICA
2 NUCLEAR REGULATORY COMMISSION

3 ***

4 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
5 368TH ACRS GENERAL MEETING
6

7 Nuclear Regulatory Commission
8 Room P-110
9 7920 Norfolk Avenue
10 Bethesda, Maryland
11 Friday, December 7, 1990

12 The above-entitled proceedings commenced at 8:30
13 o'clock a.m., pursuant to notice, Carlyle Michelson,
14 Committee Chairman, presiding.

15 PRESENT FOR THE ACRS SUBCOMMITTEE:

16 Charles J. Wylie, Vice Chairman

17 James. C. Carroll, Member

18 Ivan Catton, Member

19 William Kerr, Member

20 Harold W. Lewis, Member

21 Paul G. Shewmon, Member

22 Chester P. Siess, Member

23 David A. Ward, Member

24 J. Ernest Wilkins, Jr., Member

25 P. Boehnert, Cognizant ACRS Staff Member

1 PARTICIPANTS:

2

3

R. Fraley

S. Duraiswamy

4

A. Chaffee

M. Caruso

5

D. Fischer

S. Mirsky

6

G. Belisle

R. Karsch

7

T. Marsh

J. Donahue

8

J. MacDonald

B. Levis

9

S. Long

M. Reinhart

10

C. Rossi

J. Calvo

11

R. Lobel

W. Hall

12

B. Sheron

N. Zuber

13

E. Beckjord

J. Murphy

14

F. Eltawila

B. Wright

15

16

17

18

19

20

21

22

23

24

25

P R O C E E D I N G S

[8:30 a.m.]

1
2
3 MR. MICHELSON: The meeting will now come to
4 order. This is the second day of the 368th meeting of the
5 Advisory Committee on Reactor Safeguards. During today's
6 meeting the Committee will discuss and/or hear reports on
7 the following: nuclear power plant operating experience and
8 events; ACRS Subcommittee activities; new standardized
9 technical specification; and, NRC Safety Research Program.

10 This meeting is being conducted in accordance with
11 the provisions of the Federal Advisory Committee Act. Mr.
12 Paul Boehnert is the designated Federal Official for the
13 initial portion of the meeting. We have received no written
14 statements or requests for time to make oral statements from
15 members of the public regarding today's session. A
16 transcript of portions of the meeting is being kept, and it
17 is requested that each speaker use one of the microphones,
18 identify himself or herself, and speak with sufficient
19 clarity and volume so that he or she can be readily heard.

20 I would like to remind the members at this time
21 that if you have any comments on the draft letter which
22 Charlie Wylie is preparing be sure to give them to him this
23 morning because he's trying to put together a second draft
24 now. If there are any, please do so.

25 At this time, I would like to call on J. Carroll

1 to introduce the topic of nuclear power plant operating
2 experience and events.

3 MR. CARROLL: This morning we are going to hear
4 about four fairly recent reactor operating events. I guess
5 Al Chaffee is going to lead the discussion for the staff.

6 MR. CHAFFEE: There are four events that we wanted
7 to talk to you about today. The first one is the hydrogen
8 gas build up of a charging system at Sequoyah. For that
9 particular event, we have Mark Caruso from the Reactor
10 Systems Branch who will give a little bit of an introduction
11 on this one. Also, later on, we will talk about some of the
12 follow up actions that the staff is taking.

13 Then we have Dave Fischer from the Events
14 Assessment Branch, and he will go through and talk about the
15 actual event itself at Sequoyah, exactly what occurred and
16 what we learned from that. Later we may have -- there has
17 been some analysis done on this particular type of a
18 phenomena, and we plan on having somebody here present to be
19 able to talk about some analysis that has been done there.
20 As soon as he gets here, Steve Mirsky will talk to us about
21 that.

22 The second event that we want to talk about is
23 Brunswick Unit 2 where they had, due to some personnel
24 errors, shutting of their main steam isolation valves. They
25 also had some problems with some of their safety relief

1 valves in that event. Al Belisle, who lead in AIT to look
2 into this Brunswick event from Region II, he will be talking
3 to us about that.

4 The third event that we wanted to talk about was
5 the loss of offsite power event that occurred at Brunswick.
6 For this one, Rudy Karsch from the Events Assessment Branch
7 will take us through a discussion of that. We will see how,
8 in this particular case, the licensee lost offsite power
9 when they manually tripped the reactor after having a lock
10 out of their transformer that caused them to lose their
11 recirc pumps.

12 The fourth event we wanted to talk a little bit
13 about was Pilgrim, where the licensee had some problems with
14 their feedwater system and difficulties trying to use
15 various other line up to feed the reactor vessel. For that
16 particular one, Rudy Karsch from the Events Assessment
17 Branch will take us through a discussion of that event.

18 Roughly speaking, we thought we would spend an
19 hour on the first one, about 20 minutes on the two Brunswick
20 events -- 20 each -- and about one-half hour to 40 minutes
21 on the last event. That is flexible, based on the questions
22 that you have to ask us. At this point, I would like to
23 turn it over to Mark Caruso to lead off on an introduction
24 on the Sequoyah event.

25 MR. CARUSO: The issue of hydrogen gas build up in

1 the charging system in the Sequoyah event is not a new
2 issue. We do want to tell you about the event and will have
3 a description of the event at Sequoyah, but we also want to
4 go somewhat beyond that; in that the event at Sequoyah and
5 the issues raised there are not new. Similar events have
6 occurred like this event at Sequoyah in the past. The staff
7 has been studying the issue of this hydrogen gas build up in
8 the ECCS system. There have been similar events in the
9 past, and the staff has been concerned as to the number of
10 generic communications.

11 MR. KERR: Excuse me. I think if you hold that
12 microphone closer to where the sound is coming from it would
13 be more effective.

14 [Slide.]

15 MR. CARUSO: The primary concern that the staff
16 has with this problem of hydrogen building up in the
17 charging system is the potential that it could damage ECCS
18 pumps. Because of that concern, the staff has been looking
19 at the potential for getting this gas in multiple portions
20 of the ECCS, and also looking at the potential for gas to
21 damage the pump.

22 The staff has done some analysis in this area --

23 MR. KERR: Excuse me. You said that there have
24 been a number of other incidents of this kind before, so the
25 staff must have started looking at it earlier.

1 MR. CARUSO: Yes. The staff has been looking at
2 this since -- I think in some depth since 1988. There was
3 an event that two other PWR's -- two other events very
4 similar to Sequoyah.

5 MR. KERR: But you don't have any solution for it
6 yet, apparently.

7 MR. ROSSI: Let me point out that we have put out
8 an information notice on this issue back in 1988. We put
9 out the first information notice, and I believe that
10 information notice was prompted by an event at the Farley
11 plant. We put that information notice out, and it clearly
12 indicated what the problem was. I think even on the recent
13 one at Sequoyah they had done something in response to the
14 information notice, but it turned out that they hadn't done
15 enough.

16 So, since we put out the original information
17 notice we have put out three supplements. The most recent
18 supplement -- it actually hasn't been mailed out yet. It
19 has been signed and I think it's included in your package --
20 it will be mailed on December 10. The industry is clearly
21 alerted to the problem.

22 MR. KERR: My question is has a solution to the
23 problem not yet been found, or does a solution exist but the
24 industry is just not aware of it?

25 MR. CARUSO: I believe that there are solutions

1 out there that people have used effectively in response to
2 this. I think the concern is that the information has been
3 out there, the technology has been out there to find this
4 problem and fix it, and Sequoyah raises the issue of is it
5 getting done.

6 MR. KERR: Thank you.

7 MR. LEWIS: Could I ask, is the information notice
8 that we are talking about the one that we have in front of
9 us in which Supplement 3 is at issue? December 10, is that
10 the one that we are talking about?

11 MR. ROSSI: Supplement 3, to be issued on December
12 10, yes.

13 MR. LEWIS: Supplement 3, I have been reading and
14 trying to understand what it says. It says evaluate the
15 problem to determine its extent, if any, and implement
16 corrective actions if not already completed, which I find a
17 little bit short in telling me what is going on. I assume
18 the earlier part tells what it's really all about?

19 MR. CARUSO: I think that we agree with that, and
20 that part of what we want to talk about today is the
21 stronger action that we think needs to be taken.

22 MR. LEWIS: I will wait to learn what these words
23 mean, I guess.

24 MR. ROSSI: I am not sure what you are reading
25 from.

1 MR. LEWIS: That's why I was asking if that was
2 it. I am reading from a thing which was passed out which
3 says staff developing generic communication which requests -
4 -

5 MR. ROSSI: No, that is not the information. The
6 information notice is about four or five pages long.

7 MR. LEWIS: That's what I should be looking at

8 MR. ROSSI: The information notice does not
9 require the licensee to do anything. It conveys information
10 to them, and then as part of their normal evaluation of
11 operational experience they would address it.

12 MR. LEWIS: The communication referred to in this
13 is based on that, and it simply tells people to look at that
14 and find out what the problems are and fix them.

15 MR. ROSSI: Yes. It leaves the burden on the
16 licensee to evaluate his own situation and come up with his
17 own solution.

18 MR. LEWIS: Okay, I have no problem with that. I
19 just wasn't getting any information from what I have in
20 front of me.

21 MR. MICHELSON: You should have a copy of the
22 information notice.

23 MR. LEWIS: I have no doubt that I do.

24 MR. CHAFFEE: Also, we will see in the discussion
25 that Dave will take us through in terms of what Sequoyah had

1 happened and what they did, some of the interesting aspects
2 of what it takes to deal with this type of a problem. We
3 will get into some of those details then.

4 MR. MICHELSON: Why don't you proceed.

5 MR. CARUSO: After we go through the Sequoyah
6 event, we will talk some more about the pump performance
7 issue and talk about our analysis. Then, I will come back
8 and talk about the follow up. At this point, I guess Dave
9 Fischer is going to come up and run through the event for
10 us.

11 MR. FISCHER: Good morning. My name is Dave
12 Fischer, and I am the PWR Section Chief with the Events
13 Assessment Branch. I believe you have some viewgraphs in
14 your package. I was not going to put the ones that have the
15 discussion on the screen, but I will put the isometric
16 drawing up and talk from it basically. I think I will cover
17 everything that is written on the slides that you have in
18 your package, but I will check at the end of my kind of
19 informal presentation.

20 [Slide.]

21 Both Sequoyah units were operating toward the end
22 of August, end of September at power. Sequoyah Unit 2 was
23 the one that experienced a problem on August 22nd. They
24 were using the A centrifugal charging pump for normal
25 primary plant makeup. They were about to do a surveillance

1 on the B centrifugal charging pump here, and they started
2 the B pump in parallel with the A pump and didn't have any
3 problem. When they secured the A pump, they noticed
4 oscillations in pump amperage and in pump flow so they
5 secured the B pump.

6 They vented the pump casing and the discharge
7 pumping, and then tried to restart the B pump. Once again,
8 they got oscillations in pump amperage and in flow. They
9 secured the pump again. Again, they vented the pump casing
10 and the discharge piping, but this time they also vented the
11 suction piping at these locations and in this location right
12 here. This is a crossover line that goes over the RHR
13 system.

14 Based on change in the volume control tank level
15 of about two percent they estimate that they got about ten
16 cubic feet of gas during this venting operation. They also
17 noticed that they had about 4.75 of unventable gas in this
18 line right here, going over to the RHR.

19 MR. KERR: I must say that's a rather accurate
20 measurement of the gas volume. It is sort of interesting.

21 MR. CARROLL: My question on that is, that is
22 standard cubic feet?

23 MR. FISCHER: Yes, sir.

24 MR. CARROLL: The other question I have is, does
25 everyone have motor amp meters in normal practice in

1 pressurized water reactor pumps?

2 MR. FISCHER: I am not certain sir, but they had
3 it at Sequoyah.

4 MR. MICHELSON: Yes, at Sequoyah they have it.

5 MR. CARROLL: It would be useful to find problems
6 like this if you do have amp meters, but I am not sure that
7 everybody does.

8 MR. FISCHER: The licensee believes that this gas
9 stripping is coming from these mini flow orifices on the
10 discharge of the centrifugal charging pumps. Where they
11 have this pressure drop, they believe that the local
12 pressure is reduced and the gas is coming out of solution.
13 The volume control tank has a hydrogen cover pressure on it
14 for chemistry control purposes, and this is saturated
15 primary coolant in this piping that the gas can come out of
16 solution.

17 MR. MICHELSON: That's a very low if not non-
18 pressurized tank. I mean, it's not a pressurized tank.

19 MR. FISCHER: It is pressurized to about 15
20 pounds.

21 MR. MICHELSON: Insignificant amount of pressure.
22 You are not forcing a lot of gas into solution by pressure
23 at that point.

24 MR. FISCHER: It may be noteworthy that Unit 2 was
25 doing an excessive amount of charging because it was late in

1 life. It is probably also worth noting that --

2 MR. SHEWMON: What does that mean; what does late
3 in life have to do with where it is charging what?

4 MR. FISCHER: They were doing a lot of dilution, I
5 believe --

6 MR. SHEWMON: Oh, latent fuel cycle.

7 MR. FISCHER: Latent fuel, right.

8 MR. CHAFFEE: Apparently the licensee, in looking
9 at this event, saw a couple of aspects that were
10 contributors to the gas that was coming out of solution.
11 One of them was the VCT and the other one was being late in
12 life -- dilution they believe was bringing into play water
13 that was not completely de-aerated and was providing another
14 source of gas contribution to the problem.

15 MR. FISCHER: At Sequoyah -- another thing that
16 might be noteworthy at Sequoyah, this mini flow orifice flow
17 is routed at Sequoyah back to the discharge of the VCT
18 through the seal water heat exchanger, right downstream in
19 discharge to the VCT or basically to the suction of the
20 charging pumps. If the gas is coming out of solution in
21 that orifice, it would go to the suction of the pump.

22 It used to be that the mini flow was routed back
23 to the VCT itself, but because of another concern with
24 regard to overflow of the VCT they repiped this to the
25 discharge of the VCT.

1 MR. CARROLL: Following up on what Al said, the
2 gas that would be coming out from the dilution would be
3 nitrogen from nitrogen blanket on the primary water storage
4 tank?

5 MR. FISCHER: There is a hydrogen gas cover
6 pressure in the volume control tank.

7 MR. CARROLL: I understand that.

8 MR. CHAFFEE: What I understood was that the
9 licensee thought that there were possibly two effects. One
10 was the hydrogen coming out of the VCT and the other one was
11 by having a lot of dilution going on you were introducing
12 some gases from this makeup water that was finding its way
13 into the system as well. Exactly what type of gas it was, I
14 don't know.

15 MR. CARROLL: Typically you have a nitrogen
16 blanket on the primary water storage tank.

17 MR. FISCHER: They did analyze the gas at Sequoyah
18 following the event, and it did turn out to be 97 percent
19 hydrogen.

20 MR. CARROLL: Oh, okay.

21 MR. FISCHER: When they had the event on August
22 22nd at Sequoyah Unit 2, they got in touch with
23 Westinghouse. Westinghouse provided the licensee with a
24 letter where Westinghouse determined that six cubic feet was
25 acceptable. This was based on engineering judgment from the

1 results of some more detailed analyses that Westinghouse had
2 done for Farley and for Beaver Valley. They felt that was
3 bounding and they could use that six cubic feet criteria for
4 Sequoyah.

5 MR. KERR: Six cubic feet of what?

6 MR. FISCHER: Of gas in the piping without
7 affecting the operability of the centrifugal charging pumps.

8 MR. CARROLL: What is the basis for that analysis;
9 how did they come up with six?

10 MR. FISCHER: I think that subsequent
11 presentations may get into that with a little more detail
12 than I am prepared to talk about.

13 MR. MICHELSON: Was that intended to mean
14 uniformly distributed in the fluid or concentrated in the
15 suction void points?

16 MR. FISCHER: Once again, I am not familiar enough
17 with the study that was done by Westinghouse and with what
18 our contractors have done.

19 MR. MICHELSON: That's where it will --

20 MR. FISCHER: It will be in the next presentation,
21 is really what I am getting down to.

22 MR. MARSH: This is Ted Marsh from the staff. Let
23 me just say at this point that we really don't know the
24 technical bases for this six cubic feet. We have been in
25 some discussions with Westinghouse, and at this point we

1 don't know. We have some information of our own that you
2 are going to hear about in the next presentation that will
3 talk about volume and the impact of various volumes in other
4 plant charging pumps but we don't, at this point, know the
5 basis for six cubic feet.

6 MR. FISCHER: Unit 1 had a nearly identical event
7 occur on September 6. They, as a result of the problems of
8 Unit 1 went over, and they found the same unventable volume
9 here on the crossover piping to the RHR system. It was a
10 slightly less volume, I think it was 4.3 cubic feet. It was
11 totally voided. Then they found a little bit more gas that
12 accumulated on the upstream side of this valve. In fact, if
13 you total the two volumes that they measured when they
14 measured it with ultrasonic testing of the piping and if you
15 added it, it was more than the six cubic feet. They went
16 into a 303 Unit shutdown until they could vent some of that
17 piping.

18 Initially, because the licensee thought the gas
19 was coming from the mini flow orifices, they used the
20 positive displacement pumps for normal plant makeup. They
21 wrote procedures for what the operator should do if the
22 positive displacement pumps were inoperable. In addition,
23 they have instituted and are continuing to routinely vent
24 the suction piping from the suction of both centrifugal
25 charging pumps to positive displacement pump and in this

1 crossover line.

2 MR. KERR: Has there been any evidence of pump
3 damage in any of these operations?

4 MR. FISCHER: Not to my knowledge, sir. It seems
5 like whenever they noticed that they experienced a problem
6 they shut the pump off right away.

7 MR. MICHELSON: There have been several LER's in
8 the past concerning this gas accumulation in the suction
9 lines. The pumps quit. If you void the suction lines
10 severely, and that has happened, then you raise the suction
11 -- you drop the suction pressure so low that the pumps just
12 quit. Then they will overheat if you don't shut them off.

13 MR. FISCHER: After they had the event they did do
14 some flow testing of the system. They did surveillance of
15 the system and the pumps were operating properly.

16 MR. MICHELSON: That was after the gas was purged.

17 MR. KERR: They didn't have any difficulty
18 recognizing the situation.

19 MR. FISCHER: No, sir.

20 MR. KERR: In shutting --

21 MR. CARROLL: As long as you have amp meters you
22 are going to recognize it. I am not sure that all plants
23 have put amp meters in.

24 MR. KERR: The information notice talks about
25 potential problems, and I am trying to find out what the

1 problem is. Being as ignorant as I am about pumps --

2 MR. CHAFFEE: Again, later on, when we have one of
3 the follow on discussions, we will go into some discussion
4 in detail about the impact of the gas on these centrifugal
5 charging pumps. Basically what they are going to say, as
6 you said, it air binds the pump. They will talk a little
7 bit about how rapidly that type of a scenario can degrade
8 the pump.

9 MR. CARROLL: In a matter of minutes you are going
10 to wreck the pumps, bottom line.

11 MR. CHAFFEE: The other thing that was interesting
12 is, when the licensee did shift and started using the
13 positive displacement pump they did see, as I understand it,
14 a reduction the production rate of gas. Apparently that
15 reinforced their belief that the gases that they were seeing
16 were coming from these orifices that come off the discharge
17 side of the centrifugal charging pumps. They used that as
18 some evidence to corroborate what they believed to be one of
19 the major producers of the gas.

20 MR. WILKINS: You indicated that one of the amp
21 meters will detect this. I notice they also refer to
22 fluctuations in the rate of flow. Are there flow meters or
23 some kind of --

24 MR. FISCHER: Yes, sir. There are definitely flow
25 meters.

1 MR. WILKINS: Is that on all such plants?

2 MR. CARROLL: I believe so.

3 MR. FISCHER: I am fairly confident that they do.

4 MR. WILKINS: I would think so. Would those by
5 themselves have detected the -- given some warning of the
6 event without the evidence from the amp meters.

7 MR. FISCHER: In my opinion, they should be
8 sufficient to diagnose the problem, particularly if you are
9 alert to the potential for problem.

10 The rate of gas accumulation is a function of the
11 plant-specific piping configuration, the volume control tank
12 pressure, the reactor coolant system dissolved hydrogen
13 concentration, and to some extent the charging rate. Where
14 you are going to get the bubbles is plant-specific as well.

15 MR. KERR: At some point you are going to tell us
16 that either one can or cannot eliminate gas accumulation; is
17 that the case?

18 MR. FISCHER: I don't think I am going to tell you
19 --yes, I will tell you that you cannot eliminate gas
20 accumulation. I think that's what the bottom line is.

21 There will be some, and that you should institute measures -

22 -

23 MR. KERR: This is a problem that we have to live
24 with. It is not something that we do to eliminate gas
25 accumulation.

1 MR. FISCHER: It's a problem that you have to live
2 with and establish procedures, and maybe have a plant design
3 that does not have excessive gas accumulation.

4 MR. KERR: Can Sequoyah redesign their plant so
5 that this is the case?

6 MR. FISCHER: Sequoyah has done -- in fact, in
7 addition to doing this venting routinely, they have
8 installed vents. On Unit 2 they have completed this
9 modification. On Unit 1 they intend to complete this
10 modification by the end of this month. They have installed
11 vents on either side of this to eliminate this larger volume
12 of --

13 MR. KERR: Vents don't prevent the accumulation of
14 gas, they just get rid of it as accumulated. The problem is
15 still there.

16 MR. FISCHER: Yes, sir.

17 MR. KERR: Gas accumulation. Is there anything
18 that can be done about that?

19 MR. FISCHER: You could conceivably install
20 continuous vents.

21 MR. CHAFFEE: As far as being able to prevent the
22 gas from ever coming out of solution, I have not heard yet
23 of any approach people are taking to prevent that. That
24 doesn't mean that it doesn't exist, I am just not aware of
25 it. Most of what Sequoyah seemed to do, at least from what

1 I have been told, is tried to address ways in which they can
2 prevent the gas that is coming out from accumulating.

3 One exception to that, obviously, they did find
4 that securing the charging pumps reduced the rate at which
5 the gas was coming out. It reduced it somewhat. Mainly
6 they focused on the frequency that they would vent and put
7 in these vents in locations that didn't have them so that
8 they could get rid of large volumes of gas.

9 MR. KERR: Thank you.

10 MR. MARSH: Mr. Kerr, again as we were saying, we
11 don't know exactly why the gas is coming out of solution.
12 It may be coming out for a variety of reasons. It may be
13 coming out in the suction flow path, it may be coming out in
14 the recirculation flow path, it may be coming out due to
15 other reasons, and we don't know why. Because the system
16 is operating with saturated hydrogen -- we have seen this
17 accumulation at a number of plants.

18 What you are going to hear more about today is the
19 actions we believe are necessary to make sure that if you
20 get accumulation of gas that it doesn't come into the
21 question of the pump operability. That is the next step
22 that we believe we are going to have to take based on all
23 this information.

24 MR. SHEWMON: Is this piping clad with stainless
25 steel or is it bare?

1 MR. FISCHER: I don't know the answer to that.

2 MR. WHELFEE: I can only speculate. I suspect it
3 is clad, but I don't know that for a fact.

4 MR. CARROLL: I'm pretty sure it's bore -- just
5 stainless steel piping.

6 MR. MICHELSON: Yes, that's all.

7 MR. SHEWMON: The hydrogen overpressure is put in
8 at the pressurizer?

9 MR. CARROLL: No, it's put in here.

10 MR. SHEWMON: The super saturation that you have
11 is one atmosphere in the VCT.

12 MR. FISCHER: It's 15 pounds, approximately ten to
13 15 pounds.

14 MR. SHEWMON: That's damn close to one atmosphere,
15 you have to admit.

16 MR. CARROLL: It is really two atmospheres
17 absolute. You are at 15 pounds gage.

18 MR. FISCHER: As was previously mentioned, there
19 were several information notices or several ways that the
20 licensee should have been aware of this problem before
21 August of this year. We had 88-23, the information notice
22 after the Farley event that was almost identical to this
23 scenario, we had two supplements to that information notice
24 which identified several different mechanisms to get gas or
25 hydrogen in the suction of your centrifugal --

1 MR. KERR: What would he have done differently had
2 he been aware of the problem? It sounds as if he identified
3 it fairly soon.

4 MR. ROSSI: He might have made the modifications
5 to these and captured this event sooner had he known --

6 MR. FISCHER: He might have had other vents and
7 would have had procedures in place to routinely vent the
8 piping so that they didn't run into a problem.

9 MR. ROSSI: It's a little difficult for us to tell
10 how much our information notices and supplements contributed
11 to identifying his particular problem when it started to
12 occur also.

13 MR. CARROLL: Did your information notices talk
14 about the trick of using ultrasonic techniques to --

15 MR. ROSSI: I don't believe that it did, no.

16 MR. CARROLL: That's a good application.

17 MR. MICHELSON: When they are doing their current
18 venting, are they trying to monitor the amount of gas they
19 see in the vent stream?

20 MR. FISCHER: I don't know of them physically
21 measuring the volume. Can I get some help here?

22 MR. DONAHUE: I am the project manager for
23 Sequoyah. The implication is that Sequoyah was not aware of
24 the problem, that somehow these information notices and
25 information from Westinghouse came and they did nothing.

1 That's not true. They did something. They did an
2 assessment, they just did it wrong. They reached a
3 conclusion that was not correct but they did act on it.

4 MR. MICHELSON: That's not the question that I
5 asked, of course.

6 MR. DONAHUE: I am talking back -- originally the
7 implication was that they did nothing, and that's not true.

8 MR. MICHELSON: Did you have an answer to the
9 question that I asked or somebody?

10 MR. FISCHER: Can you ask the question again,
11 please?

12 MR. MICHELSON: Are they presently monitoring what
13 they are seeing in the vent streams? Are they still seeing
14 gas, or are they just routinely venting --

15 MR. FISCHER: I know that they are venting
16 frequency as a function of which centrifugal charging pumps
17 they are using, and the determination on what frequency to
18 establish was based on ultrasonic testing of the gas
19 accumulation. I would suspect that they would, on some
20 frequency, check that.

21 MR. MICHELSON: Do you know if they are still
22 seeing gas accumulation?

23 MR. CHAFFEE: I believe the answer is yes, but I
24 don't think --

25 MR. FISCHER: Yes.

1 MR. MICHELSON: Whatever they have done so far
2 hasn't stopped the gas accumulation, it is just keeping it
3 purged out of the system.

4 MR. FISCHER: Yes. Depending on which pump the
5 frequency is different, and they go and vent it until they
6 get water.

7 MR. MICHELSON: The other precautionary steps that
8 they are taking apparently are not doing a whole lot of good
9 then?

10 MR. FISCHER: Now they are not exclusively using
11 that positive displacement pump. They are using the
12 centrifugal charging pumps and they are venting that piping
13 more frequently. This piping -- say if they are running the
14 A pump they are venting this one and this one.

15 MR. CHAFFEE: Also, I understand that after they
16 had the problem and they shut down -- I guess they must have
17 gone through refueling outage because when they came back
18 up, apparently they didn't see the production rate of gases
19 as high as they had previously. That is why apparently they
20 were led to believe that the dilution somehow was a
21 contributing factor. Apparently the production rate of
22 gases is less now than it was before. Again, they don't
23 completely understand it, but that seems to be an aspect of
24 it.

25 MR. MICHELSON: Proceed.

1 MR. FISCHER: The only other things that I wanted
2 to mention was that there was a Westinghouse letter that
3 went to TVA that talked about the Farley information notice,
4 and that information may not have gotten directly to the
5 licensee but there was a letter from Westinghouse talking
6 about this problem. There was also, I think, four INPO
7 operating experience notices and one recurring significant
8 event notification that could have alerted them to this
9 problem.

10 MR. MICHELSON: Are you giving any thought as to
11 whether other kinds of good information notices are escaping
12 their system?

13 MR. ROSSI: Let me go back to what was said
14 earlier. I don't think the notice escaped their system, I
15 think they looked at the notice -- I guess I would
16 characterize what they did as not enough to fully address
17 the problem.

18 MR. MICHELSON: They were aware -- maybe I
19 misunderstood. I thought the people that needed to know
20 didn't get the information. Perhaps that is not the case.

21 MR. ROSSI: Do you want to say some more on that?

22 MR. FISCHER: I think this was, in part, the case.
23 At least the Westinghouse letter went to TVA. Now, they
24 have instituted procedures --

25 MR. MICHELSON: I am more interested in what

1 happened, as to why it took quite a while apparently for
2 them to get the word.

3 MR. DONAHUE: TVA did become aware of both the
4 information notices and the Westinghouse report. They did
5 an assessment. The violation that was issued in terms of
6 the fact the assessment was not correct, all that was
7 stated.

8 What they did is, they made just a wrong
9 assessment.

10 MR. MICHELSON: Okay.

11 MR. DONAHUE: If you want to call it -- they were
12 not smart.

13 MR. KERR: You say a violation was issued because
14 they made the wrong assessment?

15 MR. DONAHUE: No. I am saying when the violation
16 was issued on this, this was all discussed. It is all in
17 the public record. They did get the information, they did
18 evaluate it, they evaluated it in an appropriate manner.
19 They just reached a wrong conclusion and concluded that they
20 did not have a problem.

21 MR. FISCHER: The licensee, in this particular
22 case, said that they did not fully understand the mechanism
23 by which gas was coming out of solution. The licensee said
24 that they had focused on piping configurations that were
25 above the volume control tank, because they thought that was

1 the emphasis in the information notices.

2 MR. KERR: They received a violation for this?

3 MR. FISCHER: I have no knowledge of that.

4 MR. ROSSI: I am not prepared to talk about the
5 violation. I don't know whether we have anybody here --

6 MR. KERR: You are prepared to tell me that they
7 did. I thought somebody said they received a violation.

8 MR. ROSSI: Can anybody tell them whether they did
9 or didn't get a violation. Do you know briefly what the
10 basis of the violation was?

11 MR. DONAHUE: No.

12 MR. KERR: I don't need to know the basis. I just
13 was curious --

14 MR. ROSSI: Okay, fine. They did get a violation
15 then.

16 MR. KEPR: Apparently they got a violation because
17 they didn't understand what was going on. Apparently,
18 nobody yet understands what is going on. I presume there
19 will be continuing violations.

20 MR. ROSSI: There may very well be.

21 MR. MICHELSON: Was the violation because they
22 didn't understand or because they just failed to take proper
23 actions to assure themselves they understood?

24 MR. ROSSI: I don't know what the basis of the
25 violation was.

1 MR. WILKINS: It might have been helpful if we had
2 the text of the violation notice in front of us here this
3 morning.

4 MR. ROSSI: We didn't really come --

5 MR. SIESS: I'm beginning to get a feeling that
6 the people that know what happened and the people that
7 assessed the violation are not the same people. Maybe the
8 violation didn't have any relation to safety.

9 MR. CHAFFEE: Here's what the violation says, at
10 least the cover page. It says the violation involves
11 inadequate corrective action for a problem that TVA was
12 alluded to by NRC, INPO and Westinghouse. Several concerns
13 were relative to corrective action for experience review
14 issues are stated in paragraph 7-A of the report. The
15 violation will go into more detail relative to that.

16 MR. CARROLL: What level was it?

17 MR. CHAFFEE: It says here, it's a level four.

18 MR. CARROLL: Five is the lowest.

19 MR. MICHELSON: A slap on the wrist kind of
20 violation. Why don't you proceed.

21 MR. FISCHER: The only thing that I might say is
22 that the safety significance of this event probably relates
23 to a small break loss of coolant accident where you need a
24 high head safety injection pumps. It is probably more
25 severe on plants that have ice condensers and have to go to

1 recirc sooner following a small break loss of coolant
2 accident, and it's probably more severe on plants that have
3 their charging pumps in a dual role as their high pressure
4 safety injection pumps.

5 MR. CHAFFEE: The reason for that is, where the
6 saw the largest amount accumulation of gases in this
7 crossover line -- in the picture there it shows from train A
8 -- as I understand it, you end up using that particular
9 portion of the system when you go to recirc. That is why
10 plants that -- the recirc and how fast you go to recirc
11 becomes --

12 MR. FISCHER: You use your RHR pumps to feed the
13 suction of the --

14 MR. KERR: Is the implication that in a LOCA they
15 would not be able to vent the gas, or that they might not
16 recognize it was there, or none of --

17 MR. FISCHER: The implication is that if they had
18 a loss of coolant accident and you did not assume operator
19 action and they had unventable gas here, that could get
20 ingested into the safety injection pumps -- the high head
21 safety injection pumps and could fail the pump or it might
22 cause degraded flow, or it could cause a pump to cavitate
23 and then reprime itself. That is the discussion that the
24 mechanical engineering branch is going to talk about.

25 MR. ROSSI: It also raises, obviously, this

1 particular situation could be the source of a common mode
2 failure which could cause loss of the safety pumps. That's
3 the bottom line.

4 MR. MICHELSON: Those are manual vents yet?

5 MR. FISCHER: Yes, sir.

6 MR. MICHELSON: They have to go right up to the
7 pipe and open the little valves.

8 MR. FISCHER: It is Tygon 2, striated over --

9 MR. CHAFFEE: What is interesting is, originally
10 at Sequoyah the area where they had the highest accumul^r
11 of gas it wasn't ventable. This concern at least ini^t ly
12 at Sequoyah that they couldn't vent it, although
13 subsequently they changed that at least in one unit. I
14 guess they are in the process of -- at least have plans to
15 do it in the other one.

16 MR. FISCHER: It appears to me clear that the
17 licensee was allowing a solid slug of up to six cubic feet
18 of gas accumulation, as opposed to having uniform mix as Mr.
19 Michelson was asking about.

20 MR. MICHELSON: You are not sure that is where it
21 is either, when you measure it. You don't know that that's
22 the piece unless you measured just that piece somehow. I
23 gather you measured it with a volume control tank, and you
24 don't know where the void was?

25 MR. FISCHER: That's correct. They had this

1 voided here, and they probably had little pockets of gas in
2 this line here and maybe even right at the top of that
3 horizontal pipe may have been filled with gas.

4 MR. MICHELSON: Suction of the pumps in all the
5 vent lines.

6 MR. FISCHER: That's all I had. Are there any
7 other questions before we get to the pump people? Mark, did
8 you have anything to add at this juncture?

9 MR. CARUSO: I think I covered --

10 MR. FISCHER: You may want to use that microphone
11 there if you want to talk.

12 MR. CARUSO: I really think you covered the issues
13 which were the potential for a common cause failure of
14 pumps. The problem at Sequoyah and others has been the gas
15 in this pipe that connects the RHR pump with the high
16 pressure pumps. There may not be vents there to vent all
17 the gas, and there are no generic tech spec requirements to
18 go over and vent that piece of piping.

19 I think we went through that. I think at this
20 point we will go right to the analysis of pump performance.

21 MR. CARROLL: Okay, let's do that.

22 MR. MARSH: This is Tad Marsh again. Let me set
23 the stage a little bit --

24 MR. WILKINS: May I ask one more question? Am I
25 correct that you implied that we really don't know where

1 this gas is coming from in the first place?

2 MR. FISCHER: I think that's a general consensus,
3 they really don't know. It appears that it is happening
4 where they are having local pressure reductions.

5 MR. WILKINS: Let me -- I am kind of naive about
6 these matters too. Local pressure reduction would tend to
7 pull the gas out of solution.

8 MR. FISCHER: Yes, sir.

9 MR. WILKINS: I understand that much. How did it
10 get in the solution in the first place; where did it come
11 from?

12 MR. CARROLL: In the volume control tank up there
13 see, there's a level maintained and hydrogen is bubbled into
14 that gas.

15 MR. WILKINS: Deliberately --

16 MR. FISCHER: Yes, deliberately.

17 MR. CARROLL: Yes.

18 MR. MICHELSON: It's not quite bubbled in, it's
19 put as an overpressure on the tank.

20 MR. WILKINS: In point, it is deliberate.

21 MR. MICHELSON: You are trying to control the
22 chemistry.

23 MR. FISCHER: It's even more than a free surface.
24 The makeup is often times sprayed into that tank through
25 this hydrogen --

1 MR. CARROLL: The reason for this is at primary
2 coolant system pressure this provides hydrogen -- dissolved
3 hydrogen in the primary coolant, not saturated anymore --
4 enough of it to combine with any free oxygen.

5 MR. WILKINS: To prevent corrosion.

6 MR. CARROLL: Yes.

7 MR. MARSH: You do not want any oxygen in the
8 primary coolant system, so you input hydrogen to make sure
9 that oxygen concentration is as low as it can possibly be.
10 This is the place in the whole system where you put hydrogen
11 into the system.

12 MR. CARROLL: The radiolytic decomposition
13 reaction. MR. MARSH: That also. Let me just set the
14 stage for Mr. Steve Mirsky from SAIC. As was earlier said,
15 there have been other events at other plants where we have
16 seen hydrogen accumulation. We saw some at Palo Verde, the
17 suction of their positive displacement charging pump, we
18 have heard about Beaver Valley and also at Farley.

19 What we did not know is the implications of this
20 hydrogen accumulation in terms of pump performance. We
21 hired SAIC who subcontracted to CREARE, to determine not
22 where it came from but the implications of it; what is the
23 impact of this hydrogen concentration on pump operability.
24 So, Steve will talk to us about that analysis.

25 MR. MIRSKY: As Tad said, the purpose of our

1 contract with Mechanical Engineering Branch was to perform a
2 technical evaluation of the behavior of charging pump in a
3 PWR with hydrogen in the crossover piping.

4 [Slide.]

5 For this specific analysis we looked at a three
6 loop pressurized water reactor with three high head safety
7 injection centrifugal charging pumps. Each of these pumps
8 is a multi-stage, 11 stage pump with a free internal void
9 volume of approximately eight-tenths of a cubic foot. There
10 were also two residual heat removal low head safety
11 injection pumps at this particular plant, and there is a
12 high elevation crossover line from the A RHR pump to the
13 charging pumps that has a long horizontal run greater than
14 150 feet. This elevation is above that of the pumps, the
15 RHR and charging pumps, and the volume control tank.

16 For the purposes of this analysis, we assumed this
17 crossover line was filled with 62 and one-half cubic feet of
18 hydrogen, which is approximately the capacity of this line.

19 MR. WILKINS: What is the diameter of that line?

20 MR. MIRSKY: Eight inches.

21 MR. MICHELSON: That's not the ID necessarily.

22 MR. WILKINS: What's the ID?

23 MR. MIRSKY: It's a schedule 40 pipe.

24 [Slide.]

25 This is a simplified schematic showing the general

1 piping, the elevations relative to the pumps, the volume
2 control tank, the RWST and the containment sumps. In this
3 case as previously mentioned for Sequoyah, there is a
4 hydrogen gas overpressure of 17 psi gage which is also used
5 for scavenging oxygen. I will refer back to this diagram as
6 I go through the rest of my presentation.

7 Basically, one of the RHR pumps has a high
8 elevation crossover line whereas the other one doesn't.
9 There is also, of course, a source of water during a LOCA
10 from the RWST. The specific sequence of events that we
11 looked at for this analysis was a small break LOCA
12 specifically in the size range between one and four inches.
13 This size range was selected because for this size LOCA the
14 refueling water storage tank water inventory is depleted
15 during the injection phase and the need for switching over
16 to recirculation occurs prior to the reactor coolant system
17 depressurizing below the shutoff head of the RHR or low head
18 safety injection pumps.

19 So that, there is a need for switch over to
20 recirculation using the RHR pumps to boost the pressure from
21 the containment sump to the charging pumps. What happens
22 is, after the RWST inventory is depleted, switch over is
23 initiated by having the RHR pump suction aligned to the
24 containment sumps, the discharge is aligned to the charging
25 pumps, and then the RHR pumps are started. For purposes of

1 this analysis we designated the point in time when the RHR
2 pump is started as zero.

3 [Slide.]

4 The analysis was done in two different phases.
5 The first phase was just looking at the hydraulic response
6 of the piping between the RHR pump discharge and the suction
7 of the charging pump. The second phase was an evaluation of
8 the behavior of the charging pump.

9 MR. CATTON: You calculated pressure in the piping
10 system --

11 MR. MIRSKY: Yes. A detailed time sequence
12 analysis was done in which the pump curves of the RHR pump
13 were used in determining the pressure response of the piping
14 and the behavior of the hydrogen gas in this crossover line.
15 What happens is that when the RHR pump first starts it
16 creates a pressure large enough in the downstream piping to
17 shut the check valve connecting the RWST to the suction of
18 the charging pumps, thereby aligning the charging pump
19 suction solely to the discharge of the RHR pumps.

20 The flow through the crossover line is
21 characterized by a high froude number greater than .7. A
22 froude number is a ratio of inertia to gravity forces. This
23 high froude number has been shown to cause column to flow
24 through the pipe. That is, the water behind the hydrogen
25 gas will push the gas through as a single homogeneous

1 unmixed volume. Also, the pressure increase from the
2 discharge of the RHR pump compresses this hydrogen volume
3 from 62 and one-half cubic feet to approximately 23 cubi-
4 feet.

5 At approximately six seconds into this event the
6 calculation showed that an 85 percent hydrogen void fraction
7 mixture enters the charging pump, specifically charging pump
8 A.

9 MR. CATTON: Is it a mixture or hydrogen?

10 MR. MIRSKY: It is a mixture. There is only pure
11 hydrogen in this volume here. There is some piping
12 connecting down to this isolation valve that is filled with
13 water, so the analysis actually followed what happened to
14 the hydrogen from this point to the entrance of the charging
15 pump. This charging pump has been shut off and isolated,
16 and each RHR pump is just feeding one charging pump.

17 MR. CATTON: Why didn't the hydrogen --

18 MR. WARD: You are making some kind of assumption
19 about mixing --

20 MR. MIRSKY: This is just a simple schematic.
21 Actually, it's a more complex piping network with some
22 elbows, bends and elevation changes. There are horizontal
23 and vertical runs that are filled with water. It was an
24 actual analysis that looked at the relative velocity of the
25 hydrogen as it entered those volumes with the known flow

1 rate being sucked in by the charging pump.

2 MR. CATTON: A bit of speculation.

3 MR. MICHELSON: Where the pipe is totally voided
4 and you are sending a water column from the RHR pump back to
5 the charging pump --

6 MR. MIRSKY: The pipe is voided in this region.

7 MR. MICHELSON: Yes. You are blowing a gas column
8 ahead of the water column that is coming out of the RHR
9 pump.

10 MR. MIRSKY: Correct.

11 MR. MICHELSON: It's almost pure compressed gas
12 entering the pump for a while.

13 MR. MIRSKY: You don't compress gas up to this
14 point.

15 MR. MICHELSON: For a very short time thereafter,
16 that's voided as soon as that compressed gas starts pushing,
17 you void the pipe into the charging pump and then it's pure
18 gas for a while. Then the water column hits it.

19 MR. MIRSKY: You are talking about the water
20 column upstream. I am talking about the existing water that
21 is in this piping segment.

22 MR. MICHELSON: That gets voided very quickly, of
23 course.

24 MR. MIRSKY: Some of it does get mixed. This is a
25 simplified drawing. This is not an exact drawing to show

1 you all the piping connections. There is actually a dead
2 leg here with some water in it, and as the flow goes through
3 the pipe some of the water from the dead leg that is
4 horizontally oriented will flow down into a vertical run of
5 pipe and mix with the hydrogen. There was an actual
6 analysis done to come up with --

7 MR. CATTON: Is it important how much mixing takes
8 place?

9 MR. MIRSKY: The only thing that is important is
10 the magnitude of the void fraction.

11 MR. WILKINS: Eighty-five percent number.

12 MR. MIRSKY: Being 85 percent is not as important
13 as the fact that it is a high number. The results would be
14 the same if it was 100 percent and the results would be the
15 same if it was 50.

16 MR. CATTON: The answer to my question was, it
17 really doesn't matter.

18 MR. MICHELSON: That's right.

19 MR. MIRSKY: It would matter if there was some
20 configuration in which it was two, three or four percent
21 void fraction.

22 MR. WILKINS: That would matter.

23 MR. CATTON: If it pushed the water ahead of it,
24 it would matter.

25 MR. MIRSKY: If there was a large piping network

1 here filled with water, if the volume of hydrogen was much
2 much smaller so that by the time it reached the inlet to the
3 charging pump the void fraction was very small, that would.

4 MR. MICHELSON: You somehow think the gas is being
5 pushed on through and sort of mixing as it goes then, or is
6 it a gas piston?

7 MR. MIRSKY: It's only mixing when it hits the
8 slug of water that is downstream of it.

9 MR. MICHELSON: Doesn't it behave like a gas
10 piston? It is highly pressurized from the head of the RHR
11 pump.

12 MR. WARD: See, there's another branch --

13 MR. MICHELSON: That gets it voided in a matter of
14 seconds.

15 MR. WILKINS: That is what he --

16 MR. MIRSKY: We are talking about six second time.

17 MR. MICHELSON: You are talking about just a few
18 seconds for this whole business.

19 MR. CARROLL: I bet it will all be clear when you
20 get to your next slide as to what happens in the pump.

21 [Slide.]

22 MR. MIRSKY: Just to put the timeframe reference
23 for this particular configuration, we predict at six seconds
24 this 85 percent hydrogen void fraction enters charging pump
25 A's inlet.

1 The analysis then showed within one-half a second
2 of this hydrogen void entering the charging pump, the pump
3 will stall. What will happen is that the last two stages of
4 this centrifugal charging pump will be filled with water and
5 the first nine stages will be filled with pure gas.

6 MR. WILKINS: That's what you said, Carl.

7 MR. MIRSKY: The pump will continue running at its
8 normal operating speed without providing any flow. What it
9 will be doing is balancing the pressure difference between
10 the inlet and the outlet. For this particular sequence the
11 inlet pressure was assumed to be the shutoff head of the RHR
12 pump 150 psi, and the discharge pressure was assumed to be
13 the reactor coolant system pressure predicted for the LOCA
14 of 600.

15 Those last two stages are all that is necessary to
16 be filled with water to maintain the pressurize.

17 MR. MICHELSON: I thought the head of the RHR pump
18 was more than 150 pounds.

19 MR. MIRSKY: For this particular plant it was 150
20 pounds.

21 MR. CARROLL: This particular being Farley, right?

22 MR. MICHELSON: No, Sequoyah, wasn't it?

23 MR. MIRSKY: I said it is a three loop PWR.

24 MR. MICHELSON: This is the three loop, okay. How
25 did I miss that?

1 MR. MIRSKY: This is obviously a very unstable
2 situation for the pump. At this point we made the following
3 conclusions. The pump will fail within a matter of seconds.
4 The only question is how it would fail. I have listed here
5 a number of possible failure mechanisms.

6 [Slide.]

7 The pump can seize because of a number of various
8 components within the pump that have a very small clearance
9 and that rely on having water lubricant present. Also, the
10 inboard mechanical seal can fail. Finally, we actually had
11 an analysis to show that the shaft that runs through this
12 pump -- and I believe this is typical of most centrifugal
13 charging pumps -- the shaft is seven feet long supported at
14 each end, and has design deflection at the center of about
15 one-tenth of an inch. You can show very easily by having a
16 small amount of water in one of these impellers in the gas
17 filled area that the unbalance in the shaft will well exceed
18 that allowable deflection. That would cause another means
19 of failing the pump.

20 Finally, I wish to point out that these results
21 are specific to these particular conditions that were
22 assumed for this particular plant with its configuration in
23 this sequence of events.

24 MR. MICHELSON: Even if you didn't deflect the
25 shaft, wouldn't you have problem with bearing cooling and so

1 forth since it depends upon flow anyway.

2 MR. MIRSKY: Yes. You are not going to maintain -
3 - the pump is not designed to operate in an all gas
4 environment basically.

5 MR. MARSH: Steve, will you comment please on what
6 would happen to the pump if it happened to survive and more
7 water got into the suction of the pump? In other words, if
8 water were to arrive at the suction of the pump.

9 MR. MIRSKY: Most of these methods of failure
10 would occur either with just operating in a nice, quiescent
11 gas fill environment or when the first additional drop of
12 water entered the pump. The pump impellers are not designed
13 to be rotating at 1,700 RPM in a gas environment. Once the
14 first additional amount of water entered and started
15 rotating around in the impeller, it would cause such a
16 hydraulic imbalance --

17 MR. CATTON: Eighty-five percent void, that's a
18 lot of water.

19 MR. MIRSKY: It was 85 percent hydrogen void.

20 MR. CATTON: I see. Fifteen percent water.

21 MR. MICHELSON: Yes.

22 MR. MIRSKY: The pump is not designed to pump 85
23 percent void solution.

24 MR. MARSH: As part of this study, SAIC looked at
25 pump data, pump test data, to find out what void fractions

1 had been studied in terms of pump performance. Correct me,
2 but there is very little data about --

3 MR. MIRSKY: Basically, none of the pump
4 manufacturers test their pumps with any kind of a void
5 fraction. If you ask them the reason why, it's because it's
6 too expensive.

7 MR. CARROLL: Too expensive.

8 MR. MIRSKY: It will destroy the pump. Most pump
9 experts will agree that up to somewhere in the range of
10 about five percent void fraction they would expect the pump
11 to survive without any damage. Most pump data that has been
12 done with limited pumps -- not multi-stage centrifugal
13 charging pumps -- shows that about 20 percent void fraction
14 the performance of the pump degrades significantly.

15 MR. CARROLL: In normal operation of the pump,
16 because of the pressure drop going into the suction, you
17 probably have a small void fraction of hydrogen given the
18 system is saturated with hydrogen.

19 MR. MIRSKY: The key word is small though.

20 MR. CARROLL: Yes. It normally runs with some
21 free hydrogen.

22 MR. MIRSKY: I would also point out that eight-
23 tenths of a cubic foot is the total internal free volume of
24 the pump. We assume 62 cubic feet that was then compressed
25 to 28. Eight-tenths or a little bit less than eight-tenths

1 cubic feet was in this pump at the time it had this event
2 occur.

3 MR. CARROLL: The rest of it is back up in the
4 suction --

5 MR. MIRSKY: It hasn't gotten down, yes.

6 MR. MICHELSON: Is there much of a tendency for
7 the hydrogen to come out of solution when the pump is in
8 lay-by? These pumps, many of them, are routinely in lay-by.

9 MR. MIRSKY: I don't know the answer to that.

10 MR. MICHELSON: What keeps it in solution -- if
11 you have enough overpressure I guess you can, but there
12 isn't much overpressure on the suction. Usually there are
13 vents provided on the pumps so once in a while you are
14 supposed to go down and get your air out. I just wonder if
15 they have had much experience with the gas accumulating;
16 that was really going to be my question. Have they had much
17 experience with gas accumulating in lay-by pump?

18 MR. MIRSKY: My only knowledge is that when a pump
19 starts exhibiting any abnormal behavior that it is shut down
20 immediately.

21 MR. MICHELSON: Yes, but it's too late if it's
22 gas.

23 MR. CHAFFEE: I do not believe that any of us here
24 know the answer to your question, Carl. I don't think we
25 have information on that.

1 MR. MICHELSON: I don't think it's much of a
2 problem and I haven't heard, but there are provisions
3 usually to vent the pumps as well, the pump casings as well.

4 MR. CARROLL: How does the analysis that you
5 performed comport with what we heard earlier, that
6 Westinghouse thinks up to six CFM --

7 MR. MIRSKY: I don't think that we have access to
8 all the information that is the basis for that number.

9 MR. MARSH: As I said earlier, we don't know the
10 basis for six cubic feet. It very well may be for various
11 plant configurations that six cubic feet is an acceptable
12 number. It depends a lot on how that six cubic feet gets
13 fixed and how it arrives at the pump, the pump volume, and
14 all those performance numbers. We don't know.

15 We do know that for this plant configuration which
16 was a real plant that it really did have this volume in it,
17 and it was very deleterious to the pump performance.

18 MR. CARROLL: Yes, indeed.

19 MR. MARSH: That is with a high degree of
20 certainty. It does depend -- you were saying it doesn't
21 matter of the 85 percent. That's true, but it does matter
22 in terms of smaller volumes and how that smaller volume
23 arrives.

24 MR. CATTON: When I said it didn't matter I was
25 referring to questioning the calculation. If 85 percent, 60

1 percent, 90 percent all does the same thing, then how good
2 you do your calculations it doesn't really matter. That's
3 the point.

4 MR. MIRSKY: The only importance of calculation is
5 that if you had a much smaller volume the --

6 MR. CATTON: I understand. I was concerned about
7 doing a lot of mixing calculations, and there's a lot of
8 assumption and approximations to do it. Then you arrive at
9 85 percent, and the question is how important is the 85
10 percent. The answer was not too important.

11 MR. WILKINS: Because you are so high.

12 MR. CATTON: That's right.

13 MR. MARSH: We heard earlier today about another
14 plant that had a pretty small volume, like 4.7 cubic feet.
15 We don't know the importance of 4.7 cubic feet.

16 MR. CATTON: Whether or not that could lead to the
17 same thing.

18 MR. MARSH: That's true.

19 MR. CATTON: That's right. Here, you have lots of
20 gas.

21 MR. MARSH: The conclusions are relatively easy.
22 This study had not been done before to our knowledge. No
23 one had taken a volume of gas in a particular configuration
24 for a particular pump and found the impact of that gas. We
25 think it's important because it leads us to take the next

1 step, which you are going to hear about in just a minute.

2 MR. CATTON: That, through a complex piping system
3 and predictive void fraction downstream somewhere, is not an
4 easy thing to do.

5 MR. WILKINS: That's true.

6 MR. WARD: It seems it's really not so important
7 whether there is this 62 and one-half cubic feet or ten
8 cubic feet, but it is really the mixing that you get before
9 it enters the pump that is important. Even if there is only
10 five cubic feet, if it doesn't mix adequately, it takes six
11 seconds to blow the pump.

12 MR. MARSH: It does depend a lot on how the system
13 is operating. It depends on the method in which the RHR
14 pump is started, valves are operated, which pump is operated
15 because of various elevation. It's a complex problem.

16 MR. WILKINS: This Westinghouse letter in TVA 88-
17 825 was sent from Westinghouse to TVA, I assume. Does the
18 ~~we~~ routinely get copies of such communications?

19 MR. MARSH: No, sir, we don't.

20 MR. WILKINS: We routinely do not get them. You
21 have said that you don't know the basis of this, and I infer
22 from that that you haven't even seen TVA 88-825. Am I
23 jumping to conclusions?

24 MR. MARSH: We have not seen that letter. We
25 routinely get Part 21 notifications from vendors to

1 particular plants. I don't believe this was a Part 21.

2 MR. MIRSKY: We have seen the six cubic foot
3 number previously, but not an explanation as to the basis.

4 MR. WILKINS: You haven't seen this 88-825 which
5 presumably contains that engineering --

6 MR. MARSH: We may or may not have, we don't know.

7 MR. CARUSO. We haven't seen the analysis or the
8 documentation, but we have been told that the six cubic feet
9 is coming from the five percent mixing. How they get there,
10 what they did to get there, we don't know. That is where
11 that number comes from. It is consistent with the five
12 percent where people feel if you are below five percent you
13 are going to have a problem. If you start to get above five
14 percent --

15 MR. WILKINS: I guess I am having a problem with a
16 procedural matter. Do you have -- have you been told that
17 Westinghouse will not send you a copy of that letter? Have
18 you requested it?

19 MR. ROSSI: We can get anything that we want
20 related to the safety of the nuclear power plant from
21 Westinghouse by asking them for it, bringing them down for a
22 meeting, or whatever we want. It depends on how deep and
23 how quickly we choose to dig into a particular issue.

24 MR. WILKINS: I infer from that, that you haven't
25 asked them for it yet.

1 MR. ROSSI: Apparently we haven't. We haven't
2 gone back and probed as yet where we are going. Maybe you -
3 -

4 MR. CHAFFEE: I guess there's a little confusion
5 on that. I guess we have -- we do have the document that
6 TVA sent to -- that Westinghouse sent to TVA which simply
7 says this is the number. What we don't have, I guess, is
8 the engineering analysis that it is based on. I guess we
9 are not even sure -- we don't even know if that exists.

10 MR. WILKINS: That wasn't made clear. You have
11 the document but what you don't have is the engineer that
12 wrote the document.

13 MR. CARROLL: The engineering analysis may be as
14 simple as someone pulling a number up.

15 MR. ROSSI: Let me just address that procedural
16 thing just a little bit more. Westinghouse is obligated, if
17 they determine that there is a flaw in something they have
18 sold to a nuclear power plant that would lead to a
19 substantial safety hazard, they have to tell us about it
20 under Part 21. Once they tell us about it under Part 21, we
21 can probe as deeply as we choose into all the backup
22 information and all that kind of stuff that there is.

23 Now, there is a level of information that is
24 passed from Westinghouse to their customers and licensees
25 and so forth, telling them about problems that we do not

1 routinely get. I mean, they don't routinely put us on the
2 distribution. In many cases we find out about it as soon as
3 the licensee gets it because the licensee will decide it's a
4 big enough problem that they have to tell us about it,
5 either in a telephone call to our operations center or by
6 submitting an LER. Once we know about it, we can obviously
7 go back and probe again as deep as we wish to probe.

8 Now, there are a number of issues that are
9 supposed to be handled by a licensee being responsible and
10 responsive to any sort of information that he gets from a
11 vendor of any equipment that he gets on his plant, and he is
12 obligated to evaluate that information and do whatever is
13 appropriate to keep the plant operating safely. What we
14 generally do is monitor that process, and if we decide it
15 isn't working in a particular case, we can jump in and issue
16 a bulletin, a generic letter or order, or whatever it takes
17 to make the licensee fix the problem.

18 What we do with information is, on the issues
19 which we think are reasonably important and where we want to
20 make sure that every licensee knows about the problem, then
21 we issue an information notice. Again, once a licensee gets
22 an information notice and he knows this information, he is
23 obligated to do at least some kind of evaluation to
24 determine whether it applies to his plant. If there is a
25 safety problem he is obligated to fix it.

1 Does that help on the procedural matter?

2 MR. CARROLL: One other related issue. Has
3 Westinghouse seen the SAIC analysis, or are they aware of
4 it?

5 MR. MARSH: Yes, they have. We had a meeting with
6 Westinghouse, with SAIC, CREARE, the staff, to make sure
7 that the assumptions that were made by SAIC and CREARE were
8 acceptable assumptions. We didn't deviate from the actual
9 system configuration of the way the system would really
10 perform.

11 MR. CARROLL: That ... assumptions that went
12 into the analysis.

13 MR. MARSH: That's right. And, the analysis as
14 well.

15 MR. CARROLL: Have they seen the analysis?

16 MR. MARSH: We had a two hour meeting with them,
17 where we went through the same presentation in much more
18 detail.

19 MR. CARROLL: What was their reaction to that?

20 MR. MARSH: No comment. We were asking them for,
21 are we correct, are the conclusions correct, and what do you
22 guys think about this. They said it looks like it's
23 probably right. Some of the assumptions may be a little
24 quibbable in terms of the froude number whether it's a
25 little bit below or not. My remembrance if that it was a

1 basic agreement.

2 MR. CARROLL: When did that meeting occur?

3 MR. MARSH: July.

4 MR. MIRSKY: July of this year. I would like to
5 point out also that although Westinghouse may be responsible
6 for their plants, the piping configuration is not a
7 Westinghouse item. It is an architect/engineer. Every
8 plant, maybe every two unit plant, may have entirely
9 different piping.

10 MR. SIESS: If they were standard, they could all
11 be wrong.

12 MR. CATTON: -- an arbitrary piping system, and
13 arbitrary amount of gas and predict the void fraction as a
14 function of time of the pump inlet.

15 MR. MIRSKY: Right. That's a difficult problem.

16 MR. CATTON: I would like to see your analysis, if
17 that is possible.

18 MR. MIRSKY: Yes, sir.

19 MR. CATTON: I think there are some tricky things
20 that you have to deal with.

21 MR. MARSH: There's much more that was done than
22 what Steve is talking about. Time step analysis that he
23 went through is a very detailed analysis. For each piping
24 run as a function of time, calculated void number and how
25 the fluid went through the piping, there is much more to it

1 and we would be glad to share it with you.

2 MR. CATTON: I would like to see it.

3 MR. CARROLL: Okay, where do we go from here?

4 MR. MARSH: We would like to ask Mark Caruso to
5 now discuss -- to summarize the event study that was done
6 and where we go from here.

7 MR. CARUSO: There are a couple of important
8 points that we heard this morning. One is the ability to
9 get this hydrogen gas accumulating as a source of it is very
10 well generic. We have a lot of plants out there that have
11 the hydrogen cover gas in the VCT and the piping for
12 charging also doubles for ECCS, and there is potential for
13 having accumulation. From there it gets to be, as you said,
14 tricky as to whether or not you have a big problem or a
15 little problem or any problem depends on getting this gas
16 out of solution. Where that can happen and where it can
17 accumulate, that is dependent we think very much on the
18 particular piping system and particular arrangements.

19 [Slide.]

20 In the case of Sequoyah and some of the other
21 plants, there appears to be the propensity for getting
22 absorption and having it accumulate at least in one case, a
23 large volume. I think our feeling is that to study this
24 problem somewhat more at the NRC level is really not going
25 to identify where a problem exists and doesn't exist. A

1 licensee have known about the potential for this problem --
2 we have assumed that they have been fixing it if they have
3 the problem, evaluating their systems, taking action. The
4 Sequoyah event raises a concern that it is not happening in
5 an adequate way.

6 I think our feeling is that it is time for the
7 licensees to do it if they haven't done it, evaluate and
8 inspect if necessary with the ultrasonic devices, determine
9 whether or not --

10 MR. CARROLL: Does this present information notice
11 tell them about that technique?

12 MR. CARUSO: I don't believe it discusses that.

13 MR. ROSSI: The notice does not tell them about
14 that. Maybe that is something that we need to look at, as
15 to whether they all know about it. I gather that there has
16 been other communications to the licensees --

17 MR. CARUSO: There has been a generic
18 communication from Westinghouse to licensees.

19 MR. CARROLL: Talk about ultrasonics as a
20 technique for finding these void spaces?

21 MR. CARUSO: I'm not sure. I would have to look.

22 MR. CARROLL: Maybe INPO has told them.

23 MR. ROSSI: That is something that I think we need
24 to look at, whether they have been adequately informed of
25 the technique.

1 MR. CARROLL: That's a pretty easy way to show
2 what you got.

3 MR. MARSH: One thing we want to focus on though
4 is yes, suppose they have a good way of determining where
5 the volume is and what the volume is at that point. That
6 still doesn't mean that the volume that they are trying to
7 keep the system down to, the hydrogen volume, is an
8 acceptable number. I think what we are concerned is that
9 the number itself that some licensees may be trying to keep
10 the number to might not be the right number, as well as the
11 detection for it and actions to keep it at that number.

12 MR. CARROLL: If I know for example that I have a
13 dead leg I can't vent, that is an important piece of
14 information.

15 MR. MARSH: Right.

16 MR. CARUSO: We would basically in general propose
17 that they evaluate and inspect and determine the propensity
18 for accumulation in their piping, and the availability of
19 vents at locations they need to have them at or continuous
20 vents. We would think that in the short term if they have
21 the problem that they take a short term action to reduce the
22 potential for accumulation. Sequoyah did that to the extent
23 of finding that just using their positive displacement pump
24 because of the recirculation piping tended to reduce that
25 potential.

1 Also, to vent with the vents that they do have
2 until they can develop and implement more permanent fixes
3 that take care of the problem. Taking care of the problem
4 is not clear to us. I think we would like to have zero
5 cubic feet of gas and that's what they would need to strive
6 for.

7 This particular issue is somewhat similar to an
8 issue that we had back in the mid-1980's, steam binding of
9 aux feedwater pumps, where you could have steam leaking back
10 through recirculation lines which are connected to a common
11 header so you could have the problem of leaking into
12 multiple pump suction. In that issue we asked licensees to
13 inspect and determine if they had a problem and take actions
14 to fix it, although I think in that particular case there
15 may not have been hardware fixes other than preventing the
16 leakage of the steam with the check valve fixes.

17 In this case, the leakage if they have it, I think
18 what we found is if they are accumulating it is happening
19 fairly rapidly; and that, to fix that there's needs to be
20 some sort of continuous vent maybe.

21 MR. CHAFFEE: In the case of Sequoyah, they
22 figured they were producing gas at the rate of one-half a
23 cubic feet an hour. So, it's fairly rapid. Also, you
24 talked about the fact that -- how much gas is enough and a
25 problem or not. I guess in Sequoyah's case, they apparently

1 did have an appreciable amount of gas in their charging
2 pumps. It is not clear -- I guess from talking to the
3 project manager they may have had such a large quantity that
4 there may be some uncertainty -- it may add to some
5 uncertainty in terms of how much gas it really takes to
6 cause a problem.

7 I guess as you have seen from the analysis and
8 stuff, there are a lot of subtleties to this thing.

9 MR. WARD: Mark, on the steam binding of the aux
10 feed pumps that you referred to, wasn't one of the solutions
11 or corrective actions taken in that was to ask the licensee
12 to make use of any ability they had to monitor the
13 temperature of those? That is kind of parallel with the --

14 MR. ROSSI: That one had an easy solution, in that
15 you could go and feel the piping too and tell what the --

16 MR. WARD: Parallel with that is Jay's ultrasonic
17 monitoring I guess here.

18 MR. CARUSO: My understanding of the technique is
19 that it is very good at finding the boundary between the
20 liquid and the gas. I think what they are doing is looking
21 for the boundaries and saying I have the size bounded and
22 how big the pipe is and how much --

23 MR. WARD: Yes.

24 MR. CARUSO: Another corrective action that I
25 believe has been taken at least at one plant is to insert

1 water seal between the RHR pipe that we talked about that
2 feeds the charging pumps and the charging pump suction to
3 basically be a barrier for migration. In that case, it is
4 essentially probably reducing significantly the gas and the
5 suction but it could still leave in the RHR pipe gas up
6 there, which is very much of concern.

7 We don't think that the fixes are all that
8 complicated, and we would imagine if we were to implement
9 generic action that these things -- immediate actions could
10 be taken as they were taken in Sequoyah and longer term
11 actions could certainly be done we think, at the next outage
12 if mods are necessary or that complicated.

13 MR. CARROLL: What you are saying is that you are
14 just going to put out another letter with a bigger four by
15 four in it to get people's attention.

16 MR. ROSSI: That's our next choice. If we decide
17 that we have to do that, we can put out a bulletin or
18 generic letter that requires a letter back from the licensee
19 telling us what they have done and so forth. We can go to
20 any level --

21 MR. CARROLL: Your present plan is just to put out
22 an information notice?

23 MR. ROSSI: We have done that. We have put the
24 information notice out now. Now, we are continuing to look
25 at the problem.

1 MR. CARROLL: You are speaking of the one that is
2 going to go out on December 10 or whatever?

3 MR. ROSSI: Yes. That one will go out, because
4 it's on the way right now in the process. People are
5 continuing to look at the appropriateness of sending the
6 next two by four out, so to speak. The next two by four --
7 it means that we have to get more into the process of
8 telling them how to fix the problem. That is what the next
9 two by four means.

10 The information notice means here is the
11 information, and it leaves it open to the licensee as to how
12 he goes about fixing the problem.

13 MR. WARD: How much does this problem increase
14 core melt risk in a three loop PWR.

15 MR. CARUSO: I don't think we know that answer.

16 MR. MARSH: I don't think it is insignificant. I
17 do not. I think there have been studies that showed the
18 circulation post-LOCA is, there are risks that are there,
19 and that is a contributor.

20 MR. ROSSI: As a matter of fact, our notice says
21 that the loss of high pressure recirculation capability of
22 Sequoyah during a small break LOCA is a risk contributor for
23 core damage frequency identified in 1150. You have to go
24 on, what is the probability of this particular --

25 MR. KERR: The fact that it is already high may

1 mean that this is not a significant contributor also. I
2 think that's unlikely but it could mean that.

3 MR. CATTON: You mean, it's not going to make it
4 that much higher.

5 MR. KERR: Yes.

6 MR. CARUSO: I don't think this particular failure
7 mode of the pumps has been factored into risk analysis.
8 There are other --

9 MR. KERR: That may well be, but it might be -- it
10 could be that even if you factored it in it wouldn't have
11 much effect, if the failure of the pump is already a
12 significant contributor.

13 MR. LONG: This is Steve Long of the staff. I am
14 in the Risk Applications Branch. I took a look at the NUREG
15 1150 PRA for Sequoyah, and it essentially asked that same
16 question. If you fail one train of recirc which is what
17 this will potentially do, because there's another train that
18 it not affecting -- you just about double the core damage
19 frequency from Sequoyah. It is a significant problem.

20 MR. MICHELSON: To what extent --

21 MR. WARD: Part of the risk, by the way --

22 MR. KERR: You don't know what the likelihood of
23 failing the two simultaneously is. Until you know that, I
24 don't think you know it is a significant problem, do you.

25 MR. LONG: I was really trying to give you a

1 feeling for the exposure because you asked could it be a
2 problem.

3 MR. CARROLL: There is a real common mode problem
4 there though because --

5 MR. KERR: It's a problem only if it has a high
6 probability, Jay.

7 MR. CARROLL: I understand.

8 MR. KERR: I don't mean it isn't. I am simply
9 saying that the fact that it can potentially happen doesn't
10 mean it is a big risk contributor.

11 MR. LONG: One of the things that adds to the
12 potential risk is that there is currently no tech spec that
13 requires you to flow test the crossover piping or to do
14 anything other -- you don't have to vent the suction piping
15 or cross piping. If a bubble occurs there it can persist
16 for years. You test the stroke times of the valves in that
17 piping, so you provide a mechanism for migrating the bubbles
18 around. If they are produced in the charging header they
19 can move up and continue to accumulate in the valves that
20 normally -- there is a lot of exposure there. The problem
21 is definitely worth looking into.

22 MR. WARD: Could I just get a repeat of that
23 point? My impression was that if there is a large bubble in
24 the piping that it is just sitting there forever. I mean,
25 it's not --

1 MR. CARROLL: It ain't going to go away.

2 MR. MICHELSON: Yes, that's right.

3 MR. ROSSI: That assumes that the licensee does
4 nothing to go and look and see if there is a bubble.

5 MR. WARD: I mean, if there isn't any action taken
6 --

7 MR. ROSSI: That means he would have to comply to
8 a large extent the information that has been conveyed to him
9 in information notices and by Westinghouse and so forth.

10 MR. WARD: Aside from the analysis that has been
11 made recently, the mechanism for the bubble formation isn't
12 something that just happens every now and then. It is an
13 equilibrium situation with the plant.

14 MR. MARSH: It probably is. If there are high
15 spots, there probably will be gas accumulation, and absent
16 some kind of action it will stay there. We have heard
17 theories that it is just recirculation during the recirc
18 flow of the charging pumps, but we have seen other plants
19 where that is not the case. In the Palo Verde case,
20 operating the control tank in an incorrect manner caused
21 them to accumulate gas in the charging pump volumes and to
22 starve the charging pumps. It can occur in a number of
23 different ways.

24 I think we are not sure about Farley and how it
25 accumulated there. It may have been that just the suction

1 flow path with no recirculation phenomena -- just the
2 suction flow path where it is bends and elbows caused gas to
3 come out of solution and to migrate to high spots. You are
4 not sure of the mechanism, and it probably is a natural
5 phenomena for that system.

6 MR. CATTON: Is there consideration for the
7 ELWR's?

8 MR. CARROLL: I haven't heard any discussion of
9 that.

10 MR. CATTON: We ought to raise this issue.

11 MR. CARROLL: We ought to raise this issue.

12 MR. MICHELSON: The gas binding of pumps, of
13 course, is not unique to high pressure pumps, it is not
14 unique to pressurized water reactors. Boiling water
15 reactors also have an interesting set of gas binding
16 potentials.

17 Are you looking at that full spectrum, or are you
18 focusing just one PWR high pressure?

19 MR. MARSH: Up until -- that's part of the process
20 that will have to be gone through for the generic
21 communication to determine how widespread this communication
22 of this sort needs to be.

23 MR. MICHELSON: While you are going through it,
24 perhaps you should give some thought to a problem which is
25 almost age old now -- early 1970's -- and it still exists

1 possibly today, the resolution at that time was done at that
2 time, and it may not stand the light of day today. The
3 problem is simply that of boiling water reactors during
4 post-accident to pump from a suppression chamber, keeping in
5 mind you are pumping aerated water.

6 The gas from the dry well has been bubbled through
7 the wet well, the steam is condensing, the gas is finally
8 divided. The estimates at that time where there was a
9 several percent average void fraction potentially in the
10 suppression pool. The real problem is that if you can keep
11 that divided and uniformly distributed, the low pressure
12 centrifugal pumps can probably ingest it and get it through.
13 If you allow it to start to strip in the appropriate piping
14 points on the suction, you are going to build up gas
15 bubbles, you are going to lose suction heads, you are going
16 to hit the pump with gas bubbles and you got a real problem.

17 The resolution was that it will be finely divided.
18 I don't know if that was a staff resolution or a General
19 Electric resolution. In looking at the gas binding question
20 again, I think you ought to go back and at least revisit the
21 question of what are you trying to pump particularly during
22 post-accident. You are also getting into almost the same
23 problem after the relief valve problem on boilers were fixed
24 because of the instability of relief, they put all these
25 feet in and so forth. They also had to add vents inside the

1 drywell to keep those pipes empty when the valves weren't
2 operating. Those vents also aspirate the air then.

3 So, whenever you are venting during an isolation
4 you are venting a steam air mixture, steam coming from the
5 reactor and air coming from the drywell. Again, there is a
6 question of aerating the suppression pool, and can you keep
7 pumping that without stripping the gas and getting into
8 problems.

9 While you are looking at gas binding, I think that
10 one ought to be revisited because a long time ago people
11 decided that was a non-problem.

12 MR. CARROLL: Is there any more on this particular
13 issue?

14 [No response.]

15 MR. CARROLL: Let's hope the remaining three don't
16 take as long. In fact, it's 10:00.

17 MR. MICHELSON: It's a good time for a ten minute
18 break, until 10:10.

19 [Brief recess.]

20 MR. MICHELSON: Let's proceed.

21 MR. CHAFFEE: The next event that we are going to
22 talk about is the MSIV closure at Brunswick. Al Belisle,
23 who is a Section Chief in Region II and led the AIT, will
24 talk to us about this event.

25 MR. BELISLE: As Al Chaffee explained, my name is

1 Al Belisle. I am the Section Chief of the test program
2 section. I happened to be at Brunswick when this -- right
3 after this event and when the determination was made to make
4 a team I was chosen to lead the team.

5 Basically what happened was, it was a scram. The
6 problem was the scram would degrade performance of some
7 valves. The cause was a violation of plant procedure. That
8 is unique, and I will discuss that in just a minute. The
9 safety significance was the unnecessary challenge to the
10 plant safety systems. Both units were operating at the
11 time. A staff briefing was held for routine surveillance
12 that had to be done that evening. The work was basically
13 dispositioned among the technicians.

14 One of the tests that had to be done had to do
15 with PCIS containment isolation. The way Brunswick
16 administrative procedures are written, this requires two
17 people to do it. The technician, about 9:00 o'clock that
18 evening, the technician received permission from the control
19 room operator to commence this test. The man that was
20 assigned with him to help him perform this test was back in
21 the INC shop helping some other technician repair a
22 recorder.

23 The technician commenced to do the test.
24 Basically it's a four sequence test. He goes into cabinet
25 A-1, generates a trip signal, verifies some lights and

1 breakers work and the appropriate lighting is received in
2 the control room, clears that channel, goes to the second
3 channel and does essentially the same thing, clear those
4 signals and goes to the third channel. When he was in the
5 third channel what he failed to do was clear the signals.

6 Consequently, when he went to the fourth channel
7 with one channel partially tripped and put the test signal
8 in, the plant scrambled on a two out of four coincidence
9 signal. Just prior to the scram he came out to talk to the
10 control room operator. As the control room operator was
11 going back to talk to him, the control room operator says
12 did you just give me this scram signal? The instrumentation
13 technician says, I just put the test module in. I think it
14 must have spiked.

15 The communication, what they were actually talking
16 about was two different channels. The control room operator
17 was talking about the insertion of the scram signal on
18 channel A-2 and the INC technician was talking about the
19 scram signal because he put the test module in channel B-2.
20 The lack of communications between the two guys basically
21 said -- and then the control room operator said oh, okay,
22 thinking that they were talking about the same channel when
23 in reality they were talking about two different channels.

24 Because they were talking about two different
25 channels when the INC technician put the signal in on the B-

1 2 channel it caused the plant to trip. When the plant
2 tripped--

3 MR. SHEWMON: Is there anything that the second
4 technician does except to watch and double check what the
5 first technician does?

6 MR. BELISLE: The second technician's function is
7 for independent verification. When the plant tripped, the
8 first technician got on the MC system and called the second
9 technician and says come out here real quick. He says I
10 have been doing the test and everything is okay. Here, sign
11 my procedure form. We didn't have anything to do with the
12 scram.

13 The second technician, recognizing honesty and
14 integrity or whatever you want to call it, did it.

15 MR. MICHELSON: Did it, meaning sign it?

16 MR. BELISLE: He signed for steps that were not
17 verified. Later into the event the site incident
18 investigation team met about midnight, and by 4:00 o'clock
19 they had talked to the technicians and says what you say on
20 this piece of paper could not have happened and what did
21 happen. Basically they extracted confessions from the
22 technicians that said we lied.

23 During the course of the event, reactor pressure
24 reached 1,133 pounds and some of the safety relief valves
25 did not operate. Those safety relief valves that did not

1 operate were put under quarantine and sent to Wylie for
2 testing. During the subsequent testing at Wylie they were
3 basically found to be set high. Previous to their
4 installation during the last outage they were also set
5 within specs at Wylie, and this is kind of an ongoing issue
6 in safety relief valve drift.

7 MR. CARROLL: Wylie had performed the last actual
8 setting of them but --

9 MR. BELISLE: Yes.

10 MR. CARROLL: What is the explanation, do they
11 know?

12 MR. BELISLE: They expect some pilot seat bonding.

13 MR. MICHELSON: Some people think it's hydrogen, I
14 guess.

15 MR. BELISLE: I am not a safety relief valve
16 expert, so I can't address your issue one way or the other.

17 MR. MICHELSON: I think it's still premature to
18 talk about them but they do have a sticking problem. Some
19 people, including one of our former members -- this has been
20 going on for years more or less -- thought that it was
21 hydrogen welding.

22 MR. BELISLE: It gave one data point, in that the
23 unit had only been operating for a couple of months since
24 coming up from their outage. During discussions with the
25 plant people and these safety relief valve problems, it was

1 never known if this was something that occurred over the
2 course of the outage or something that happened just as soon
3 as you put the valves back in and heated them up. At least
4 this gave one data point that since the plant had only been
5 operating for a very short period of time it appears that
6 the bonding may be reasonably rapid. That's hypothesis on
7 my part.

8 MR. MICHELSON: They did test the valves again at
9 Wylie, or do you know?

10 MR. BELISLE: Yes.

11 MR. MICHELSON: They were now tested within their
12 set point or found high?

13 MR. BELISLE: They popped the valves four times at
14 Wylie. The pressures on the initial pop was anywhere from
15 about three to ten percent high.

16 MR. MICHELSON: And then, after that?

17 MR. BELISLE: After each test pressure started to
18 come back down again. The basic conclusion of the AIT was
19 the scram did result from an intentional departure from
20 procedural compliance exacerbated by a lack of command
21 control by the operations people. The transient was
22 complicated by some equipment failures, poor procedure aids,
23 and negative training on the simulator.

24 MR. CARROLI: What were the operations people
25 supposed to do?

1 MR. BELISLE: The operations -- what were they
2 supposed to do, I'm not sure I understand.

3 MR. CARROLL: Your statement is that the problem
4 was exacerbated by their lack of command and control. What
5 did you feel was lacking there?

6 MR. BELISLE: When the communications, prior to
7 the surveillance maintenance being performed, what the INC
8 technicians do -- there's a rip off sheet on the
9 surveillance test. He gives that to control room operators.
10 This basically tells the control room operators, these are
11 the following alarms that you are going to receive.
12 Obviously, these alarms were received during the course of
13 the evolution.

14 From our perspective the control room operators,
15 since they do so many surveillance -- this is a routine
16 evolution -- they get what we felt was maybe no hum, it's
17 another routine evolution and no big thing. When the
18 instrument and control technician gave him the signal from
19 channel B-2 that showed that the channel was in trip, he
20 already had an indicating light -- an annunciator light
21 showing him a valid scram signal on channel A.

22 We felt that when we discussed this with the
23 control room operators and asked them point blank, you had
24 this channel in scram and you had this channel in test,
25 didn't that alert you to the possibility that when that

1 instrument and control technician cranked his signal you
2 were going to drop the plant. He waffled on that point
3 somewhat during our discussions. We felt that maybe perhaps
4 this is such a routine evolution that it maybe got to be
5 sort of dull and boring because it was a later Sunday night
6 or whatever.

7 A more positive control by the control room
8 operator -- he had the opportunity to ask the question.
9 When him and the INC technician met and discussed he is
10 talking about channel A and the INC technician is talking
11 about Channel B, he could have been more positive. He
12 should have -- we felt he should have been aware -- more
13 cognizant of what the INC technician was doing.

14 MR. CARROLL: These two techs were on shift or
15 were called in specially to do this?

16 MR. BELISLE: No, they were on shift, as part of
17 the routine weekend duties.

18 MR. WILKINS: Should the control room operator
19 have known that there was only one technician in the room
20 doing the work?

21 MR. BELISLE: The channels, relative to where the
22 control room operators are, probably are separated by 50
23 feet or so. Unless he had physically walked back there and
24 talked to Joe or Harry he probably would not have known.

25 MR. WILKINS: Let me rephrase the question

1 differently then. Should he have asked -- can they
2 communicate without his walking back?

3 MR. BELISLE: I believe there is some
4 communication back there, but I am not sure. Should he have
5 asked?

6 MR. WILKINS: Yes.

7 MR. BELISLE: That's an interesting hypothetical
8 question which gives a hypothetical answer. Their
9 administrative controls require a test of this type to be
10 done by two people. So when the technician came to the
11 control room operator and said I am ready to start this
12 test, there would have been nothing to trigger the control
13 room operator that he was doing the test by himself. These
14 were seasoned technicians, they had been there for the
15 average of I think -- one was there for seven years and the
16 other guy was there for five years. They are not brand new
17 people.

18 This is a routine evolution and they do it every
19 31 days. Both of these INC technicians had done it before
20 on multiple occasions.

21 As corrective action because of what happened,
22 they basically fired the two technicians. They re-performed
23 the surveillance test, they went through and evolved some
24 new maintenance pre and post-job briefing requirements. The
25 plant manager conducted personnel meetings with all plant

1 work groups. They instituted a course of formalized
2 communication between the control room operators and people
3 performing work in the plant. Maintenance people adopted
4 some standards of excellence and upgraded some procedures,
5 and did some work on the simulator.

6 MR. WILKINS: Let me approach my point in a
7 different direction. These two technicians have a
8 supervisor.

9 MR. BELISLE: That is correct.

10 MR. WILKINS: Where was the supervisor?

11 MR. MICHELSON: Could you use your microphone
12 Ernest?

13 MR. WILKINS: These two technicians have a
14 supervisor; where was the supervisor?

15 MR. BELISLE: The supervisor was not observing
16 this particular test, he was tied up on other duties.

17 MR. WILKINS: The AIT and management at the plant
18 determined that he didn't fail to do anything he should have
19 done?

20 MR. BELISLE: The supervisor?

21 MR. WILKINS: Yes.

22 MR. BELISLE: It has been -- Bill, please correct
23 me if I am wrong -- it has been a long running issue I
24 believe at Carolina Power and Light. I am speaking --
25 please keep it in perspective -- beyond the grounds of the

1 AIT. More supervision and day-to-day involvement is
2 required by their people.

3 MR. WILKINS: This is just one more instance of --

4 MR. CARROLL: On something with experienced people
5 as experienced as this a supervisor wouldn't normally be
6 looking over their shoulder.

7 MR. WILKINS: Understood. Would the technician
8 have said to the supervisor, I am about to start this.

9 MR. CARROLL: Not necessarily. He probably has a
10 list of surveillance tests to do and just goes off and does
11 them.

12 MR. BELISLE: That's exactly correct.

13 MR. WILKINS: Okay.

14 MR. LEVIS: This is Bill Levis, NRC Staff resident
15 inspector, Brunswick. I would like to add one little thing
16 to this. The technician was flying through the test. These
17 channels typically take about 15 minutes a piece to do, so
18 you would expect an hour total duration for the test.
19 However, this technician was averaging four to five minutes
20 per channel.

21 The supervisor, I wouldn't expect him necessarily
22 to have gone out and actually watched this test while he was
23 performing his supervisory duties.

24 MR. CARROLL: Once in a while it isn't a bad idea
25 for a supervisor --

1 MR. LEVIS: That's correct. The supervisor is
2 required to go out and monitor activities that he is
3 responsible for. Had the test taken an hour, that very well
4 might have occurred. We have seen them at the site, other
5 supervisors monitoring the activities of this particular
6 crew.

7 MR. WARD: Perhaps I didn't hear and I apologize
8 for that, but is there any indication of whether or not this
9 was an isolated incident or whether there is a pattern of
10 testing like this?

11 MR. BELISLE: This was thoroughly investigated by
12 the licensee staff, by their QA staff, and this truly
13 appears to be an isolated instance. This is basically a
14 plant manager's nightmare. They guy was winging it, for
15 lack of a better explanation. Are there any other questions
16 or comments?

17 [No response.]

18 MR. BELISLE: Thank you very much.

19 MR. CARROLL: Al, in terms of the sequence of what
20 comes up in our remaining time, if we can't get to both of
21 them is one or the other a better one to pick in terms of
22 people being from out of town or something like that, that
23 couldn't conveniently come back next month?

24 MR. CHAFFEE: I would suspect that you would want
25 to probably hear about the other Brunswick event.

1 MR. CARROLL: All right.

2 MR. SIEGEL: Why don't we have Rudy Karsch go
3 ahead and take us through that. I think you will find that
4 one of interest.

5 MR. KARSCH: Good morning, gentlemen. I am Rudy
6 Karsch, in the Events Assessment Staff in NRR.

7 [Slide]

8 There are a lot of interesting aspects to this
9 event. What you might not be familiar with are some of the
10 human factors aspects. If I could digress for just a
11 moment, I would like to go through those. We have
12 identified those as one of the key areas in the problem are
13 of this event.

14 The safety significance that we identified as the
15 loss of offsite power challenges the emergency power
16 systems. Emergency diesels are not one of the highest
17 reliability items in a nuclear plant. We tried to avoid
18 challenges to that system or reliance on emergency diesels
19 for a long period of time.

20 Unit 2 was initially operating at 100 percent
21 power when a ground fault alarm was received in the control
22 room. Typically plants operate with a neutral grounding
23 system on their transformer so that they can detect ground
24 faults either in the switchyard or in the distribution
25 network. In a three phase system you can tolerate one

1 ground, but a second ground will cause high circulating
2 currents that could damage transformers. Typically at a
3 certain point the transformer will lock out and be isolated
4 from the switchyard and from the distribution grid to
5 protect the transformer because they are high cost items.

6 The crew in the control room received the ground
7 fault, they notified the Carolina Power and Light relay crew
8 man who is not necessarily associated with the nuclear site.
9 They travel from site to site within the utility's
10 distributio: system. This man was alerted to the ground
11 fault, and was called in to trouble shoot. June 17th was a
12 Saturday. This was toward the end of their shift, and he
13 was probably contemplating going home when he was called in
14 and put on overtime to do the trouble shooting.

15 At the time they called the relay crew man in, the
16 plant manager was called at home and advised of the problem
17 in the switchyard. The plant manager felt that in case
18 there was a transformer lock out, he wanted the operators to
19 reduce power in the reactor by driving rods in. The reason
20 he wanted them to do that was, if rods are inserted into the
21 -- for a GE plant they come in from the bottom -- this tends
22 to minimize the possibility of core instability, core
23 oscillations if you have a recirc pump trip. So, he was
24 sensitive to the fact that if they had a transformer lock
25 out, the way their line up of the recirc pumps was on their

1 buses, they would get a recirc pump trip and it could throw
2 them into core oscillation. He wanted to avoid that if
3 possible.

4 Here is one of the first instances of the human
5 factors error. The operators didn't understand where he was
6 coming from in asking them to reduce power. Instead of
7 reducing power by driving rods in, they reduced power by
8 running back recirc pump flow which really doesn't do
9 anything for you. They were still at 100 percent rod line.

10 The relay crew man was in a hurry to get through
11 the trouble shooting of the ground fault indication, and he
12 strongly suspected that it was a problem in the indicating
13 system logic and not an actual ground fault. He wanted to
14 eliminate that possibility first off. He called into the
15 operators and said I want to put a jumper across the neutral
16 grounding transformer, thinking in his mind that they had a
17 current transformer. All the non-nuclear sites on CP&L's
18 grid use current transformers for neutral grounding whereas,
19 the nuclear sites use potential transformers for neutral
20 grounding. The operator gave him permission to do that,
21 picturing this is a jumper. In their experience when people
22 come in to trouble shoot INC. This is the kind of wire that
23 they use. When in actual fact, picture a set of battery
24 jumper cables, something with number six wire. That is what
25 he was going to jumper this transformer with. He got up on

1 a ladder with his hot stick, attached the jumper to the
2 transformer bushing and the other side was connected to
3 ground, the thinking being that if it's a current
4 transformer and you short across the winding of the current
5 transformer if the light stays on saying you have a ground
6 fault it's a problem in the indicating system, a stuck relay
7 or something like that and not an actual fault.

8 What he did when he installed that ground -- this
9 gave a second ground to the system because they had a
10 legitimate ground in their bus from the transformer to the
11 switchyard, got the high circulating currents -- probably
12 maybe an instantaneous current of 100,000 amps and
13 immediately vaporized this large piece of wire, blew the guy
14 off the ladder. Fortunately, it didn't kill him, although
15 afterwards he might have wished he was dead.

16 It gave him the second short and immediately
17 locked out the transformer to protect the transformer and
18 the recirc pumps tripped. Let me catch up with this slide
19 here.

20 [Slide.]

21 MR. CARROLL: The start up transformer is
22 receiving power from offsite and running and energizing the
23 bus that the recirc pumps are on?

24 MR. KARSCH: Right.

25 MR. CARROLL: They don't use an auxiliary

1 transformer which --

2 MR. KARSCH: You mean like a reserve transformer
3 or something like that?

4 MR. CARROLL: Yes.

5 MR. KARSCH: No, this site does not have that.

6 MR. CARROLL: You don't have a picture of the
7 electrical arrangement with you?

8 MR. KARSCH: We brought one, if you wanted to get
9 into that aspect of it.

10 MR. CHAFFEE: They do have an aux transformer, and
11 they do have the capability to power the recirc pumps to the
12 aux transformer, but this licensee has chosen to power
13 theirs through the start up transformers, as I understand
14 it.

15 MR. CARROLL: Do you know why?

16 MR. KARSCH: They call it the unit transformer.
17 They have a unit transformer and a start up transformer.
18 Yes, we do know why. Let me just describe the bus set up
19 real quick, and then I will get into why they had it set up
20 on June 17th the way that they did.

21 MR. CARROLL: Okay.

22 MR. KARSCH: The unit transformer is driven off of
23 the turbine generator. They have a breaker and a bus and
24 start up transformer. Then they have the step up
25 transformer that goes out to the switchyard off that same

1 isophase bus. The recirc pumps are powered off the start
2 up transformer, the breaker from that unit transformer to
3 close on that bus is open.

4 The reason they do this -- early in the life of
5 the plant they had a lot of trips of their generator or of
6 actually their reactor which caused a generator trip. When
7 the recirc pumps were powered off the unit transformer
8 which, at that time, was their preferred line up, every time
9 they get a reactor trip they lose the recirc pump seals
10 because of the design of the seals and the way the seals are
11 wetted and lubricated.

12 Their feeling was we are not getting a lot of
13 reliability and we are spending a lot of money on seal
14 packages, let's administratively tie the recirc pumps to the
15 start up transformer which is offsite power which should be
16 more reliable. So they operated for many years that way,
17 with the breaker from the unit transformer open and the
18 breaker from the start up transformer closed, recirc pumps
19 both powered off that same bus so they cannot split them in
20 power one off the unit transformer and one off the start up
21 transformer.

22 Through another series of breakers and busing and
23 so forth, they also power their emergency buses that way as
24 well.

25 MR. CHAFFEE: Let me point out one more thing.

1 Also, unfortunately, once they got into that configuration
2 when they recognized they were going to have problems with
3 this -- might have problems with the transformer, they
4 couldn't change the configuration. The way their electrical
5 system is designed they have a break before make arrangement
6 for the bus in question and it did not allow them then to
7 shift the recirc pumps to the unit transformer in
8 anticipation of possibly have a problem. That is why they
9 had to stay in that configuration they were in, into what
10 happened in the event.

11 MR. CARROLL: That's an unusual design.

12 MR. KARSCH: They cannot make a fast transfer. It
13 would have forced them to trip the recirc pumps, and they
14 would have gotten into the bind of having to scram the
15 reactor if they wanted to realign them to the unit
16 transformer in anticipation of the start up transformer
17 being tripped out.

18 Let me revisit the human error for just a minute.
19 I have discussed all three of them, and let me go through
20 the score card. The first one was the operator's not
21 understanding the rationale for reducing power. They didn't
22 drive the rods in. The second one was what is a jumper. If
23 the control room operators had understood that it wasn't
24 this kind of jumper but something that would carry a lot of
25 current, I think they would have questioned the man more,

1 what do you intend to do by installing this piece of number
2 six cable across the transformer. That might have triggered
3 in their mind that there was some kind of an unusual trouble
4 shooting scheme going on here.

5 The third human error was the lack of
6 understanding of the relay crew man that nuclear units are
7 different than fossil units, in that they have potential
8 transformer neutral grounding versus current transformer
9 neutral grounding. Out front we had all these cognitive or
10 communication human errors.

11 MR. WARD: Would this trouble shooting with the
12 jumper cable have been appropriate for the other type of
13 transformer?

14 MR. KARSCH: For a current transformer it would
15 have been fine because a current transformer is a low
16 resistance to ground. Potential transformer is a high
17 resistance to ground. Jumpering across the primary of that
18 transformer gave you in effect, a dead short to ground and
19 you got very high circulating currents.

20 MR. WARD: I mean the procedure this trouble
21 shooter was following would have been appropriate for the
22 different type of transformer?

23 MR. KARSCH: That's correct.

24 MR. CARROLL: These relay guys are not part of the
25 plant organization.

1 MR. KARSCH: Right. They are not part of the
2 operations department of the plant. They are separate and -

3 -
4 MR. CARROLL: I know the situation. I guess in my
5 experience usually something like this is going on, and the
6 plant electrical group would work with these outsiders, if
7 you will, and make sure they knew what this guy was doing.
8 That wasn't the case here?

9 MR. KARSCH: Apparently that wasn't the case, and
10 I don't know who is on site on a Saturday at 3:30 or 4:00
11 o'clock and who gets to go home. What I do know is that the
12 plant --

13 MR. LEVIS: Excuse me for a second. There were
14 people from the plant staff out there with the relay group.
15 The tech support people were out there, and concurred in
16 what the technician did.

17 MR. CARROLL: They did?

18 MR. LEVIS: Yes.

19 MR. WILKINS: I heard a slight difference between
20 what Jay said and what you said. You referred to the
21 electrical crew and you just said tech support. Were there,
22 in fact, people from the plant with electrical knowledge.

23 MR. LEVIS: The people from the technical support
24 organization were electrical people.

25 MR. KARSCH: This is an interesting turn of

1 affairs then. It wasn't just the relay crew guy that made
2 the human error, it was actually plant people as well. That
3 is something that I didn't know. Thank you very much.

4 At this point they are sitting there with 100
5 percent rod line, two recirc pumps are tripped, we have
6 issued guidance to licensees since the LaSalle event, a
7 bulletin called 38-07 and a supplement to that, Supplement 1
8 that says if you get a recirc pump trip you have to punch
9 the plant out. We do not want to get into core
10 oscillations. We have looked at a lot of events that show
11 that core oscillations can build very quickly, you can get
12 very large power swings, and there are a lot of different
13 mechanisms involved.

14 We don't fully understand all of them, but we do
15 know that we don't see that because you can get very high
16 heat generation rates in very small areas of the core. They
17 were then --

18 MR. CARROLL: Just out of curiosity, I have never
19 heard the term punch the plant out. I have heard red handle
20 it, scram it, all kinds of things. Where did you pick that
21 terminology up?

22 MR. KARSCH: I really don't know.

23 MR. WILKINS: I think it's pretty commonly used.
24 It's meaning is crystal clear.

25 MR. CARROLL: Oh yes, absolutely.

1 [Laughter.]

2 MR. CARROLL: I am just used to red handle it.

3 MR. KARSCH: Anyway, they scrammed the plant and
4 got a normal scram, all the rods fully inserted. They were
5 operating at this time under the NRC bulletin 88-07
6 Supplement 1, which requires that. Their procedures
7 reflected that bulletin. Just about the time they scrammed
8 the plant the plant operations manager arrived in the
9 parking lot.

10 MR. CARROLL: What did you guys do to me?

11 [Laughter.]

12 MR. KARSCH: Actually, his intention was that if
13 the plant had a problem and they had inserted rods
14 sufficiently to get below an 80 percent rod line, they were
15 going to try to keep the plant operating under a 50.54 X
16 exception that would be their discretion. The reason they
17 wanted to do that is, they did not want to trip the plant
18 and take what ensued in this case a nine hour loss of
19 offsite power.

20 Their feeling was that if they got below an 80
21 percent rod line that they were in an operating area where
22 the chances of core oscillations were extremely remote, and
23 they felt technically justified in taking exception to their
24 procedure and exception to bulletin 88-07 Supplement 1 and
25 keeping the plant running rather than taking the loss of

1 offsite power and relying on their diesels.

2 That whole course of operations was precluded by
3 the fact that they got the scram and they weren't at a lower
4 power rod line.

5 [Slide.]

6 At this point, recirc pumps tripped, you got a
7 loss of offsite power -- at this point, their start up
8 transformers locked out, their generator isn't running. So,
9 the only way they have to power their emergency buses is
10 their on site diesels. At this plant, when they have a loss
11 of off site power, they have four diesels at two units. All
12 four diesels start and loads are shared between all four
13 diesels.

14 What they have to do at this point to recover
15 offsite power is, they have to physically open up the
16 isophase bus, unlink the generator from the isophase bus,
17 and then they can power back from the switchyard through
18 their unit transformer. Because of the tag outs --

19 MR. CARROLL: They don't have motor operated
20 disconnects?

21 MR. KARSCH: They do not. It is manual disconnect
22 that they physically have to unbolt. Several plants have
23 these. Millstone I is another example where they take a
24 long time to restore offsite power. In fact, I think
25 probably as many plants do not have disconnects as do.

1 It took them seven hours to go through all the
2 clearances and tagging and the mechanical procedure of
3 unlinking the generator from the isophase bus. It took them
4 another two hours to figure out how to shut their emergency
5 diesels off because they have a relay that doesn't allow the
6 emergency diesels to be unlinked from the emergency bus
7 until it sees power coming in. It took them a while to
8 figure out that they had to reset the logic for that relay,
9 so it took them seven hours to do the unlinking and another
10 two hours to figure that out.

11 After nine hours, they finally restored offsite
12 power.

13 MR. WILKINS: During all that time the emergency
14 generators worked fine.

15 MR. KARSCH: They worked fine, with no problem.

16 MR. MICHELSON: I think though, something I didn't
17 fully appreciate is that there are a number of plants in
18 which if you experience a loss of offsite power or a
19 disturbance that might lead to that disconnect, that it
20 takes maybe as much as eight or nine hours to reconnect even
21 though the offsite power is into the yard.

22 MR. KARSCH: That's correct.

23 MR. MICHELSON: I wonder, did we think about that
24 when we looked at the power blackout situations and so
25 forth; did we realize that it takes that long?

1 MR. ROSSI: I think there are number of events
2 where this has been the case, as I recall.

3 MR. MICHELSON: There are just a lot of things
4 that escape me. This one escaped me, because I was thinking
5 of plants where they do have the capability of coming back
6 much quicker. I just thought everybody had that capability.

7 MR. CATTON: Is this built into the PRA's?

8 MR. KERR: What does the third bullet mean? The
9 third bullet seems to indicate that you can get some offsite
10 power if you go through Unit 1.

11 MR. KARSCH: Let me explain this. I asked them, do
12 they have -- I didn't want to put up a diagram of their on
13 site distribution because I think it would just be more
14 confusing than what it would clarify.

15 MR. KERR: I certainly agree.

16 MR. KARSCH: They have breakers installed where
17 they can link emergency buses together and they can link
18 other buses together. Administratively, they do not use
19 these breakers. They have a complete separation of the
20 buses at the various units, but they are there, they are
21 installed and they are racked out.

22 When they went through their station blackout
23 analysis and the various Appendix R analyses they developed
24 emergency procedures where, in extreme circumstances, they
25 could crosstie some of the buses between Unit 1 and Unit 2.

1 That is what I refer to in this bullet. I asked them,
2 could you power Unit 2 loads from the Unit 1 start up
3 transformer if you got into some kind of an extreme
4 situation where the only thing that stood between you and
5 core damage was loading that transformer.

6 The Brunswick people don't like to think about
7 that situation because they never really analyzed what the
8 loading on that transformer would be. They said that if it
9 ever got to that where they had maybe three emergency
10 diesels fail and the only thing that stood between them and
11 real serious problems was using that transformer, they said
12 they would figure out really fast some way to strip loads
13 and connect that transformer. They do not have a procedure
14 for that.

15 MR. CARROLL: It's not big enough to support --

16 MR. KARSCH: It's not big enough to support both
17 unit ECCS loads. As far as the emergency procedures that
18 they do have in place, I asked them how long would it take
19 you to go through that procedure if you had to. They said
20 it would take one-half an hour to 45 minutes. Although nine
21 hours sounds bad, they had some cards up their sleeve that
22 they could have played if they had to.

23 MR. CARROLL: Nine hours doesn't sound bad to me.
24 I don't know why they put so many God damn bolts in those
25 disconnects, but they do.

1 MR. KARSCH: I think a lot of it is tagging out to
2 make sure someone doesn't get electrocuted too.

3 MR. CARROLL: Although they must have had some
4 clearance all written up for that. I guess the other thing
5 this reflects to me is that the business the way the
6 operators responded to the plant manager. It doesn't sound
7 like they fully understand the augmented training they have
8 recently received on the matter of forbidden areas on the
9 power flow curve and all that good stuff.

10 MR. KARSCH: I think they have a lot more
11 understanding now than they did on the 17th of June. In
12 addition since this event occurred, Brunswick has installed
13 a better seal package in their recirc pumps and have gone
14 back to powering the recirc pumps off the unit transformer.

15 MR. CARROLL: That's a very good idea.

16 MR. KARSCH: Are there any further questions?

17 MR. WARD: Brunswick has, as I recall, these kind
18 of elaborate flow chart emergency operating procedures. Are
19 you familiar with those?

20 MR. KARSCH: I am afraid not. I really can't
21 speak to that.

22 MR. CARROLL: Rev 4.

23 MR. KARSCH: Does anyone on the staff --

24 MR. CARROLL: Rev 4 EOP's.

25 MR. WARD: Did they come into play here?

1 MR. LEVIS: The only way the EOP's would have come
2 into play is in initial scram. If they had looked for
3 various injury conditions there wouldn't have been any in
4 this case. Had they not been able to power up their 4KV
5 buses with the diesel loss, they would have been into --

6 MR. CHAFFEE: We also have some other people here
7 from Region II. I don't know if they have anything they
8 would like to add or not.

9 [No response.]

10 MR. CHAFFEE: It doesn't sound like we have enough
11 time to go on with the next event. Since we don't, let me
12 point out one thing. Another thing that was of some
13 interest on this particular event, as I understand it, was
14 when they finally did get the disconnect links and were
15 ready to bring power on back to the main transformer, I
16 understood there was some interlock or something that they
17 made an oversight on, and that's what resulted in the
18 additional two hours before they were finally able to secure
19 the diesels. The point being, it was interesting that even
20 after doing all this one would have hoped that this had been
21 very carefully rehearsed and understood. Apparently they
22 did have some trouble even doing the activity.

23 MR. KERR: That just points out that it's a good
24 idea to have an incident like this occasionally to --

25 MR. CATTON: Sharpen up the troops.

1 MR. CARROLL: If I remember right, you did put an
2 information notice out on this one.

3 MR. ROSSI: I don't remember whether we did or did
4 not.

5 MR. CARROLL: It sounds familiar to me, but I read
6 so much --

7 MR. ROSSI: I would be a little surprised if we
8 did. I just don't remember.

9 MR. CARROLL: How does the rest of the industry
10 hear about something like this? I mean, there are some
11 lessons here?

12 MR. ROSSI: I don't know. It depends on whether
13 we thought the lessons were important enough and generic
14 enough and all of that to go with a notice.

15 MR. CARROLL: Or whether INPO thought they were.

16 MR. ROSSI: INPO may have put something out.

17 MR. KERR: Did you ever read Jean Kerr's book
18 called Please Don't Eat the Daisies?

19 MR. CARROLL: Yes, I did.

20 MR. KERR: I am not sure one should publicize this
21 sort of thing. Somebody else will come along and put a
22 jumper across a transformer sure as shoot.

23 MR. CARROLL: It is not the first time it has ever
24 happened in a power plant, I know that.

25 MR. MICHELSON: I would like to get a

1 clarification here. There was a procedure, pre-determined
2 procedure on how to get these disconnects made and so forth?

3 MR. KARSCH: Yes, that's correct.

4 MR. MICHELSON: Apparently --

5 MR. KARSCH: That is covered by procedure.

6 Generally they have the tagging made up ahead of time, as
7 you were pointing out.

8 MR. MICHELSON: Why was there a --

9 MR. KARSCH: There still is a lengthy --

10 MR. MICHELSON: -- problem then with overlooking a
11 relay? Was it because the procedure had overlooked it?

12 MR. KARSCH: That was not covered by this
13 particular procedure.

14 MR. CARROLL: The relay had to do with the fact
15 that the diesels were running.

16 MR. MICHELSON: Isn't that a part of a procedure
17 to understand what all is happening at the time you try to
18 implement a procedure?

19 MR. CARROLL: I think that the procedure is for
20 the very normal operation of opening up the disconnect or in
21 outages so that you can --

22 MR. MICHELSON: It wasn't envisioned to ever be
23 carried out during a time when diesels were running; is that
24 what you are saying?

25 MR. CARROLL: Yes.

1 MR. LEVIS: That's correct. The procedure was
2 made up for outage purposes.

3 MR. MICHELSON: Only, okay. It has been revised I
4 suppose, to cover diesel operation as well?

5 MR. LEVIS: Yes, sir, it has.

6 MR. CARROLL: As resident inspector down there, do
7 you feel they would handle this same event better next time
8 around?

9 MR. LEVIS: As a resident inspector, I hope there
10 is no next time around. I am confident that in this
11 particular event, they would handle it better, yes.

12 MR. KARSCH: We feel at this point, with the
13 recirc pumps powered at the unit transformer they probably
14 wouldn't even get into this box.

15 MR. CARROLL: That's correct.

16 MR. KERR: One puzzling thing to me is that the
17 operators apparently did not follow the instructions of the
18 plant manager.

19 MR. KARSCH: I don't think they understood the
20 instructions.

21 MR. KERR: Whether they understood them or not, if
22 they didn't understand them it seems to me they would have
23 gone back and said we don't want to do what you told us to
24 do. You indicated that he told them to insert rods.

25 MR. KARSCH: He told them to reduce power,

1 assuming that they would understand the reason why and take
2 the appropriate action.

3 MR. KERR: Your transparency said that he told
4 them to insert rods, and that puzzled me. I just thought
5 that you said that --

6 MR. KARSCH: The bullet says advise the operator
7 to reduce power in case there was a transformer lock out.
8 His intent was to have them drive rods in.

9 MR. WARD: If you had been the operator you would
10 have done the right thing.

11 MR. KERR: No, not if you told me to reduce power
12 I would have --

13 MR. WARD: With all you know about PWR's
14 stability, you wouldn't have done the right thing, Bill?

15 MR. WARD: He said he would.

16 MR. KERR: I would not trust me to operate a
17 reactor.

18 MR. WILKINS: Miscommunication is one of your
19 great human errors.

20 MR. KARSCH: That was the first of three.

21 MR. CARROLL: Are you a human error specialist; do
22 you have that kind of training?

23 MR. KARSCH: No. My area of expertise is
24 instrumentation and control systems. I had the benefit of
25 an excellent briefing put on by Carolina Power and Light

1 about a year and one-half ago for Dr. Murley where they got
2 into the human factors aspects of this very heavily. Like
3 most events, there is always a human factors aspect.

4 MR. CARROLL: Anything involving humans --

5 MR. KARSCH: It is very difficult for us to get
6 our arms around that and see what we can do to reduce the
7 human factors problems. We can handle a lot of the
8 mechanical problems, but how do you improve a human being in
9 their performance.

10 MR. KERR: One lesson here is that you just aren't
11 going to eliminate human errors. If you don't make these
12 systems fault tolerant you are going to have trouble.

13 MR. KARSCH: I think that's our main thrust.

14 MR. MICHELSON: As a instrumentation and control
15 expert, do you feel you are well qualified on solid state
16 electronic control, of the variety particularly that we are
17 using on the next generation of reactors; or are you more
18 the traditional instrumentation control of the past?

19 MR. KARSCH: I am pretty knowledgeable of that
20 state-of-the-art.

21 MR. MICHELSON: You would be somebody I might chat
22 with when I want to ask some questions about problems of
23 solid state electronic control?

24 MR. KARSCH: Feel free.

25 MR. MICHELSON: Is your phone number on your

1 handout, like we always ask?

2 MR. KARSCH: It's 492-1178. I might add though, I
3 do not work in the instrumentation and control systems
4 branch.

5 MR. MICHELSON: That wasn't what I asked either.
6 I asked if you were knowledgeable.

7 [Laughter.]

8 MR. CARROLL: It is on the cover sheet.

9 MR. MICHELSON: It is?

10 MR. CARROLL: Yes.

11 MR. MICHELSON: That's right, there are several
12 cover sheets here.

13 MR. CARROLL: These guys learn.

14 MR. WILKINS: I notice that they have a standard
15 cover sheet.

16 MR. MICHELSON: Yes. I was looking at the top of
17 the handout. That is my fault.

18 MR. KARSCH: I assume that we are going to
19 reschedule the Pilgrim event discussion, because that's also
20 an extremely interesting event.

21 MR. CARROLL: I guess we will have to, yes. We
22 are out of time this morning.

23 MR. KERR: Mr. Carroll, in connection with that,
24 there is a November 19th memo to you from Boehnert which
25 includes some event in Quad Cities II. Have you seen that?

1 MR. ROSSI: Apparently we do have a number of
2 people from out of town on the Pilgrim event. I hadn't
3 realized that, and I know you asked us that question. I
4 don't know whether you want to reschedule it or --

5 MR. CARROLL: How long do you think it would take?

6 MR. MICHELSON: How long do you need?

7 MR. ROSSI: I don't know, can you go through it
8 rather quickly, Rudy?

9 MR. MICHELSON: Quickly has to be identified since
10 we have only one hour --

11 MR. WILKINS: You have future activities.
12 Couldn't that be pushed into --

13 MR. CARROLL: What was the event at Quad Cities?

14 MR. KERR: It had to do with an event in which the
15 operators were running a test and they got in trouble during
16 a test, and it sounds to me like a classic Chernobyl
17 precursor. I think it is very significant. I am curious as
18 to what had been done about it.

19 MR. ROSSI: Which event was it?

20 MR. KERR: It's an event that occurred on October
21 27, 1990, and it was during an attempt to perform a special
22 turbine test, turbine test to determine --

23 MR. ROSSI: Yes, that's --

24 MR. KERR: -- the reactor automatically scrambled
25 on high and it appears that the test had not been

1 sufficiently analyzed so that people knew what to expect in
2 an unusual test that was non-routine. This is precisely the
3 sort of thing that happened at Chernobyl.

4 MR. ROSSI: We will be happy to come and brief you
5 the next time on that.

6 MR. KERR: I am less interested in a briefing than
7 in getting word to people that if they are going to do
8 unusual tests and persuading them that they really need to
9 go through this in great detail -- I hope you are doing it.

10 MR. ROSSI: We are in the process, I guess, of
11 issuing an information notice on that one. I think that's
12 the one where AEOD had some human factors people go to the
13 site.

14 MR. CARROLL: That's right. That's what I
15 remember about it.

16 MR. ROSSI: It is getting a lot of attention, and
17 we will issue --

18 MR. CARROLL: They must have, like you, concluded
19 it was like Chernobyl.

20 MR. KERR: It is the nearest thing to Chernobyl I
21 have seen in our own experience.

22 MR. CARROLL: I remember.

23 MR. CHAFFEE: Also there are some generic
24 communications on this.

25 MR. CARROLL: Pilgrim.

1 [Slide.]

2 MR. KARSCH: This event occurred September 2nd of
3 this year. Feedwater control was lost, and the cost was
4 failure in the feedwater control system caused the operators
5 to lose control of both feedwater regulating valves. The
6 reason was maintenance oversights, and a defective
7 procedure. The defective procedure caused RCIC to be
8 rendered inoperable. We characterize this is a reactor
9 scram with complications.

10 I am going to try to run through this really fast
11 so that there will be a little time for questions, because I
12 think you will have some questions.

13 The reactor was 100 percent power. The operators
14 got a high level alarm and it took them about 20 minutes to
15 one-half hour of going through various manipulations of the
16 feed system when they finally realized that they did not
17 have any control of the feedwater. They had just basically
18 lost feedwater regulation in both automatic and manual.

19 At that point they tripped the plant and started
20 going through various recovery procedures. They did not
21 reach level two, so they did not get an automatic start of
22 RCIC, but in anticipation of level going down they manually
23 started RCIC, and because of this procedural flaw they
24 rendered RCIC inoperable.

25 They tried to start up this motor driven start up

1 feed pump and run through the start up feed regulating
2 valves and had a failure in the start up feed regulating
3 valve that also closed over feed to the vessel. They went
4 through more unusual line up of the feed system to try and
5 feed through a valve that they could throttle. At some
6 point during the event they started HPCI and they saw flow
7 oscillations in the output of HPCI when it was in the
8 automatic mode. They secured HPCI during the course of
9 realigning HPCI to a manual control mode. They managed to
10 get feed into the vessel through a heater string block
11 valve, and they were able to throttle that valve. They were
12 also able to cycle pumps and control vessel level that way.

13 At that point they restarted HPCI and ran in a
14 full flow test mode, and driving an HPCI turbine gave them a
15 way to relieve pressure from the vessel. Prior to that,
16 they were relieving pressure through the safety relief
17 valves. At some point in the event -- and I don't want to
18 get into a big long time line on this event -- the MSIV
19 closed and they reset the MSIV's and began to depressurize
20 normally using the condenser as a heat sink.

21 [Slide.]

22 The MSIV closure was reset and they reopened the
23 MSIV's, and at that point they were able to depressurize
24 normally using the main condenser. The vessel pressure had
25 decreased to the point where they could use condensate pumps

1 and, later on when they didn't require as much feed flow,
2 they were able to use rod drive pumps and RWCU pumps. When
3 they tried to align the RHR system they had a pressure spike
4 in the suction that caused them initially to isolate RHR.
5 It took them about 40 minutes or so to vent the RHR system
6 suction side so that they could reopen and realign RHR.

7 MR. CARROLL: What caused the pressure spike?

8 MR. KARSCH: Inadequate venting in the RHR suction
9 line. They have had a history of this on their A-train
10 because of the pipe configuration.

11 MR. CARROLL: So, when I am trying to open the RHR
12 valves --

13 MR. KARSCH: Three times out of four in the last
14 one-half or three-quarters of a year they have had a suction
15 isolation because of a pressure spike.

16 MR. CARROLL: What is causing the pressure spike?

17 MR. KARSCH: The insurge of water into the gas
18 space in that pipe.

19 MR. MICHELSON: Why is there a gas space in the
20 pipe?

21 MR. KARSCH: I am not sure.

22 MR. MICHELSON: I thought that was a fully filled
23 pipe at all times, unless air is accumulating in it somehow.

24 MR. MACDONALD: Excuse me, Rudy, I can help you.

25 John MacDonald, senior resident inspector at Pilgrim. It is

1 actually a voided area in a pipe, it's not a gas area.
2 There is a belief that when the shutdown cooling subsection
3 of KHR is in standby that, due to convectional heat transfer
4 from the RCS system temperature across the valves, a certain
5 amount of the shutdown cooling system inventory boils and
6 actually steams free from the venting causing a voided
7 section of pipe.

8 When the shutdown cooling system suction isolation
9 valve opens, some of the RCS fills that voided area and
10 causes the pressure spike. The pressure spike actually
11 occurs in the recirc loops, not in the suction shutdown
12 cooling system suction line.

13 MR. CATTON: That's water hammer.

14 MR. MACDONALD: Very minor water hammer.

15 MR. CATTON: That depends on how big the steam
16 bubble is.

17 MR. MACDONALD: That's correct.

18 MR. KARSCH: We tended to call it a water hammer.
19 The licensee preferred to call it a pressure transient.

20 MR. CATTON: A steam bubble, that's a water
21 hammer.

22 MR. KARSCH: I think we might be playing games
23 with semantics here. The bottom line is that there were
24 people in the room that didn't hear anything. They didn't
25 see any pipe movement, and when they walked down the system

1 they didn't see any damage to pipe or anything like that.

2 MR. CARROLL: To simply spike a pressure sensor
3 doesn't take --

4 MR. MICHELSON: It doesn't take much, no.

5 MR. KARSCH: Let me get to the last bullet here,
6 because I think this is also very interesting. Subsequent
7 to the event they determined that they had an overpressure -
8 - a pressurization of the RCIC suction piping in excess of
9 the design rating of that pipe. In other words, they opened
10 the safety valve and calculating the peak pressure that was
11 reached, it was somewhere between 600 and 800 psi.

12 This pressure came from the reactor water clean up
13 system pressure. The reason why that happened is, they have
14 a check valve on the discharge of the RCIC pump which did
15 not --it allowed backflow through that check valve, through
16 the idle pump and into the suction line. The duration of
17 this pressurization was about 50 seconds.

18 MR. MICHELSON: But the RCIC feeds back to the
19 feedwater line, doesn't it?

20 MR. KARSCH: Yes.

21 MR. MICHELSON: What does reactor water clean up
22 have to do with that?

23 MR. KARSCH: That also feeds into the same section
24 of the feedwater pipe.

25 MR. MICHELSON: At the same point?

1 MR. KARSCH: Virtually the same point. Maybe John
2 can speak to that. I think there's a header that goes in
3 and all of these lines come into that header.

4 MR. MICHELSON: I see.

5 MR. MACDONALD: That's correct.

6 MR. ROSSI: I think that since we have people from
7 Region I here including the senior resident, if they have
8 any additional perspectives or corrections or augmentations
9 to the description you might --

10 MR. KARSCH: I did run through this very quickly
11 because we are pressed for time. John, you might have
12 something to add that I have skimmed over because of the
13 speed that I went through this.

14 MR. MACDONALD: The description was basically
15 accurate, but was brief. Essentially, the event was very
16 well handled by the operators that were on shift. They were
17 presented with several system malfunctions and component
18 failures, and they handled the event quite well. If you
19 have any questions on the bullets, I would be glad to
20 address them.

21 MR. CARROLL: Overall what is your perspective on
22 how Pilgrim is doing since they restarted?

23 MR. MACDONALD: This is my opinion.

24 MR. CARROLL: That's what I asked for.

25 MR. MACDONALD: That's correct. I believe Pilgrim

1 continues to improve. Their past problems throughout the
2 plant continue to cause perturbation in that improvement
3 process. This is an example of it. However, their ability
4 to recover from these events is greatly improved.
5 Management is well focused on being capable of identifying
6 the root cause of the problems, correcting them, and
7 ensuring any programmatic implications are addressed which
8 is good, in my mind.

9 MR. CARROLL: They have always had very good
10 operators there, haven't they?

11 MR. MACDONALD: Previously they had a major
12 problem with the staffing level of operators. Recently, in
13 the past two years, they have had 100 percent pass rate on
14 all NRC administered exams.

15 MR. KARSCH: Are there any more questions?

16 MR. CARROLL: I don't believe so. We would like
17 to thank you again for a good series of presentations. I
18 think there was a lot of food for thought here. I guess of
19 these events we would like to, the next time you are in, get
20 a follow up on what has gone on in the hydrogen gas issue.
21 That one concerns me.

22 MR. ROSSI: Let me just thank real quickly the
23 people from the Region that came to the meeting, because
24 they do travel a long way and give a perspective I think
25 from being closer to the problems that would be missing

1 without them. So, I would like to thank them.

2 MR. MICHELSON: Perhaps one of the things that we
3 are going to have to be careful of is fewer events. You
4 never know how long they are going to take.

5 MR. CARROLL: We only went over 13 minutes Carl,
6 that ain't bad.

7 MR. MICHELSON: No, but we really gave the last
8 one a rater short shift.

9 MR. CARROLL: That was all attributable to the
10 first one, yes.

11 MR. WARD: I think it's really Jay's fault for
12 selecting events that are so interesting.

13 MR. MICHELSON: That's right.

14 MR. CATTON: The first two were really very
15 interesting.

16 MR. MICHELSON: Yes, and they are significant.
17 Are you finished then, Jay?

18 MR. CARROLL: Yes.

19 MR. MICHELSON: We need to get on to our next
20 agenda item, which is the future activities. There are
21 several things that we need to talk about during that time,
22 so I will let Richard get started.

23 [Whereupon, at 12:30 a.m., the transcribed portion
24 of the meeting was recessed, to reconvene at 1:00 p.m., this
25 same day.]

AFTERNOON SESSION

[1:05 p.m.]

1
2
3 MR. MICHELSON: The next item on our agenda this
4 afternoon is new standardized technical specifications.
5 This is a briefing by the staff. I believe Jay Carroll will
6 conduct it.

7 MR. CARROLL: We have been generally following
8 different efforts with the staff in the general area of tech
9 specs. We had a briefing a while back on risk-based tech
10 spec work. Today we are going to be hearing about the new
11 standard tech specs. Jose, do you want to lead off?

12 MR. CALVO: Yes. I am just going to introduce the
13 speaker. My name is Jose Calvo, I am the chief of the
14 Technical Specifications Branch. Here with me are the
15 members of my staff and my boss, Ernie Rossi, Dr. Rossi,
16 Director of the Division of Operational Events Assessment.

17 Without going further, I think I am going to give
18 the floor to Mark Reinhart, who is going to give you the
19 presentation.

20 MR. CARROLL: You didn't have to introduce him to
21 me.

22 MR. CALVO: I know he was here this morning.

23 MR. CARROLL: I hired him right out of the Navy.

24 MR. CALVO: You did, all right. Be nice to him.

25 [Laughter.]

1 MR. REINHART: My name is Mark Reinhart, with the
2 Technical Specifications Branch. The ACRS has shown
3 interest in the technical specification improvement program
4 and the new standard technical specifications, so as we
5 approach issuing our final draft we wanted to come and brief
6 the ACRS on our progress and where we are headed. When we
7 issue the draft for comment to industry, the staff will also
8 provide it to ACRS for information.

9 MR. CARROLL: While Mark is getting started, there
10 is some additional background information in your Tab A to
11 the black binds.

12 [Slide.]

13 MR. REINHART: This is about the third slide in on
14 the package. It shows the background and our progress
15 today. In February, 1987, the Commission issued an interim
16 policy statement based on a lot of effort by industry and
17 the staff to improve technical specifications. Based on
18 that policy statement the industry proposed to the staff a
19 division of requirements that were in current standard
20 technical specifications, which requirements would stay in
21 the specs and which requirements would be relocated to
22 licensee control documents.

23 The staff discussed that with industry, and in May
24 of 1988 issued the short term titles, the Split report which
25 delineated which requirements went elsewhere and which

1 stayed in the technical specifications. Based on that split
2 report, from May of 1988 through the March and June
3 timeframe of 1989, the industry developed and proposed new
4 standard technical specifications, one for each Owners
5 Group, Boiling Water Reactors had two -- a BWR-4 and BWR-6
6 version.

7 The staff reviewed and discussed those proposals
8 with industry from April of 1989 through December of 1990,
9 where we are today. The staff is to the point where we are
10 getting ready to issue this final draft STS and their bases
11 by January back to industry and the staff for a final
12 review. Following that review we will start to work more
13 with the lead plants to implement the spec, and we
14 anticipate we will have some iteration to the specs during
15 that time and eventually issue them in spring of 1991.

16 [Slide.]

17 To show the extent of participation in this
18 program we put together a slide that tries to generally show
19 who all was involved. We have had we say 30 persons from
20 industry. Those would be the key ones, obviously backed up
21 by their staff. They represented NUMARC, the NSSS Owners
22 Group, lead plant licensees and another group of licensees
23 who were involved. To point out the lead plants we have
24 North Anna 1 and 2 for Westinghouse, Crystal River 3 for
25 Babcock and Wilcox, San Onofre 2 and 3 for Combustion

1 Engineering, Hatch 1, the BWR-4 and Grand Gulf with BWR-6.

2 Of course, they were all of them. Just to mention
3 a few, we had representations from plants such as Davis-
4 Besse, Diablo Canyon, Palisades, Rancho Seco, Waterford and
5 Watts Barr.

6 MR. CARROLL: On the BWR lead plants, would the
7 BWR-4 tech specs take care of earlier BWR's?

8 MR. REINHART: The BWR Group had an approach where
9 they would take those two and most likely the earlier ones
10 would go with BWR-4. The 5 would probably go with the 6, if
11 I have that right. As time developed and plants came in,
12 they would continue to add to the specs until they got a
13 comprehensive set that would cover all of their plants.

14 On the staff side, we had NRC people -- about 65 -
15 - representing the technical specifications branch.

16 Virtually every one of the NRR technical review branches
17 including Risk and Human Factors, we had the projects
18 divisions, the regions and the technical training center.
19 The technical training center took a set of specs proposed
20 by the Owners Groups and implemented it specifically in one
21 of the simulators and ran a class through on that set. They
22 gave us some really good comments on the value of the specs.
23 They appreciated them, the format, the bases, and the
24 improvements that they saw.

25 Supporting the NRC we had about 25 contractors

1 from National Labs, Lawrence Livermore, Idaho National
2 Engineering Lab, Pacific Northwest and had Science
3 Applications International also supporting. We think that
4 we can say that not since the inception of technical
5 specifications have so many people with such broad and
6 diverse backgrounds looked so deeply for such a period of
7 time at this document.

8 [Slide.]

9 Slide number six shows an outline --

10 MR. KERR: Could you then paraphrase Mr. Churchill
11 to say never have so few owed so much to so many?

12 [Laughter.]

13 MR. REINHART: Good parallel. Our genera' outline
14 here looks probably very similar to what current tech specs
15 are, but I want to point out that in the 1.0 section that up
16 until now has been mostly definitions, has been expanded to
17 clarify how the specs are used. We are addressing the
18 logical connectors, completion time, surveillance
19 frequencies and operability. Also, the 3.0 section,
20 applicability, has been improved to try to provide for the
21 operator a uniform guide in using the specifications.

22 The split was applied primarily to the 3.1 through
23 the 3.10 sections. Human factors principles were applied
24 throughout. One of the obvious ones right here, if you
25 remember the old 3-4 section which the industry commented

1 provided a lot of confusion not only for them but for
2 ourselves as well. We took those LCO's and surveillances
3 from the three and four and integrated them into one section
4 because they were together anyway. We will show in a minute
5 an example of what a new spec looks like compared to one of
6 the previous specs.

7 MR. CARROLL: I am curious about 3.10; what is
8 that all about?

9 MR. REINHART: Three point ten is a group of
10 special exceptions that licensees have requested to perform
11 various tests. If they are going to do some physics testing
12 they might need an exception to a particular LCO. The staff
13 approved those. The PWR's chose to integrate those specific
14 exceptions in with the particular spec and BWR's left it
15 separate.

16 [Slide.]

17 To highlight some of the changes, from the split
18 report about 40 percent of the requirements were located to
19 licensee control documents. The licensees will provide
20 controls on those relocated documents, and those controls
21 will be approved by the staff and audited prior to
22 implementation. The range of control will be to something
23 similar to 10 CFR 50.59 control all the way up to a prior
24 staff review and approval prior to making the change.

25 We want to point out that a lot of people had a

1 concern that the requirements are removed, and I want to
2 emphasize they are relocated. They are still there, they
3 are important, we will follow them, and we will enforce
4 them.

5 MR. WILKINS: May I interrupt you at that point?
6 Was it a part of the charge that you had in this project to
7 examine in fact whether they were important?

8 MR. REINHART: I think we say they are important.
9 We know they are important to begin with.

10 MR. WILKINS: Maybe they were important to begin
11 with and maybe they are no longer important.

12 MR. REINHART: That's a good question. The ones
13 that we relocated, the staff and industry to date hasn't
14 really delved into those. Most of our effort has been on
15 the document that is remaining. When we go to the lead
16 plant in the follow on plants as they implement those, they
17 will be showing us where they are located, where the
18 controls are and, at that time, those type of questions will
19 come to the surface.

20 MR. MICHELSON: I may have missed it and for that
21 I apologize, but have you discussed what you might be losing
22 out of the LER system now by taking and moving this over
23 into other areas where it isn't any longer clearly under
24 LER?

25 MR. REINHART: Licensee event report?

1 MR. MICHELSON: Yes.

2 MR. REINHART: We have discussed that, and there's
3 a lot of mechanisms for reporting to the staff other than
4 the LER system.

5 MR. MICHELSON: Yes, but the LER system is a very
6 clearly, well established mechanism to get general
7 information about the state of the industry and its
8 operation. There are other mechanisms but they are not
9 formal, there are not any requirements for them, and you
10 lose it if you --

11 MR. ROSSI: I think the only place that you will
12 lose in the area of the LER rule that says you have to
13 report violations of the tech specs. There will be some
14 things that are not violations of the tech specs anymore.
15 So now, we will be more dependent on the other sections of
16 the LER rule that tell you what kind of things you have to
17 submit LER's on, on the basis of their individual importance
18 to safety and --

19 MR. MICHELSON: You have looked at this carefully
20 and have concluded that you aren't going to lose anything
21 important; is that right?

22 MR. ROSSI: You will hit the other sections. We
23 also have some other efforts as part of our regulatory --

24 MR. MICHELSON: Excuse me.

25 MR. ROSSI: -- underway on the LER interpretation.

1 MR. MICHELSON: By sections you mean the other
2 triggering mechanisms for the LER?

3 MR. ROSSI: Right, for getting LER's, right.

4 MR. MICHELSON: You say that anything that we
5 really need to get we get that way?

6 MR. ROSSI: That would be my view, yes.

7 MR. MICHELSON: That may be right. I am asking it
8 because I don't have time to go back and look to see what
9 those triggers might be. You have looked at it and you have
10 satisfied yourself we are not losing any important
11 information?

12 MR. ROSSI: We have not looked at each item that
13 has been relocated in terms of whether we would --

14 MR. MICHELSON: I was thinking for instance of
15 fire protection. Now you have relocated, I think, most of
16 it into other areas. If I have a problem with a fire
17 protection system since the system is no longer in the tech
18 spec, what is the trigger to find out about that problem? I
19 didn't have a fire, of course, I just had a problem with the
20 system. I might have even inadvertently actuated the
21 system.

22 MR. ROSSI: If you inadvertently actuated it and
23 it gave you any kind of significant problem, I think that
24 would trigger one of the other LER things. I also assume
25 that in the tech specs there is a general fire protection

1 thing even though the details are --

2 MR. MICHELSON: You mean, still in there?

3 MR. CATTON: Isn't there a general --

4 MR. CALVO: If I may, the fire protection
5 requirements was not -- they had already been removed before
6 this program came into being.

7 MR. MICHELSON: Yes, but I thought --

8 MR. CALVO: If I remember correctly, the generic
9 letter established some reportability requirements and some
10 ground rules in there which may take care of some of those
11 things.

12 MR. MICHELSON: Which generic letter are you
13 referring to?

14 MR. CALVO: We can --

15 MR. REINHART: I have the number here, and I can
16 look it up real quick.

17 MR. MICHELSON: This is a fire protection generic
18 letter?

19 MR. REINHART: It's generic letter 88-12.

20 MR. CALVO: They call it the line item --

21 MR. MICHELSON: That's when the discussion came
22 about. It was about 1988 timeframe. That's when the
23 discussion first came up about are we losing most of the
24 information that we might have otherwise gotten on fire
25 protection devices. I guess you have looked at that and you

1 are satisfied that --

2 MR. ROSSI: We have not gone through line by line
3 of the things that we have removed to determine their effect
4 on what LER's that we would lose. The other triggering
5 mechanisms in the LER rule are things like unreviewed safety
6 problems beyond the design basis and those kinds of things,
7 and inadvertent actuations that would be an important effect
8 on safety related equipment are still going to trigger one
9 of those.

10 I feel very confident that we are going to get
11 everything that we need to get --

12 MR. MICHELSON: I will take your word for it.

13 MR. ROSSI: -- without going through line by line.

14 MR. MICHELSON: It was though, a conscious
15 decision to try to determine that you weren't losing
16 important information; is that right?

17 MR. ROSSI: I would not say that we looked at that
18 particular aspect.

19 MR. MICHELSON: Did you think that was not
20 important to consider?

21 MR. ROSSI: A systematic look at it?

22 MR. MICHELSON: Whatever look it takes to
23 determine that you aren't losing important information. We
24 have such a little amount of this information coming in
25 anyhow, at least in a form that is disseminated widely in

1 the industry go so forth such as the LER's are.

2 MR. ROSSI: Let us give some more thought to it.
3 We do have some other efforts on relooking at the LER rule
4 and 50.72 rules and the guidance on that.

5 MR. MICHELSON: There are some things that you can
6 certainly get rid of. I don't want to lose good things in
7 the process.

8 MR. ROSSI: We understand. I have a vested
9 interest in that myself because of the other part of my job.

10 MR. MICHELSON: Right.

11 MR. REINHART: In addition to applying the split
12 report, we mention here for a while these line item
13 improvements. Those are an item that, while approved,
14 parallel to the new STS. We have incorporated into the new
15 STS. We had an evaluation, and industry-wide evaluation of
16 surveillance testing and made some recommendations and
17 incorporated those into the new STS based on industry as
18 well as staff operating experience, to try to get more
19 realistic surveillance testing where possible.

20 MR. CARROLL: This isn't risk-based, it is
21 someone's judgment about --

22 MR. REINHART: Most of it is deterministic. The
23 risk -- most of this effort was deterministic. We had a
24 flavor of risk in certain areas that I will talk about on
25 this next bullet.

1 MR. ROSSI: Mark, this includes -- the new
2 standard tech specs include all the reports of the topical
3 reports that have been submitted by the industry that we
4 have approved.

5 MR. REINHART: That's true.

6 MR. ROSSI: Those, I think, have a lot more risk
7 and quantitative stuff than some of the other.

8 MR. CARROLL: Just to give me a feel, in a big
9 PWR, how much have you reduced surveillance testing?

10 MR. REINHART: I don't have a good feel for that.
11 Rich, do you have a feel for that?

12 MR. LOBEL: My name is Rich Lobel from the tech
13 spec branch. I can't give you a number off the top of my
14 head, but it was a significant amount. If you look at the
15 amount of testing that gets done, a lot of it was in the
16 order of monthly channel checks, channel tests, that
17 required all RPS instrumentation once a month. By means of
18 the topical reports a lot of that got changed to quarterly
19 or we gave the industry the opportunity to change it to
20 quarterly.

21 There were also these things that were taken out
22 of the tech specs that required surveillances too. A lot of
23 it was instrumentation and a lot of it was reduced by a
24 factor of three. As a rough number for instrumentation you
25 could say a factor of three.

1 MR. CARROLL: I guess in our background section
2 somebody is talking here about Limerick requiring 40
3 surveillance tests a day or over 14,800 tests per year.

4 MR. LOBEL: That's total number of tests. That's
5 the number that are done now, and that number includes every
6 test that is done of a circuit that is required by tech
7 specs, every check that is required by tech specs of a
8 configuration of valves in a system to make sure they are in
9 the right line up. A lot of these are monthly and a lot of
10 them are more often. It adds up to quite a big number.

11 MR. CARROLL: I guess the other thing that I was
12 curious about with respect to instrumentation calibration,
13 several of us recently visited San Onofre as part of our
14 adopted plant program and heard a presentation on their so-
15 called RIM program which I understand a number of other
16 people are playing with too. Is that getting a lot of
17 encouragement from the staff?

18 MR. LOBEL: Yes, it is. They have used some of
19 the data they are getting from that, I am sure that you
20 heard, for justification for extending their cycle from 18
21 to 24 months. They are showing with real data that it is
22 not necessary to do these surveillances as often as required
23 in their tech specs now.

24 MR. CARROLL: I guess we should tell the rest of
25 the Committee that wasn't there was RIMS is about. Why

1 don't you give it a try.

2 MR. SHEWMON: Also, tell us what real data is as
3 opposed to whatever they had before.

4 MR. LOBEL: What I mean by real data is that most
5 utilities don't have real data. Most utilities come in with
6 or would like to come in with general justifications to show
7 that they don't need to do surveillances as often. This
8 program that Southern California Edison has is a problem
9 where they actually monitor the output of sensors for
10 safety-related instrumentation, feed this into a PC and I
11 believe the interval is at least five times an hour.

12 They do this over a whole cycle, and they look for
13 any outliers, any indications that the instrumentation is
14 starting to drift, that it is going off scale or getting out
15 of calibration or out of the range that it is supposed to be
16 in. What they found in general is that the instrumentation
17 has behaved very well, and --

18 MR. SHEWMON: But did they keep track of whether
19 the technician when he did do the check found that it was in
20 range or out of range?

21 MR. LOBEL: Yes. In fact, they even tracked not
22 only that but they looked at what happened to their readings
23 after the technician did he tech spec required calibrations,
24 and they found in some cases that even though the
25 instrumentation was well within its range and they couldn't

1 see any differences in -- the operators couldn't see any
2 differences in the control room, with this system they could
3 actually see that and the technician actually made things a
4 little worse.

5 MR. SHEWMON: That is interesting, but let me ask
6 the same question I just asked again which I did not make
7 clear. Before they had this fancy PC-based system, did they
8 keep track when they did it once a month or once a year or
9 once a quarter, whether or not the technician found the
10 system was in or out of spec?

11 MR. LOBEL: Sure. They have to do that, and they
12 are required to do that.

13 MR. SHEWMON: That's not real data?

14 MR. LOBEL: Let me --

15 MR. SHEWMON: Or, it's less real than what they
16 are getting with the PC which is real data.

17 MR. LOBEL: What they are getting now with this
18 RIM system isn't whether just something is in or out of
19 calibration. They are tracking the trends of the
20 instruments and are showing that even when the
21 instrumentation is still within calibration they can track
22 whether it is behaving well or drifting toward getting out
23 of --

24 MR. SHEWMON: I understand all of that and I agree
25 it's better. I am getting back what data did they have

1 before, and I guess the fact that you didn't trust it or
2 they didn't accumulate it and use it --

3 MR. LOBEL: I don't believe most of any utilities
4 that don't have a system like this keep track of the things
5 in kind of detail that they are doing with the RIM system.

6 MR. SHEWMON: It's absolutely impossible to do it
7 in the line of detail, but that's still not the question.

8 MR. ROSSI: I think you are taking issue with the
9 use of the term real data. Perhaps a better
10 characterization --

11 MR. SHEWMON: It was my impression that there must
12 have been a fair amount of data there before on their plant
13 and their instruments if somebody cared to use it.

14 MR. LOBEL: If the problem with the words I used,
15 let me clarify what I was trying to say. What San Onofre
16 was trying to do -- what the utility was trying to do is, in
17 a very responsible way, gather sufficient data so that there
18 couldn't be any argument about drift, about whether their
19 instrumentation was behaving well, whether if they got to
20 the end of an 18 month cycle if they continued for another
21 six months they were going to get out of calibration or not.

22 They gathered all this data in enough detail so
23 that they could make arguments about the frequency that it
24 was necessary to do surveillances.

25 MR. SHEWMON: I understand. The data they got

1 before was not adequate in quantity or in quality to give
2 you that piece of mind; is that --

3 MR. LOBEL: That's right. It was a different kind
4 of data.

5 MR. CARROLL: Their ultimate goal Paul, is I think
6 to get rid of calibration entirely. You don't just
7 calibrate because 18 months are up or 24 months are up. You
8 calibrate because one of nine channels that you are tracking
9 isn't following the other ones, and it's an indication that
10 something is wrong with that instrumentation.

11 MR. KERR: This implies that the NRC has adopted
12 or formulated reliability standards by which they judge the
13 performance of this equipment. That is interesting. Has
14 your Subcommittee looked at these criteria?

15 MR. CARROLL: The NRC is watching this experiment
16 with interest, I think is a fair statement.

17 MR. KERR: I thought they said that they had now
18 permitted one plant to extend its --

19 MR. CARROLL: Calibration intervals?

20 MR. KERR: Yes, on the basis of these data. This
21 seems to me to mean that there is a reliability criterion or
22 a set of criteria which the plant has demonstrated that it
23 can achieve, and which is satisfactory to the staff.

24 MR. CARROLL: Have you let them extend to 24
25 months?

1 MR. LOBEL: I believe they have gone to 24 months
2 for their instrumentation. I wasn't involved in the review.
3 I saw the system when I was at the plant talking about
4 something else. I don't think I am the person to talk about
5 what the criteria were for --

6 MR. KERR: I wasn't trying to find out what they
7 are. I think this is commendable, and I was just curious.

8 MR. LOBEL: I don't believe there is reliability
9 criteria that have been established.

10 MR. KERR: There must be some criteria that they
11 are meeting.

12 MR. CALVO: We approve the 24 month extension, the
13 safety evaluation report for that criteria. I don't recall
14 what it was. It was done about two years ago. I believe
15 that one we accepted. Whether that system had been in place
16 long enough, whether that system was used as the basis for
17 the staff approval, I don't know.

18 We had that staff criteria which was extended from
19 18 to 24 months. San Onofre had not been the only plant
20 that we had done this. I think we had done this to Harbor
21 Cliff and all this. Whether those people had the same
22 systems or not, I do not know. If you are interested we
23 can, in some kind of way, identify what we had written which
24 documents the criteria that is used for this.

25 MR. KERR: I was trying to find out if any of our

1 Subcommittee's has reviewed this. Maybe, indeed, it should
2 be the instrumentation subcommittee for all I know. I
3 hadn't recognized that criteria for reliability had been
4 established. I think that's commendable.

5 MR. ROSSI: Most of what we have done when we have
6 extended surveillance intervals and that kind of thing has
7 been on the basis of looking at the delta change in
8 something and saying that it's a very small one, so there's
9 a small difference between whether you do a one month
10 surveillance or a three month surveillance, an 18 months
11 surveillance to a 24 month.

12 MR. CARROLL: Delta change in what?

13 MR. ROSSI: Whatever is being looked at,
14 availability of the instrument or going outside the drift or
15 that sort of thing. We don't have a firm criteria, but we
16 say there's a very small change in the benefit that you get
17 from an 18 month surveillance as opposed to a 24 month and,
18 therefore, we believe that a 24 month is --

19 MR. KERR: You haven't reached any conclusions as
20 to what is appropriate. It is just that as long as people
21 don't make any changes in what they are saying it's okay.

22 MR. LOBEL: Getting back to the slide, the RIM's -
23 - that system wasn't involved in any of the work that we did
24 with the technical specifications. It had no input into
25 what we are talking about here. The criteria that we used

1 for this work --for the topical reports wasn't changed in
2 core melt frequency. Changes were proposed in surveillance
3 and allowed outage times, and calculations were done to see
4 what the change in core melt frequency would turn out to be.

5 For the work that Mark Reinhart was talking about
6 that was more qualitative, what was done was a look at
7 operating experience and an evaluation of the surveillance
8 requirement. What we did was look at the benefits of doing
9 the surveillance requirement in terms of how many problems
10 did that surveillance requirement identify and was that
11 surveillance actually identifying the important contributors
12 to unavailability, and balancing that by problems caused by
13 that surveillance requirement. We did have criteria for
14 that.

15 We had four criterion. The criteria were, was the
16 surveillance causing unnecessary wear to the equipment; was
17 it causing a burden to the operators or to the plant; was it
18 causing an increase in dose to people unnecessarily. Those
19 kinds of criteria were used, and it was a qualitative
20 balancing of looking whether the surveillance was
21 accomplishing anything and what it was costing.

22 MR. KERR: Presumably the surveillance was
23 designed to ensure a certain level of reliability; was it
24 not?

25 MR. LOBEL: No.

1 MR. KERR: You don't care about reliability --

2 MR. LOBEL: That's a different question. I didn't
3 say that we didn't care.

4 MR. KERR: I can't understand why else one would
5 do surveillance if one was not interested in trying to
6 achieve some level of reliability.

7 MR. LOBEL: The purpose of a tech spec
8 surveillance requirement isn't to determine reliability.
9 The purpose of a tech spec surveillance requirement is to
10 determine operability. You want to determine whether that
11 equipment is operable. Most tech spec surveillances aren't
12 done often enough to determine reliability in the short
13 term.

14 MR. KERR: I don't understand what you are telling
15 me, but I guess --

16 MR. LOBEL: I am telling you that tech spec
17 surveillances are done to determine operability. Nobody is
18 requiring utilities to determine reliability.

19 MR. KERR: How can something be operable if it
20 isn't reliable?

21 MR. LOBEL: I think that's fairly easy. It can be
22 operable one time and not operable the next 12 times.

23 MR. KERR: You only care if it's operable when you
24 start it up. You don't care what happens after that? The
25 periodic verification gives you some reliability inevitably.

1 MR. REINHART: Sure. It gives us a sense of
2 reliability in a macroscopic sense. We were talking about
3 the risk insights. Again, the work on existing as well as
4 new STS has been largely deterministic, but there are a few
5 areas where we used what risk insight was available. One
6 was in the split report itself. In addition to the three
7 criteria that would capture requirements to remain in the
8 spec, we used existing operating experience coupled with
9 risk significance to capture a few other systems.

10 We mentioned the topical reports that various
11 vendors submitted for their Owners Groups were largely based
12 on PRA type information for extension of surveillance
13 frequencies and completion times for reactor protection
14 systems. To give us a scoping evaluation of where we were
15 on the tech specs, we had SAIC use three 1150 PRA type
16 plants and run dominant risk sequences with the changes we
17 made to surveillance frequencies and completion times to see
18 if we were in the ballpark.

19 In a broad spectrum we found out that we were will
20 within a comfortable range. We did find a few outliers that
21 caused some problems and went back in and adjusted those
22 frequencies until we brought those numbers back into --

23 MR. KERR: Excuse me. How did you determine the
24 comfortable range?

25 MR. REINHART: Well, the number we used was a

1 change of around ten percent core melt frequency. We felt
2 that was within -- I mean, one-tenth of a percent of core
3 melt frequency. Rich, do you want to --

4 MR. LOBEL: What SAI did was to compare the change
5 that we made to the base 1150 number and look for a change
6 in core melt frequency in these cut sets. If they found a
7 change that looked significant, we looked at that in a
8 little more detail and evaluated it qualitatively. In the
9 cases where it was significant like a change of core melt
10 frequency, I believe some were very large because the
11 conservative assumptions we made -- without going into a lot
12 of detail -- these were all done pretty conservatively.

13 If we saw a large change of core melt frequency we
14 went back to the original tech spec number which was the
15 number that was in place when the 1150 analysis was done.

16 MR. KERR: I assume then that what SAI used was a
17 difference in the reliability of individual components or
18 systems in order to detect a change in core melt frequency;
19 wasn't it?

20 MR. LOBEL: They used the difference in the
21 surveillance test interval or the allowed outage time.

22 MR. KERR: In effect then, that's a measure of
23 availability?

24 MR. LOBEL: It is measure of availability, that's
25 true.

1 MR. REINHART: What that gave us was a ballpark
2 feeling. We wanted to see if our effort was in the
3 ballpark, and we felt that it is. The third thing that I
4 would like to hit here --

5 MR. KERR: This means that what you were trying to
6 do was determine that the changes you were making did not
7 make any change in core melt frequency, any significant
8 change?

9 MR. REINHART: That's correct. A third highlight
10 is the human factors effort. The staff human factors people
11 as well as industry human factors people looked at the
12 specs, made some recommendations. We documented that in a
13 writers guide that was agreed to on both sides and have
14 tried to follow that as closely as possible throughout this
15 program to again, make the document user friendly, if you
16 will.

17 MR. CARROLL: How many human factors people had
18 apoplexy after being first exposed to the original standard
19 tech specs?

20 MR. REINHART: I don't know how many we had to
21 revive. We will get to an example here that I think will
22 probably demonstrate what you are saying there.

23 MR. WILKINS: Before you take that off, what is an
24 instrumentation completion time?

25 MR. REINHART: If an instrument becomes inoperable

1 for some reason or the limiting condition for operation
2 isn't met, the completion time is the time allowed to
3 restore that to the normal situation.

4 MR. WILKINS: Either by repair or by replacement.

5 MR. REINHART: Right. Or, by going out of the
6 applicability. It might be changing mode, it might be
7 replacement, it might be repair or whatever.

8 [Slide.]

9 I would like to address a summary of our
10 improvements. A goal was to focus on operational safety and
11 make our specification more operator oriented.

12 MR. KERR: Operational safety means what? Does it
13 have anything to do with core melt frequency?

14 MR. REINHART: We weren't using that risk criteria
15 in what we are calling operational safety. We are trying to
16 focus what the operator is going to do for the plant.

17 MR. KERR: What does operational safety mean then?

18 MR. REINHART: Let me see -- I think I have a
19 slide that really hit on that. I don't have it with me.
20 What we are looking for is a number of things that are
21 listed here. We are trying to make the specs more operator
22 oriented, we are trying to reduce the action statement
23 induced transients of the plant, we are trying to make them
24 less complex and more easily understood to the operator, we
25 are trying to focus on a requirement that an operator in a

1 day-to-day operation of a plant would run across as opposed
2 to something that maybe maintenance would run across. Those
3 types of things.

4 MR. KERR: That is what you mean by operational
5 safety?

6 MR. REINHART: That's a good chunk of it. There's
7 a whole list, and I don't have it with me. Does anybody
8 remember anymore of those?

9 MR. KERR: That's okay. What our split report did
10 was really focus on requirements that the operator would
11 use. We tried to make the specs designed so that an
12 operator could quickly determine the correct course of
13 action in a given situation. We tried to adjust the
14 completion times and surveillance frequencies where we could
15 justify it so that we would minimize a plant transient that
16 would be generated just because of one of those times.

17 Another thing that we tried to do was eliminate
18 redundant surveillances. If we went through the specs we
19 would find a number of specs that required the same
20 surveillance on the same equipment, so we tried to isolate
21 that into one place. We still did the same thing, but the
22 plant's attention now was more on operating the plant rather
23 than keeping the paperwork and trying to track those
24 surveillances.

25 [Slide.]

1 Maybe if we compared the specs, this is an example
2 of what an operator faced on one of today's current specs.
3 It is generally a prose-oriented approach. The operator had
4 to read paragraphs to find out if he was in a condition that
5 wasn't one that he wanted to be in, what he had to do, how
6 long he had to get out of it and any kind of contingencies
7 that he might have to take.

8 Our approach was to take these requirements and
9 put them more in a tabular format where in one place the
10 operator has his limiting condition for operation and any
11 amplifying note, where it was applicable and what mode, and
12 give him in a concise statement what the condition was, what
13 he was required to do and how long he had to complete that
14 action. That fact alone, we feel generates operational
15 safety providing that ease of use to the operator.

16 [Slide.]

17 Surveillance frequencies for surveillances were
18 approached in a very similar way. Again, rather than trying
19 to read a lot of prose, the surveillances were broken down
20 into discreet requirements the operator had to do, amplified
21 by notes where necessary, and a given frequency when that
22 requirement came due again. We tried to be consistent in
23 the tech specs not just in a given Owners Group but across
24 the line of Owners Groups so that the industry, the staff,
25 the management, the operators would all have the same type

1 of wording, the same type of approach to understanding the
2 requirements.

3 MR. CARROLL: I am a little puzzled on that one,
4 Mark. Why is the note above the requirement?

5 MR. REINHART: That's a good question. Some
6 individuals tend to like it below the requirement and some
7 tend to like it above the requirement. Those of us that
8 liked it below the requirement lost.

9 MR. CARROLL: I would have voted with you.

10 MR. KERR: You mean standard tech specs have to
11 have it above, and if it were below it wouldn't be standard?

12 MR. REINHART: I guess that's true, if that's a
13 level of standardization. The convention proposed by the
14 industry was to have those notes above and after much
15 discussion, that's where they are.

16 MR. CARROLL: That wasn't Sam Bryant's idea, was
17 it?

18 [Laughter.]

19 [Slide.]

20 MR. REINHART: Another improvement that we felt we
21 have made in the specs is in the bases. We have tried to
22 expand those from just some curse statements to really
23 describing what the bases do for us. I will go back to my
24 previous slide here.

25 [Slide.]

1 We tried to provide in the bases the reasons for
2 each requirement, be it an LCO, a surveillance, a completion
3 time, and to try to tie that requirement back into the
4 safety analysis where that was possible. We also tried to
5 tie it into the margin of safety. It wasn't always easy to
6 specify where that connection was, and we came up with an
7 acceptance limit that would tie that requirement to that
8 spec to the margin of safety where possible. If it was
9 determined that it was not possible, the spec will clearly
10 say that so there's no ambiguity.

11 Again, we mentioned that we tried to promote
12 better understanding of technical specifications and that
13 was the wording. We mentioned the improvements of 1.0 and
14 3.0, the applicability and use and application section. We
15 hope that will minimize interpretations coming from
16 licensees for the specs.

17 That really summarizes where our improvement
18 program is going. After the staff and the industry complete
19 our final review of the specs, we will provide that to NRR
20 management, to CRGR for approval, and certainly will provide
21 copies to the ACRS for information at that time.

22 MR. CARROLL: Tell me more about what the lead
23 plants are going to do here in the near future. They are
24 going to convert their existing tech specs and use them for
25 a while?

1 MR. REINHART: During the final approval period of
2 the new STS, the lead plants will start to implement. We
3 are going to iterate back and forth. Before we actually
4 issue a license amendment to the lead plant we want to have
5 an approved STS, but we want to learn through the initial
6 first months of that process to get the feedback.

7 MR. CARROLL: They will be operating under their
8 existing tech specs during that period of time but making
9 the transition, training their operators and people on the
10 new ones coincidentally?

11 MR. REINHART: What most of the lead plants have
12 proposed is to operate under their current specs while they
13 develop new ones. Once the staff approves the specs but
14 before we issue the license amendment, they want to take
15 about a year to go through and update their procedures and
16 start training their personnel. Then for most of them -- I
17 think this is the approach that we prefer -- during a
18 refueling outage make the switch, do the final training, and
19 start up with a new core on the new specs.

20 MR. KERR: In discussing the surveillance
21 frequencies, apparently your criterion was that one did not
22 change the core melt frequency appreciably. Is it your view
23 that the new tech specs make risk greater or less or, again,
24 did you use the criterion that the risk shouldn't be
25 changed?

1 MR. REINHART: Again, we really -- the approach
2 was deterministic in the development of the specs. Maybe I
3 could show you --

4 MR. KERR: I am just asking you for a judgment of
5 whether that was a conscious condition.

6 MR. REINHART: I think consciously we are saying
7 it's not going to increase risk. We don't want it to
8 increase appreciably, obviously. We didn't really use a
9 risk-based criteria to be able to point to some solid
10 numbers.

11 MR. KERR: Did you want it to decrease risk?

12 MR. REINHART: That would be ideal. Again, we
13 don't have numbers to prove that.

14 MR. KERR: I am trying to understand the
15 motivation for doing this. These are referred to as
16 improved tech specs.

17 MR. ROSSI: Let me try. Qualitatively it's our
18 belief that these will reduce the risk by being easier to
19 understand and focusing the operator's attention more on the
20 most important things. It will also allow the licensees on
21 the less important things to more promptly revise them under
22 a 50.59 process without coming to the staff to get prior
23 approval. So, in that sense, we think it will make the
24 plant safer.

25 From a quantitative standpoint, we have not looked

1 at what the surveillance changes and that kind of things do.
2 I guess qualitatively, there we would feel that it would
3 reduce the risk too because we -- our feeling is that by
4 increasing things like surveillance intervals and allowing
5 more time to repair equipment that is out of service, that
6 in a qualitative sense that will reduce a risk even though
7 perhaps we haven't quantitatively tried to calculate it.

8 Would you have any comment on my characterization
9 of it?

10 MR. REINHART: I think that's a good
11 characterization. The operator is the one operating the
12 plant, and the more his attention is focused on the plant
13 rather than something else, the safer he is going to operate
14 that plant. We feel that we have made some progress in that
15 direction.

16 MR. CALVO: Dr. Kerr, when this program first
17 started we were a little concerned that maybe we are
18 relaxing things a little too much. We felt some good
19 reasons behind it. Maybe the data that we had based on
20 operating experience, we felt kind of the way we wanted to
21 couple with a little of risk -- so this one we hire the
22 service of the SAIC to look at it and see if we are doing
23 anything wrong up there because of an outlier that will get
24 us into trouble.

25 We did that, but we do it in kind of general way.

1 We did find out that for all practical purpose where we
2 could relax it to allow for all the convenience in operation
3 and maintenance it was not so bad. We found in a few cases
4 where we have some problems, and those we corrected. We did
5 that. We were concerned about that problem.

6 Again, you know, every plant has different
7 characteristics and peculiarities in it. That may be
8 different in the one that we had generalized but we are
9 hoping to pick those up as we go along through this process.

10 MR. KERR: How thick are the new tech specs
11 compared to the old ones?

12 MR. REINHART: They are probably thicker. If you
13 look at them --

14 MR. KERR: I thought we had simplified things.

15 MR. CARROLL: We improved them.

16 MR. REINHART: We put white space in where there
17 is a lot of words. I think if you look at the bases, the
18 new bases compared to the old bases, they are going to be
19 significantly larger. If you look at the LCO surveillance
20 portion they are going to be a little bit larger, but
21 there's going to be a lot more white space on the paper. If
22 you remember from the example that we showed rather than
23 having all that stuff jammed together they are kind of split
24 out so the operator can, at a glance, tell --

25 MR. CARROLL: Forgetting the bases, Mark, the guts

1 of the tech specs in terms of words, how many words do you
2 think there are compared to the existing ones?

3 MR. REINHART: I don't know. The contractor who
4 is producing these, I have asked to give me a page count.
5 They are not done printing yet. I can get a number for you.

6 MR. CALVO: To be honest it is much bigger than
7 the others because we are trying to explain things better.

8 MR. CARROLL: The bases aren't something that the
9 operator looks at every day necessarily.

10 MR. ROSSI: Even the ICO's, you know, they can be
11 easier to understand and simpler for the operator to use but
12 still take a lot more thickness of pages than the old ones.

13 MR. CARROLL: Simply because you don't have as
14 many words on a page.

15 MR. ROSSI: Also, the words are better and easier
16 to understand. That's the other thing.

17 MR. REINHART: I think your answer in word count,
18 my gut feeling is that there are going to be fewer words.

19 MR. CARROLL: Yes, that's what I would think.

20 MR. REINHART: A lot fewer words.

21 MR. ROSSI: There was one viewgraphs that gave a
22 comparison to the number of LCO's that we believe have been
23 removed from the tech specs, and I think the number is
24 something like 40 percent reduction in the number of LCO's
25 that are controlled by the tech specs in the new tech specs

1 as compared to the old ones. That, I think is a better
2 measure for the degree to which we specified the tech specs
3 in taking things out and trying to stack the pages up.

4 MR. KERR: How thick is one of these things? I
5 must say that when you add them with the tech specs, is this
6 a ten volume thing?

7 MR. CARROLL: No, it fits in a binder like this.

8 MR. REINHART: The LCO's, I hope will fit in a
9 binder like that, I'm not sure.

10 MR. CARROLL: About that thick.

11 MR. REINHART: Maybe thicker. The LCO's might fit
12 in a volume and the bases will fit in maybe a large volume
13 to two volumes.

14 MR. WILKINS: You don't really expect any
15 particular operator to know everything that is in that whole
16 volume?

17 MR. CARROLL: Yes. He doesn't get a license if he
18 doesn't.

19 MR. WILKINS: The operator doesn't get a license
20 if he doesn't pass the test on the whole thing.

21 MR. CARROLL: It's an open book test, but he has -
22 -

23 MR. WILKINS: That means that he's got to thumb
24 through it and find what he's looking for.

25 MR. CARROLL: He has to know what it says and what

1 it means, particularly the senior operator.

2 MR. CALVO: We tried the Pacific Northwest
3 Laboratory in the last two months. We have requested to be
4 provided to us on licensing examiners. We want to say tell
5 us what you think of it and see what is your feeling of it.
6 They all love it. I couldn't believe it, because there was
7 a lot of words in there but they like the idea that it
8 explains the reasons for the limited conditions for
9 operations.

10 They say at least now I know for right or wrong
11 what is operable before training -- the bases will tell me
12 these things. They like it. There was some self-purpose
13 because they figured out they can use that to give test to
14 the operators.

15 MR. KERR: Who is this that liked it?

16 MR. CALVO: The Pacific Northwest Laboratory who
17 are helping us out with the operator license.

18 MR. CARROLL: Contractor licensing.

19 MR. KERR: I would wonder how licensed operators
20 would like it rather than how Pacific Northwest Laboratory
21 people liked it.

22 MR. ROSSI: You might speak again to what you did
23 at Chattanooga, because that may address that question
24 better.

25 MR. REINHART: I mentioned we took a set of these

1 specs and gave them to a training center. They implemented
2 on one of their simulators, they put in specific numbers for
3 that simulator and had a class of people who at least at one
4 time held SRO licenses to operate the plants. From the
5 people that took the class as well as the training center
6 itself we got very good comments that they liked those specs
7 greatly more than the current specs.

8 MR. KERR: From that I assume that industry
9 generally is enthusiastic about what you are doing?

10 MR. REINHART: I definitely think so. Industry
11 proposed the format and has been very enthusiastic about it
12 from the beginning. I mention both they and us agreed on
13 that format at the start.

14 MR. CALVO: Keep in mind that it was the industry
15 idea. All we are doing is tuning it up and we are
16 confirming that safety has not been degraded. That's all we
17 do. The idea and the concept, the format and presentation
18 was the industry. You have to give them credit for that.

19 MR. MICHELSON: Are we finished?

20 MR. REINHART: I have finished the presentation.

21 MR. CARROLL: One of the things with the existing
22 tech specs was that there was never a requirement to update
23 the bases, not that that made a lot of difference because
24 the bases were so bad. Is that going to be required as you
25 make changes to the plant?

1 MR. REINHART: There is a portion in the
2 administrative controls that provides for the control of the
3 bases and how changes would be made to the bases. If a
4 licensee proposes a change to an LCO they would reflect it
5 on the bases. They may even come in and propose a change to
6 the bases based on what they learned.

7 MR. MICHELSON: In the tech specs there are
8 various places where there is certain requirements
9 concerning motor operated valves that will be met. Are
10 those requirements still in the standard tech spec, or have
11 they been moved to some other location?

12 MR. CALVO: The requirements --

13 MR. MICHELSON: Surveillance, for instance,
14 periodic surveillance.

15 MR. CALVO: Some of them are there --

16 MR. MICHELSON: They were there and now are they
17 still there?

18 MR. CALVO: If those particular motor operated
19 valves had to do with the system that is important that say
20 satisfy the criteria that are required to stay in the tech
21 specs yes, that particular motor operator will have all the
22 surveillance that you had before.

23 MR. MICHELSON: Maybe I missed those criteria then
24 that decided what stayed in the tech spec.

25 MR. ROSSI: Somebody must have the viewgraph with

1 the -- why don't you put it up.

2 MR. REINHART: I have it here.

3 MR. LOBEL: In some cases we are allowing for
4 deletion of lists of specific valves; is that what you are
5 referring to?

6 MR. MICHELSON: That's part of what I am referring
7 to. When you delete them what happens to them, just delete
8 them and forget them?

9 MR. REINHART: They are relocated to licensee
10 control documents.

11 MR. MICHELSON: You mean -- how do I know what
12 document or whether it's even picked again? These
13 surveillance still have to go on.

14 MR. REINHART: That's true.

15 MR. MICHELSON: Clearly --

16 MR. REINHART: When the licensee proposes his new
17 tech specs he is required to tell us where the relocated
18 requirements go, how they are implemented and the staff is
19 required to go out and inspect to make sure that is --

20 MR. MICHELSON: Each licensee may do it
21 differently according to his particular arrangement, is that
22 right? You have to pre-prescribe where it has to be moved
23 to, so I guess it depends on the licensee.

24 MR. CALVO: If it is a system that puts in -- we
25 had reference on the bases to tell where that information is

1 located. Keep in mind -- only the tech specs establish the
2 framework where the procedures on that plant that they got
3 to be implemented to assure that the criteria set forth on
4 that surveillance have been met. If you want to list all
5 that equipment and the bases you are not talking about --

6 MR. MICHELSON: You have to list it somewhere or
7 people don't know what they are supposed to do.

8 MR. CALVO: That's right. That's the procedure.

9 MR. MICHELSON: This is found in another document
10 now. That document, they prescribe how frequently the
11 surveillance has to be performed.

12 MR. REINHART: That's correct.

13 MR. ROSSI: Specific isolation valves -- the
14 actual list of the containment isolation valves -- augment
15 or correct if I say something wrong -- the actual list of
16 the specific valves by valve number will not be in the
17 standard tech specs. They will be somewhere else. There
18 will be statements covering LCO's and surveillance times and
19 action statements in the tech specs for the containment
20 isolation valves as a whole but the specific list will be
21 somewhere else.

22 MR. MICHELSON: In other words this tech spec will
23 say you need to do the testing but it won't indicate the
24 acceptance standard --

25 MR. ROSSI: The time responses on them will be

1 somewhere else.

2 MR. MICHELSON: It would have to be, or you are
3 back to a list. Let me -- we used to have that information
4 in a tech spec and now it has been moved. The requirements
5 are still the same in a new location; is that correct?

6 MR. ROSSI: The requirements, I would say, are in
7 the tech spec --

8 MR. MICHELSON: No, the requirement that it must
9 close in 15 seconds, that kind of requirement.

10 MR. ROSSI: Yeah, that is somewhere else.

11 MR. MICHELSON: That will be in a new location.
12 Now, what control is there over that new location in terms
13 of my changing it to 20 seconds instead of 15 --

14 MR. ROSSI: It will be through the 50.59 process
15 basically, or a process similar.

16 MR. MICHELSON: Was that the way --

17 MR. REINHART: A staff approved process in 50.59
18 as upgraded is one of the methods that is proposed.

19 MR. CALVO: The requirement how often you got to
20 do the test, that is in the tech specs. What is outside the
21 tech specs is the procedure or mechanism how to accomplish
22 that test. That procedure has to satisfy that criteria that
23 is set forth in the tech specs. For instance in containment
24 isolation valve, I think the requirement for the containment
25 isolation valve is in accordance with the in service testing

1 inspection program who establish possibly once every
2 quarter. That is a requirement governed by the tech specs
3 and nobody can change it without staff approval or without
4 issuing an amendment.

5 The mechanism to implement that is outside the
6 tech specs in a procedure. That time cannot be changed.
7 You go back and change the tech specs.

8 MR. MICHELSON: The frequency --

9 MR. CALVO: The frequency is controlled by the
10 tech specs.

11 MR. MICHELSON: The acceptance standards are what
12 I was really trying to deal with.

13 MR. CALVO: If you have some peculiarity in there
14 that you want the leak rate for that particular valve has to
15 be so much and you feel that it is -- you put that as part
16 of the surveillance and then you are controlled by the tech
17 specs.

18 MR. MICHELSON: The key question that I asked is
19 that was what was in the old tech spec and now in the new
20 tech specs, has now been moved and has anything been changed
21 when they moved it.

22 MR. CALVO: No, not in all the cases. On some
23 very few cases. It was established in the tech specs and
24 sometimes not.

25 MR. MICHELSON: If it was established that it had

1 to be a certain time to closure for instance, that I will
2 find now in this new document.

3 MR. CALVO: Right. When we went through the
4 process of reviewing all these surveillance of what stays in
5 the tech specs, we also challenged some of that acceptance
6 criteria that we used in the tech specs. It was a staff
7 decision which it wants to still keep them in and which it
8 we felt was not important enough to keep them out and let
9 that be controlled by the document.

10 MR. MICHELSON: Let me ask the question a little
11 differently. In the process of creating this new document,
12 this new location for that particular listing, did you drop
13 things off the list when you did that or is it the same list
14 that would appear in the old tech specs.

15 MR. REINHART: That is to be audited by the staff-

16 -

17 MR. MICHELSON: What was the intention --

18 MR. ROSSI: I think the answer is, recognize that
19 we have some plants out there today where the list in the
20 tech specs isn't up to date, and to get that up to date
21 takes a license amendment. By moving these out into
22 someplace else it will be much easier --

23 MR. MICHELSON: The adders I am not too concerned
24 about. It's where you have subtracted --

25 MR. CARROLL: Well, the subtractors they have to

1 do 50.59.

2 MR. MICHELSON: That's right, and that's the
3 answer that I got. It is the same list unless they have
4 done a 50.59 on a particular item that got dropped off. I
5 am not challenging that you have done it right or wrong.

6 MR. CARROLL: Any more questions of the staff?

7 [No response.]

8 MR. CARROLL: Did NUMARC want to make any comments
9 on this program?

10 MR. HALL: My name is Warren Hall. I am the
11 Operations Manager of Support Service, Division of NUMARC.
12 I would like to thank the Committee for giving me an
13 opportunity to speak here, and I appreciate it. Basically
14 my thoughts here are, we have listened to the presentation
15 and would just like to clarify a few things as least as far
16 as the industry and NUMARC are concerned.

17 First of all, the staff review and discussions
18 with the Owners Groups, we have not been in discussion with
19 the staff on the tech specs, the LCO surveillances or the
20 bases since about late July or early August timeframe. We
21 have not had any meetings, nor have we had any reviews of
22 the things that they have been writing to date.

23 We have had several discussions with Mr. William
24 Russell of the NRR staff, and we are under the impression
25 that the tech specs that will be issued by the staff in

1 April are not the final draft. That was our impression, and
2 that is what we were told by Mr. Russell. What we will get
3 is a set of tech specs that the industry will review and
4 comment on along with the staff. We will return comments to
5 the staff on these tech specs. We will, at that time,
6 proceed to meet with the staff on these issues and try to
7 resolve these things, at which time when and if we get all
8 the comments resolved or whatever the final resolution of
9 the issues are, the tech specs will then be issued in final
10 form to ACRS, CRGR and the rest of the world to look at and
11 comment on or go through the process.

12 There is also included in there an appeal process
13 for issues that the staff and the industry do not agree on.
14 We do have some, they are aware of some, and we are aware of
15 some. I just wanted to kind of let you all know that that
16 is our understanding of how this process goes prior to
17 coming back to you all for another session. It was also our
18 understanding that it would be coming back to you folks for
19 another session prior to being issued for use by the
20 industry and for implementation by the industry.

21 Also, our understanding was -- and I may be wrong
22 and if I am correct me please -- that the lead plants would
23 not be implementing these programs until after we have been
24 through the review process and the discussion process with
25 the staff. That was our understanding of the issues several

1 weeks ago when we spoke with Mr. Russell.

2 Outside of that, I don't have any other comments.
3 I just wanted to get that on the record to get that
4 straight.

5 MR. CARROLL: What is the appeals process as you
6 understand it?

7 MR. HALL: Excuse me?

8 MR. CARROLL: What is the appeals mechanism?

9 MR. HALL: The appeals mechanism, as we understand
10 it, if after we have marked up our comments and submitted
11 them back to the staff and after our meetings if we have an
12 impasse, we then have the first process would be Dr. Rossi.
13 Then we would go to Bill Russell and then to Dr. Murley. I
14 don't assume we would go much past that at that point.

15 MR. CARROLL: Generally the industry is happy with
16 what is happening here?

17 MR. HALL: I don't know. We have not seen
18 anything since July or August, and I would not want to
19 comment one way or another about it until we see the final
20 product.

21 MR. WILKINS: Let me ask the question a little
22 differently. Are you happy that something is going on?

23 MR. HALL: Again, I would have to see what was
24 there before I would say I was happy or unhappy.

25 MR. ROSSI: I wonder if you could comment on the

1 format and the user friendliness and that kind of thing of
2 the tech specs. I don't think there's any changes going on.
3 I think most of your comments apply to individual line item
4 disbursements that you may have with the staff.

5 MR. HALL: Format and so forth is as -- we agreed
6 on that, and I think everybody is quite happy with the way
7 the format has been laid out and feel that is probably going
8 to be very beneficial. The operators from the various
9 Owners Groups that have looked at the format also in concert
10 with the staff think that the format is very good.

11 MR. CARROLL: Are you a party to the idea that you
12 give people cautions before you tell them what you are
13 cautioning them about? Question withdrawn.

14 MR. WILKINS: I notice in the EDO's letter to the
15 Commission -- SECY something or another -- 93.66 dated
16 October 29, the staff expects to resolve any public comment,
17 complete ACRS and CRGR review and publish the final version
18 of the new STS in the spring of 1991. That doesn't somehow
19 seem compatible with what this gentleman has just said nor,
20 in fact, does it seem compatible with what I heard behind
21 me.

22 MR. ROSSI: We are in the final stages now of
23 completing the editorial work on all these sets of standard
24 tech specs. We hope to send those out by letter very soon,
25 hopefully by the end of the year or very soon thereafter to

1 NUMARC and the Owners Groups and within the staff and
2 obviously they will be made public at that point in time,
3 asking for the comments from the Owners Group and NUMARC,
4 and I guess anybody else that wants to comment on them.

5 We are anticipating I think it's 30 working days
6 now to get the comments back, and then there will be some
7 period of discussion and resolution of the comments. Then
8 we would hope that we can issue these things in final. We
9 believe that we are talking spring of 1991.

10 MR. WILKINS: That means you will do it before you
11 have the experience from the lead plants.

12 MR. ROSSI: We are not intending to have the lead
13 plants try to use the tech specs on a plant before we issue
14 them. The lead plants have been involved in this.
15 Recognize issuing the new standard tech specs is not the
16 same as issuing the tech spec for a particular plant. If
17 you issue the tech specs for a particular plant it's a very
18 legal document and only can be changed by license amendment.

19 The new standard tech specs really serve as
20 guidance for people to use in developing plant-specific tech
21 specs. Obviously, anything that we learn through the
22 process of a lead plant adoptions of these new standard tech
23 specs, we will factor them back into the new standard tech
24 specs as part of a reasonable process. It is also the lead
25 plants have been involved all along in the new standard tech

1 specs, so it's our hope that there is not going to be a big
2 gap here anywhere.

3 Obviously, with something like tech specs there's
4 always disagreements between the staff and the industry over
5 the need for individual requirements and whether something
6 ought to be seven days or 14 days; whether a particular
7 piece of equipment really needs to be controlled by tech
8 specs or not. For that, there will probably be some
9 disagreements, and they will be resolved through some kind
10 of an appeal process.

11 MR. MICHELSON: Will you have to review them on
12 every plant? How many people are going to use the standard
13 tech specs?

14 MR. CALVO: About 70, 75 or 76.

15 MR. MICHELSON: You have to review every
16 conversion since licensing action --

17 MR. CALVO: Yes.

18 MR. MICHELSON: Voluntary.

19 MR. WILKINS: If what I heard this gentleman say,
20 he doesn't know either, and that will depend on what they
21 look like.

22 MR. HALL: That's correct. I think that's a fair
23 statement.

24 MR. MICHELSON: It is going to be a rather large
25 effort on the part of any given licensee to convert since

1 this is a quite a bit different kind of tech spec. He has
2 to now make it a plant-specific tech spec. He just doesn't
3 take it and fill in a few blanks.

4 MR. CALVO: Somebody tells me -- some of the
5 industry and some of the licensees -- you require three
6 years from the time you make your mind to do it to the time
7 that you implement it. I guess the hardest part is to
8 collect the information to establish the basis for the
9 standard because -- the other hardest part is to prepare
10 those significant considerations to go from what you go to
11 what the new one is. You got to explain that it cannot be -
12 -

13 MR. MICHELSON: Haven't you been allowing them to
14 remove certain items from the tech spec already and
15 replacing them over in other documents?

16 MR. ROSSI: Yes.

17 MR. CALVO: That will require also significant
18 hazards too --

19 MR. ROSSI: We have issued a number of generic
20 letters, and there are some more generic letters that are
21 going through the CRGR process now that allows them to do
22 things like remove component lists and put them somewhere
23 else without adopting the whole new standard tech spec.

24 MR. MICHELSON: Without adopting the standard tech
25 spec.

1 MR. ROSSI: Surveillance interval changes we have
2 done through topical reports, and people can do that today
3 in a lot of cases.

4 MR. CALVO: It will be a very expensive endeavor.

5 MR. MICHELSON: Let me ask one other question.
6 There is the NSAC document 125 dealing with 50.59
7 interpretations which I guess must get into this process
8 since that is the mechanism you are using. Have you people
9 reviewed NSAC 125 and adopted its principles, or how --

10 MR. ROSSI: We have reviewed the document and we
11 have commented on it a couple of times, and our comments I
12 guess are included in it. It is out now. I think some
13 utilities are using it today; are they not?

14 MR. HALL: Yes. All of the comments that Dr.
15 Rossi's group and the staff had are incorporated into the at
16 document before it was issued. We issued it about a year
17 ago, and we have just -- we went out and asked for comments
18 from the industry. We have gotten back approximately -- we
19 have gotten back comments from 25 utilities regarding their
20 use of the document over a year.

21 MR. MICHELSON: Is it reasonable though in my
22 reading of it that I can say that the staff has blessed that
23 document?

24 MR. ROSSI: Where we are right now is that we have
25 commented on it, our comments are in it, and at some point

1 in time we are going to solicit our own round of comments
2 from people within the NRC and then we will discuss the
3 industry comments in it. Then, there will be another round
4 of blessing of the document.

5 MR. MICHELSON: ACRS has never, to my knowledge,
6 reviewed that document. It is becoming more and more
7 significant because of its use in lieu of whatever is
8 already said in the regulations. Presumably it complies
9 with the regulations. At some point I think we ought to --
10 at some appropriate Subcommittee time it would be well to
11 look at it Jay.

12 MR. CARROLL: I think that's right.

13 MR. MICHELSON: I find it -- I have some
14 questions. I am not sure that I have any problems, but I do
15 have a lot of questions about it.

16 MR. HALL: We would be happy to accommodate you as
17 far as anything that we can do.

18 MR. CARROLL: When do you feel it would be a good
19 time? When is the dust going to settle?

20 MR. ROSSI: After we get our new standard tech
21 specs out. That's where all of our effort right now is
22 going, and then we will return to some of these other
23 efforts like further blessing of NSAC 125. That also, at
24 some point in time, is probably going to have to go to CRGR
25 before we put something out that more formally adopts it.

1 MR. MICHELSON: It is getting somewhat widespread
2 use without appearances of being -- it's not a reference
3 document --

4 MR. ROSSI: It doesn't have Reg Guide status, no.

5 MR. HALL: It was issued as a guideline. That was
6 the purpose.

7 MR. MICHELSON: Only as an industry guideline, not
8 as an NRC guideline.

9 MR. HALL: I might pass on a bit of information.
10 In the process we have been trying to gather information
11 from our members on the 50.59 as I said. There was the
12 staff mostly NRR people, did an inspection at Palisades on
13 their steam generator change out program. They went in and
14 inspected there, and spent quite some time I guess, about a
15 week, going over their 50.59 program that they were doing
16 for their steam generator.

17 The inspection report has been out several months.
18 It gave them a very clean bill of health with regard to
19 that. Our discussions with Palisades indicates that their
20 entire 50.59 program is based on the guidance that was put
21 out in NSAC 125. At least from that point of view it looks
22 like it has been fairly positive.

23 MR. CARROLL: I think what you are suggesting Carl
24 is appropriate. Paul, do you want to sort of keep in touch
25 and find out what a good time for us would be to sit down

1 and look at NSAC 125. Are there any other issues on tech
2 specs?

3 MR. WILKINS: I just observed that the then
4 Commissioner Hazeltine had some rather caustic remarks to
5 make. I thought that at least a couple of them are things
6 that staff ought to pay a little attention to. I assume they
7 did.

8 MR. CARROLL: Page 21.

9 MR. WILKINS: In my book it is handwritten page
10 21. He wants to be sure that the NRC continues to have its
11 ability to fine a licensee or to seek escalated enforcement
12 action against a licensee who fails to comply with a
13 relocated technical specification.

14 MR. CARROLL: No problem.

15 MR. WILKINS: You have no problem with that at
16 all.

17 MR. CARROLL: That is what Appendix B does for
18 them.

19 MR. HALL: Thank you, I appreciate it.

20 MR. CARROLL: I thank the staff for a very
21 informative presentation. Paul, I guess we have to decide
22 what we are going to do on future interaction on these new
23 standard tech specs. I guess from reading the SECY 93.66
24 which we just heard some discussion of, it sounds like the
25 staff expects to resolve any public comment, complete ACRS

1 and CRGR review and publish the final version in the spring
2 of 1991, which sounds like we are supposed to be in that
3 loop.

4 I guess that would take place after NUMARC and the
5 staff had interacted. Again, I guess I will charge you with
6 keeping in touch and finding out when a good time to have a
7 NUMARC and staff discussion on that prior to publication of
8 the final version. Back to you, Mr. Chairman.

9 MR. MICHELSON: Thank you. Time for our 2:30
10 break. We will be back at 2:45.

11 [Brief recess.]

12 MR. MICHELSON: We are ready for our next agenda
13 item, which is relating to the NRC's safety research
14 program. Ivan Catton is going to conduct the discussion.

15 MR. CATTON: The DCH issue seems to come and go,
16 just as my personal view of it does. About a year and one-
17 half ago Novak Zuber was asked to address a scaling issue as
18 associated with severe accidents. I am not sure how it came
19 to pass, but the DCH question was chosen for the
20 demonstration. The project is almost completed, and a
21 report is due in draft form by the end of this month.

22 The reason for asking Novak to give a presentation
23 at this time is that he is retiring at the end of this
24 month. I thought that in that he has had an illustrious 40
25 year career in the business of boiling and two-phase flow,

1 we should hear what he has to say about the scaling in this
2 arena.

3 MR. ZUBER: I would like to thank the Committee
4 for giving me this opportunity to present the results of the
5 --

6 MR. MICHELSON: I think you are going to need to
7 put the microphone closer to you because we can't hear you.

8 [Slide.]

9 MR. ZUBER: I appreciate the opportunity to be
10 able to present the results of the work that we have been
11 conducting for about two years, and the work was done by
12 technical program group. You will see the names of the
13 participants. The reason I am to be here is that if you
14 have any criticism please address them to me, because I
15 would like to be able to answer and accept it.

16 What I would like to present today is given in
17 more detail in the handout. I will not go over the entire
18 material. The reason I prepared extensive handout is so
19 that you can read it if you are interested and follow it in
20 a more -- in a better way than if I skip something in my
21 presentation. All this material is presented in the report,
22 and I will discuss the outline of the report, the content
23 and the date it is planned to be issued.

24 [Slide.]

25 What I will present today is an integral structure

1 and scaling methodology for severe accident technical issue
2 resolution. A technical program group was formed in January
3 of 1989 to address this problem and develop a methodology.
4 The members of the group are listed on this slide. You can
5 see that you recognized authorities or experts or
6 knowledgeable people from industry, from laboratories, from
7 universities. It's a balance of talents and inputs of
8 different point of views. What we present is output from
9 nine meetings we had with the TPG.

10 [Slide.]

11 The outline of the topics which are covered in the
12 --you have five handouts, five parts to the handout. You
13 have the topics which are covered. There is an overview of
14 the structure for technical issue resolution. There is a
15 brief description of the components and overview of the
16 scaling methodology SASM, a brief description of the
17 components, and overview of two-tier scaling analysis, an
18 application to DCH transient and the content of the report.

19 What I shall do is just mention this in about two
20 minutes. You can read it, and I will emphasize and spend
21 most of my time on the scaling analysis application to DCH
22 and what conclusions we derived.

23 [Slide.]

24 ISTIR, the methodology has five components. These
25 are shown on this slide here. The purpose of this structure

1 is to provide an efficient method for technical issue
2 resolutions. In component one you specify the issue, you
3 specify the requirements, and the phenomena in the
4 particular transient. This is the requirement for
5 experimentation and code development. The reason that you
6 have this one here, you want to provide the same requirement
7 to two activities; experiments and code analysis.

8 Box number two is SASM and severe accident scaling
9 methodology and experimentation. Its function is to ensure
10 that the data obtained from experiments are prototypical and
11 can be used either in codes to develop models or a special
12 models done for a particular problem in activity three. The
13 technical issue resolution is achieved either through codes
14 and uncertainty analysis or through some special models and
15 experimental data and uncertainty analysis.

16 I will not discuss item four, five and three. I
17 will just give you an outline of one and spend my time on
18 item two. You have the description of the activities in the
19 handout.

20 [Slide.]

21 Component number one specifies the requirement.
22 You have to specify what the issue is and provide the
23 success criteria. To specify the scenario, you have to
24 specify the particular plant because plant configuration is
25 important aspect on this problem. You have to specify the

1 accident part, because different parts lead to different
2 results. You have to provide a rank and table of phenomena.
3 You identify the phenomena and rank them, and this provides
4 the requirements for experimentation and for code. This is
5 the first activity.

6 [Slide.]

7 I will discuss now the second activity, SASM, and
8 give you an outline and go into details. This is scaling
9 and experimentation. SASM is divided in three elements. In
10 the first element from component one, you transpose the
11 requirements into experimental objectives. In element two
12 you perform scaling analysis, identify similarity criteria
13 from integral test or separate effect tests, obtain the
14 data. Element three is provide documentation and there is
15 requirement for documentation. Those are the three
16 elements. I will not describe the steps. They are in the
17 report, and some of them are in the outline. This is the
18 procedure to follow.

19 I will now stress from now on the scaling and the
20 similarity criteria and its application to the DCH problem.

21 [Slide.]

22 What I will discuss now is an overview of a two-
23 tier scaling methodology, and I will give you the rationale
24 why we need the two-tier methodology for severe accidents
25 and how we did apply this methods to DCH. The topics which

1 are covered in the handouts are listed here. I will just
2 briefly outline the highlights, and more information is
3 provided in the handout. The rationale is discussed in the
4 handout and in more detail in the report.

5 Let me first tell you something about severe
6 accidents. Let me first tell you the objective. The
7 objective of this activity is to ensure prototypicality of
8 the experimental data, one. Two, to provide the methodology
9 that is systematic, practical, auditable and traceable.
10 This is what is needed by a regulatory agency. We have to
11 provide the scaling rationale and similarity criteria.
12 Somebody asked how did you scale the facility, what was the
13 rationale that methodology should provide this. Four, we
14 must have a procedure how to review design and test. You
15 have to provide this procedure.

16 Finally, the final objective also is to -- if you
17 have biases, if you have scale distortions or non-
18 prototypical conditions, you would like to have a method to
19 determine the biases. The objective of the scaling
20 methodology is to meet these four objectives. What I should
21 present is that this is methodology that meets all of them.

22 MR. LEWIS: Are you confident that there is a word
23 prototypicality, because if so I have just learned
24 something.

25 MR. ZUBER: Let me say that I think we can provide

1 the phenomena that we observe in a small facility --

2 MR. CATTON: Novak, I believe he is questioning
3 the english word, prototypicality.

4 MR. LEWIS: I agree that there should be such a
5 word.

6 MR. ZUBER: I didn't coin it or wish I had. I
7 just copied it.

8 MR. LEWIS: You were just being inventive.

9 MR. ZUBER: No, I was not inventive on that one.

10 [Slide.]

11 Let me tell you something about the characteristic
12 of severe accident, because this sets up the tone of the
13 development. The characteristic of severe accidents is the
14 interactions and reactions of media, of many constituents,
15 several phases which exchange mass momentum and energy
16 simultaneously.

17 How we can characterize this problem is one, each
18 constituent occupies only a fraction of the volume because
19 they are acting in a given closed space. Each system
20 component is characterized by a scale and by a time
21 constant. Each physical process, whether it is physical or
22 chemical, it is again characterized by a dimension and time
23 constant.

24 What this means is that when you look at a problem
25 in the entirety it is a problem which has multiple scales

1 for spatial and temporal. What this means is, because of
2 this complex iteration and reaction between various fields
3 and phases and solids you have to take synergetic effects.
4 You have to take global view of the problem. You cannot
5 take one aspect of it and analyze it to death, because it
6 may be relevant in the globality of the processes.

7 So, what this interaction, this synergetic effects
8 forces you to take a global look. Because of the complexity
9 this forces you also to look at the hierarchy. You cannot
10 look at everything at the same time, you cannot scale
11 everything satisfactorily. You have to have a rationale how
12 you applied and then be able to sell this rationale to other
13 people. This is what I am trying to do now. We have to do
14 it outside.

15 The next viewgraph really summarizes the entire
16 methodology, and let me spend some time discussing it.

17 [Slide.]

18 There are really five concepts which provide the
19 basis and it is divided in four activities. One is that we
20 need a hierarchy. What this means is that you have to
21 decouple the system, provide a system hierarchy to identify
22 the geometries and then identify the physical processes.
23 You have to identify the geometries because you have
24 different scales, different areas. You then have to
25 identify the scale. There are really three scales that you

1 have to deal with.

2 One is that each process has its own time scale.
3 Each process occurs across the characteristic area. That
4 area has a scale. For example, let me say that in a water
5 and debris, you have to characterize the geometry. The
6 third important factor is the concentration. You have to
7 characterize the amount of material of any material in that
8 volume. You cannot give a number of pounds or kilograms or
9 tons in looking how does it affect the entire process.

10 There are three things that you have to really
11 scale and provide this hierarchy. This is the activity
12 here.

13 [Slide.]

14 The two-tier scaling analysis is being carried by
15 a top-down system approach and a bottom-up process approach.
16 The system approach is predicated because you have to look
17 at the globality of the phenomena and formulate a rationale
18 how to address them. What this means is you have to have
19 the conservation equations, the scaling groups, establish
20 criteria hierarchy, and identify important processes which
21 have to be looked at in great detail.

22 I said there are many fields which are
23 interacting. How can you scale all of them in the same way.
24 Usually when you go into textbooks people scale or example
25 the momentum equation ratio forces. You go to the energy of

1 the ratio of energies. What we are using here is something
2 which some other people did also before us. We used the
3 time scale. We transferred everything in terms of a system
4 scale which is how the system responds and how each process
5 responds and we make a comparison.

6 This provides us with a mechanism to use the same
7 meter, the same measure on all processes. This enables us
8 to obtain the scaling hierarchy and identify which are the
9 important process and then really scale them correctly. We
10 don't care about scaling something -- you have to address
11 the important phenomena and this methodology provides it.

12 Once we have identified important phenomena and
13 scaling ratio, we perform a detailed analysis, a detailed
14 scaling analysis to provide -- to ensure that the important
15 processes are properly scaled. This is the reason for a
16 two-tier approach. You cannot do this without looking at
17 globality. Doing this together with the globality gives you
18 assurance that you have addressed the important processes.

19 This activity ensures that the methodology is
20 comprehensive, systematic and traceable. At every point of
21 the analysis you can check this thing here. This activity
22 provides for properly focused analysis. You identify what
23 is important and you analyze it. Together, this provides
24 the efficiency, this activity provides the sufficiency, and
25 together they provide the method which is practical and then

1 you can use it. I will then use this to the DCH, these
2 steps to show what the results we obtained and what
3 conclusions we reached.

4 [Slide.]

5 Let me illustrate how we establish system
6 decomposition. We can decompose a system in subsystem in
7 modules. I call them module control volumes. Each control
8 volumes can have several constituents, water, hydrogen or
9 whatever. Each constituent can have several -- two phases,
10 either fluid and gas or fluid and solid. Each phase is
11 characterized by particular geometry. That is important.

12 The reason the geometry is important is because
13 transfer occurs at those areas. This is what you have to
14 scale. You have to look at the particular geometry. For
15 each geometry you can have then described in terms of three
16 fields mass energy momentum, and for each of these fields
17 you have different processes. This is the hierarchy, the
18 marching order of the thinking and of the analysis.

19 [Slide.]

20 At each stage of this analysis you identify at
21 time scale and length scale, and as you get into geometric
22 configuration you have to identify also the concentration.
23 This concentration really tells you how much of this amount
24 is present in this volume and that volume. This provides
25 the scaling of the amount. There are, as I said, three

1 things to consider. There's time, length and amount. This
2 has to be scaled. You cannot address this problem without
3 thinking of these three elements.

4 [Slide.]

5 Now, what are the characteristic length. The
6 characteristic length is the transfer area, because this is
7 which this process occur. You have several processes For
8 example, take the cavity. You have solid walls, you have
9 structures, you have melt down, you have droplets, you have
10 water, droplets. You have to provide a rationale how you
11 can address all of them together and then scale it.

12 The thing to do is the transfer area concentration
13 is the area for transfer divided by the control volume.
14 These scales, each surface across which the transfer mass,
15 momentum, energy or whatever. You define a void fraction of
16 the given constituent, volume constituent divided by the
17 control volume and this is the volume fraction of
18 constituent V . The area concentration of this particular
19 constituent is which energy and mass is transferred is given
20 this ratio. It is a characteristic length multiplied by
21 this volume.

22 This volume specifies the initial amount and this
23 specifies the geometry. For example, for sphere this is six
24 over D for films is one over thickness of the film. If you
25 have solid structure we have another quantity. If you have

1 pipes it's one over D and so on.

2 [Slide.]

3 Now let me see how you form hierarchy for the
4 geometry. Suppose now I am considering water. Control
5 volume V consists of V. The constituent is water, the
6 fraction of the water in that volume is α_{sub-C} . Water
7 can be in gas form and in liquid form, each one has its own
8 fraction of the volume. The water can be in terms of
9 droplets or in terms of films. Each one has its own
10 characteristic geometry.

11 This you analyze the system, you want to
12 synthesize these results and you bring it up and this is the
13 characteristic transfer area for water, which takes into
14 account the initial amounts, particular geometry and
15 particular lengths. This is how -- the thing to notice is
16 this. You see how this affect is being attenuated because
17 all of the fractions are less than one. This may be a
18 quantity here, but this is factor of ten or more by the time
19 you reach here.

20 This is the reason that you have to consider the
21 total system in -- you have to look at all present phases to
22 obtain these fractions correctly. I will not discuss the
23 scaling of time. It is in your handout. Let me say
24 something about the time processes.

25 [Slide.]

1 There are two time processes of interest. One is
2 the system response. This is how the control volume, if I
3 have a control volume and Q is the volumetric flow rate of a
4 fluid, this is the residence time in the control volume.
5 This specifies how the system, how fast it responds. Each
6 transfer process has its own time scale. Let me take J as a
7 general flux. Let me say this is a heat flux. Multiply by
8 the transfer area gives me BTU per hour.

9 If size is general quantity, then it is a quantity
10 per unit volume. If this is energy, this would be the
11 enthalpy per unit volume multiplied by the volume of the
12 control volume. This gives me the initial amount of energy
13 in the control volume. This ratio gives me characteristic
14 frequency. This tells me how important is a particular
15 process. This is almost like interest rates. You put so
16 much money in the bank and this tells you how many times
17 this changes per second. This is identical if you want to
18 develop number. It gives you the frequency. The ratio of
19 these two numbers, of these two times, scales the relevance
20 of a particular process. This is shown on the next slide.

21 [Slide.]

22 This tells you how long a particle remains in the
23 control volume, this tells you how fast the transfer process
24 occurs. It gives you the total change of a particular
25 process during a residence time. This is the characteristic

1 ratio. The important thing is that all processes are
2 measured by the same residence time, so this gives you the
3 common meter to compare all the processes whether it's mass
4 transfer energy, transfer momentum, transfer -- this
5 provides you the scale.

6 [Slide.]

7 For each process this ratio incorporates temporal
8 and spatial scale. We use the same yardstick to evaluate
9 all processes. The similarities provide that the processes
10 have to occur at the similar time scales. If a process --
11 if this ratio is ten to the minus one and another process is
12 ten to the fifth, of course, the ten to the minus one
13 doesn't mean anything. We only focus on the important one.
14 This ratio provides two things; the process point and
15 system. It really puts everything together for each
16 particular process. You will see how this works on the DCH.

17 [Slide.]

18 Let me summarize something important on this slide
19 here. What I have discussed was, I gave you some physical
20 explanation about the characteristic times are. You can
21 derive the same criteria from the general balance equations.
22 What this means is that all processes can be measured by a
23 single measure in terms of time ratio. At each point this
24 provides you with capability to establish a scaling
25 hierarchy.

1 At each point in the hierarchy you can evaluate
2 any process and you can examine it in detail. This then
3 provides you for a methodology that is systematic, auditable
4 and traceable. You provide the hierarchy, you can examine
5 every point and any element in the hierarchy and then
6 evaluate the importance. The hierarchy can be used for two
7 functions. One is to provide you justifiable rationale why
8 you perform these experiments in this way. This process is
9 more important compared to the other ones, and you will see
10 an example.

11 It also identifies which processes are important
12 so that you have to pay more attention to them and perform a
13 bottom-up analysis. The bottom-up analysis assures that
14 what is important is properly addressed. This gives you the
15 sufficiency. In a nutshell, this is the outline of the
16 methodology. What I will now show you is the application to
17 the DCH.

18 [Slide.]

19 This is discussed in Section 3. What I will just
20 briefly mention is application of component 1. We identify
21 the scenario which was DCH station blackout. We took Zion
22 as the plant. We identified the accident and you will see
23 what it is, and we identified the process. This is in your
24 handout. Let me just show you the part and I won't discuss
25 this because there is a big discussion of this in the

1 report. What I shall discuss is the application of scaling,
2 show you the flow diagram, how we approach the problem, how
3 we scale the reactor pressure vessel discharge phenomena,
4 and how we scale the phenomena in the reactor cavity.

5 [Slide.]

6 I will show you now the accident part we analyzed.
7 This helps us analyze what are the processes at different
8 stages, and from this we transfer in another activity to
9 identify the important phenomena. It is in the handout, and
10 you can see how we rated them.

11 [Slide.]

12 Let me show the application of SASM to the DCH.
13 We have to set up the initial conditions. We looked at the
14 pressure vessel failure conditions. We even looked at the
15 reactor pressure vessel discharge phenomena and reactor
16 cavity phenomena. The items which specified initial and
17 boundary conditions were looked at by Sol Levy. There is a
18 quality report in the appendix our report. He addressed the
19 following items; reactor system pressure behavior,
20 progression of the core damage, the relocation of debris at
21 the bottom head, heat transfer to and failure of bottom head
22 in order to be able to obtain the amount and composition of
23 the material coming out. This sets up the conditions.

24 Then you looked at discharge phenomena, corium
25 solid melt discharge, multi-phase discharge steam blow

1 through hole ablation, solid debris retention in vessel, and
2 single phase. What is interesting thing, this was something
3 that we found is that if you have debris which is partially
4 solid and partially melted, the solid will remain in the
5 vessel. There is an angle of 45 degrees from the hole.
6 Everything beyond that angle will remain in the vessel. He
7 performed some experiments and obtained that.

8 What it means is that if you have some debris, a
9 large portion of the solid material will remain in the
10 vessel and only the liquid may come out and a fraction of
11 the solid. They he proceeded to look at the reactor cavity
12 phenomena. We did the two-tier approach of scaling. We did
13 the pressure rate equation and I shall discuss it. From
14 this we obtained the similarity criteria and obtained these
15 hierarchy. Then we performed a bottom-up analysis to
16 analyze corium discharge and dispersion.

17 [Slide.]

18 Let me just give you an example of the results
19 that Sol Levy obtained in his analysis. He specified
20 initial amount, so it is station blackout at high pressure
21 and low pressures. The point of interest is that you can
22 see the difference in the composition and a difference in
23 the amount of material. This is the reason why it is
24 important to specify the scenario. Different scenario and
25 condition will give you different initial conditions,

1 different initial conditions give you different scaling
2 groups, different volumes for the scaling groups and
3 different conditions to perform your experiments.

4 This table that is also in your handout, a table
5 of contents of his report, so you can see all the items
6 which are addressed in his report and which will be
7 reproduced in our final report.

8 MR. CATTON: He concluded it was about one-half
9 the core.

10 MR. ZUBER: Forty tons.

11 MR. CATTON: Less than half. The temperature is
12 2,500 degrees?

13 MR. ZUBER: Twenty-five, but the composition
14 changes. I think that is important for several reasons, and
15 you will see why.

16 [Slide.]

17 This is information we had. We had to analyze
18 what is available in order to set up the conditions. Let me
19 show you an example of applying the top-down approach to
20 obtain top-down analysis. We formulated the problem,
21 Wulfgang and I did this. We formulated the problem in terms
22 of conservation of steam, hydrogen, water liquid, and debris
23 conservation of mass. Conservation of energy for steam,
24 hydrogen mixture, water and liquid and energy balance of the
25 water liquid interface and gas-liquid interface.

1 Then we work with these equations and derived the
2 pressure rate equations. I shall discuss it in a moment.
3 We used this pressure equation to obtain the scaling groups
4 which were expressed in terms of time ratio, and from this
5 we obtained the scaling. This is what is important
6 phenomena, where we have to put our attention and where we
7 have to put our money. So, this is the result.

8 [Slide.]

9 I will show you just the equation to show you that
10 what I am saying exists. It is in the report. This shows
11 you just how we addressed the problem of water in the
12 cavity. We have here debris, we have hot gas, we have a
13 liquid which may be subcooled. The debris can radiate to
14 the interface, the gas can transfer energy by radiational
15 and convection to interface. You have a transport due to
16 the vapor which is vaporized. You have an transport to the
17 interface with the fluid, and you have heating of the fluid
18 because it's subcooled. The mass and energy balance is
19 here. This is something that we used to formulate the
20 problems.

21 [Slide.]

22 The pressure equation is shown on this slide. Let
23 me tell you and identify the terms so that you can see what
24 it addresses. I won't discuss each term. Pdt is the rate
25 of pressure change WG is the volume of gas. The first term

1 here accounts for the enthalpy of the steam and the
2 hydrogen. This is the enthalpy output of the cavity of the
3 steam and hydrogen. Item three is the gas structure heat
4 transfer, this is the area of the structures, temperature of
5 gas and temperature of the structure.

6 This is debris to gas heat transfer, debris of
7 temperature of the debris in gas, and this is the area for
8 transfer of the debris to gas. Item number five is the
9 zircalloy oxidation. It has two terms. The steam gas is
10 moving through the pellets and transports in enthalpy. This
11 is a loss to the mixture of the gases. Hydrogen is coming
12 out of the pellets due to the reaction with the given flow.
13 This is the balance of energy at interface and reduction
14 occurs in the pellet.

15 Zero is the area of the zirconium available for
16 the oxidation in the pellet. This term here is due to
17 water, this is the enthalpy flow of the saturated operation.
18 This is the heat transfer from the gas to the interface, and
19 this is the interfacial area between the gas and liquid.
20 Each process has a different area. This is the reason you
21 really have to look totally to address the problem.

22 This is the PtV term due to moving the liquid.
23 This is the PtV term due to moving the debris, and this is
24 the most interesting quantity that came as a final result.
25 Because the hydrogen doesn't have the same density of the

1 steam, as you generate hydrogen there is a PtV due to
2 hydrogen generation. This term accounts for the difference
3 in density between the hydrogen and steam.

4 [Slide.]

5 Let me just show you a type of equations we get --
6 we put these equations in non-dimensional form. We obtain
7 the pie groups for different assumptions. Let me just
8 illustrate what we get. For example, the effect of
9 oxidation zircalloy is given in this group here. These are
10 the parabolic rate equations. This is the diameter of the
11 particle. This is the initial temperature of the debris,
12 and this is heat of reaction. This quantity here accounts
13 for the amount of the debris which is melted which may be in
14 droplet forms and the amount of zircalloy. This is the
15 reason I am saying you cannot just take one problem and look
16 at it, you have to formulate it globally and look in detail
17 at each step. This is all pie ratios are of this form here.

18 [Slide.]

19 I will not discuss them. The rest of them are
20 reproduced in the report. What I will show you what we did
21 on the bottom-up scaling because we found out, of course,
22 this was particle size was important and then we analyzed
23 detail. This was done by Ishii and Sal Levy. We looked at
24 the corium discharge modes, corium impingement and spreading
25 in the cavity, cavity flow conditions, and corium

1 entrainment and droplet size.

2 Once we have established what is important, then
3 we focus in more detail on the important phenomena. In
4 discharge modes we looked at the single jet breakup, two
5 phase jet breakup, jet breakup length and droplet diameters.
6 In the corium impingement we looked at the corium jet and
7 droplets impinging on the flow, and the spread out in
8 thickness.

9 Here we looked at the conditions in the cavity,
10 the conditions. The final thing we obtained inception of
11 entrainment, transient entrainment rate, and droplet size.

12 [Slide.]

13 I will not go into details, but you have in the
14 handout. You have table which summarizes the results. Let
15 me just show you one thing, for example, that Sal obtained.
16 This is correlation and this is scaling factor, this is
17 represents entrainment parameter, and this is correlation of
18 the data. There is additional data in your handout. This
19 is something that we obtained.

20 You can ask me now what did we do with it. Well,
21 we formed the pie groups. This is not in your report for
22 one reason, that this was not reviewed by the group. What I
23 will tell you is my opinion and this is opinion of BNL who
24 did these calculations. Having these pressure calculations
25 we obtained the pie groups and we obtained the scaling.

1 This shows the results. This shows the effect of heat
2 transfer of liquid, water and zirc oxidation.

3 Here we have six particle sizes; one millimeter,
4 six and 20. The reasons we worked with six and 20 is that
5 analysis of Ishii and correlations available indicate that
6 the particles in the reactor will be in this range here.
7 Pie PG means heat transfer from debris to gas. It has for
8 one particle has a volume of 14. That is the largest one
9 that it can have, otherwise it will be smaller for this
10 particle size.

11 Gas to structure is -- this you can completely
12 neglect with respect to this thing here. If you change the
13 size, these are the volume that you have. This is important
14 to discuss, there are two terms with the water. We first
15 looked at the effect of heat transfer from gas to the liquid
16 by convection and radiation. We are now looking also at the
17 effect of radiation from the debris to the gas or to the
18 interface.

19 There is a mechanical term which is much smaller
20 than this, but let me say something about this term here.
21 This is the minimal value that we can have if you want
22 conservative. In fact, it can be much larger than this.
23 This calculation was performed only for this calculation you
24 have 40 tons of melt. The amount of water was only five
25 percent in the cavity and you obtain a quantity of two.

1 Sandia has performed some experiments where the cavity was
2 half full which means ten times larger than this. This
3 number then becomes much larger.

4 What I am trying to say is that you cannot perform
5 an experiment and take any arbitrary amount, either of
6 solids or liquid. You have to do it on a consistent basis
7 and address it and perform experiments in a consistent
8 basis. That is number one. Number two is also the effect of
9 droplets as they evaporate the droplet size decreases and
10 operation gets faster and faster. Therefore, this
11 contribution of water will be even larger than this thing
12 here.

13 What I am really caution about this is while
14 conservative, it may be much larger depending how much water
15 you have and the operation. The effect of zirc oxidation
16 there are two terms. One is the thermal and the other is
17 mechanical. This one comes from the PtV term and this comes
18 from the heat of reactions on order of one and one and one-
19 half.

20 What can we do with this? We can say fine, I can
21 perform experiments and verify this or I can use different
22 assumptions and do sensitive analysis on any one of these
23 numbers. You don't need a code, you need a slide or hand
24 calculator, and you can perform sensitivity for different
25 assumption of heat transfer coefficient or of sizes, and you

1 can establish a rationale how to approach something. Then
2 what you want to verify in experiments.

3 This gives you the scaling criteria, and gives you
4 the roadmap, the hierarchy to approach something. Of course
5 we can neglect heat transfer, here we can neglect the PtV
6 term for water and so on. Let me show you one more thing
7 and then I will have to quit.

8 MR. CATTON: About ten more minutes.

9 MR. ZUBER: Okay, good. We were interested to
10 compare the amount of how important this chemical reaction
11 versus heat transfer to debris, because debris has to effect
12 one to transfer and one to zircalloy reaction. We formed
13 this ratio here. You can see that as the droplet size
14 decreases the importance of the chemical reactions gets more
15 and more important compared to the debris heat transfer.
16 The point is, what we found out from Ishii analysis is that
17 in the reactor the particle size probably will be in this
18 range here.

19 Essentially, this would indicate that chemical
20 reactions using parabolic the way we used it, is unimportant
21 and much less important than debris in addressing the debris
22 would be probably more important. We can perform another
23 sensitivity analysis and use different reaction rates to see
24 what happens to these numbers here. It provides a way to do
25 sensitivity analysis in a very efficient way.

1 MR. CATTON: If I have a lot of water in that
2 cavity then the sizes are going to be measured in microns.

3 MR. ZUBER: Put it this way, if you have lots of
4 water it is completely different ballgame. I think that is
5 what is important. Let me say one more thing. Equations
6 which we used we didn't use the fragmentation. I think
7 these numbers for water may even be larger than that. Even
8 in this conservative way they approach -- if I have a cavity
9 half full of water it will be more important than heat
10 transfer.

11 [Slide.]

12 Let me tell you what is in the report and what
13 will be available. This is your handout number four. The
14 report is divided in two volumes. The first volume presents
15 the general analysis and application to DCH, and volume two
16 has all the appendices. Everything what we have here is the
17 integrated structure, general application, hierarchy
18 approach. This is all typed and finish and 3.4 is in
19 typing. This part three of volume two will be ready
20 probably by Monday or so.

21 In part two is the application to DCH. This is
22 what I am working on now. I have input from other people
23 and have to put it in the kind of integrated form. This
24 will be finished by the end of the month. The plan that I
25 am shooting for is to finish the volume one by the end of

1 the month, to have it reviewed by the Committee. I will
2 retire at the end of the month, that's what I said, but I
3 would like to get together on my own free time and not
4 charge the government to review with the Committee whether
5 any change be made in the final draft. Then we are planning
6 to have this in mid-January. If the Committee has no
7 problem, volume one can be published.

8 Volume two, the appendices provide more
9 information. This, I have to put together to get from these
10 other people in a readable form. This will be available in
11 January, toward the end of January. As far as the final
12 results of the program, everything, this is in volume one
13 and should be available at the end of the month. If the
14 Committee reviews it in the middle of January the draft
15 should be out by the middle of January.

16 MR. CATTON: You are going to do that for nothing?

17 MR. ZUBER: To me that was always a technical
18 challenge. I would like to have the opportunity to do it at
19 no cost.

20 [Slide.]

21 Let me say what we did accomplish. I think we
22 presented a methodology that is auditable, that is
23 traceable, that is systematic and comprehensive. We
24 presented methodology which can be applied to severe
25 accidents. The reason it works is because we use this time

1 ratio and provide the hierarchy. It is sufficient because
2 we address it in a two-tier, the top-down and the bottom-up.

3 Every point in the analysis can be tested,
4 discussed, argued. There is no arm waving. I mean,
5 everything is there on a piece of paper and people can
6 evaluate it, agree or disagree but there is something to be
7 discussed and assessed. I think this is the presentation.
8 If you have any question I will be very happy to try to
9 answer them, or any criticism, put it this way.

10 MR. CATTON: The first paper I heard Novak Zuber
11 give was in 1961 at the International Heat Transfer
12 Conference, and it was interesting. There was a person
13 named Ralph Stein who challenged him, and there were a
14 couple of students who were from the University of Colorado.
15 Novak got so excited in answering, one student was holding
16 the microphone trying to keep it in front of him and another
17 one was in the back running the volume up and down trying to
18 keep it right. I decided then that boiling was not for me.

19 MR. ZUBER: You have a better memory than I do. I
20 have other recollections.

21 MR. CATTON: If there are no questions, --

22 MR. WILKINS: Can I make a comment? I have known
23 this gentleman for a few years, maybe not as long as you
24 have, and I have always been impressed by his understanding
25 the depth of his understanding of the various concepts. I

1 never understood a pie group as well as I do now, after he
2 explained it today. I have heard about dimension groups and
3 all that, and I have always thought as a mathematician I
4 didn't need all that nonsense because I could write down the
5 differential equations and invent my own dimension groups.

6 I must say this discussion today has been
7 masterful.

8 MR. CATTON: But as a mathematician you certainly
9 have dealt with problems that have multiple scales.

10 MR. WILKINS: Absolutely.

11 MR. CATTON: Now you know where they come from.

12 MR. WILKINS: And now I have a whole lot better
13 appreciation for what mathematicians call ascentotic.
14 Ascentotic, they want to let all the other scales go to zero
15 or infinity depending on how you look at it.

16 MR. ZUBER: Thank you. Let me say that I would
17 like to leave a message to this group or whoever is going to
18 do the work. Ivan is in this field anyway. You need a two-
19 tier approach. There is no way you can address all this.
20 You have to address in a globality to evaluate what is
21 important. You have to make it tractable. This is a top-
22 down approach.

23 In order to have a good feeling in your belly that
24 you addressed the right things, you have to have this
25 scaling hierarchy and identify the important thing and hit

1 them very hard. Using this method we can go in front of any
2 group, physical society, we can always present a rationale
3 which is defensible. I think this method provides it.

4 MR. CATTON: I also noticed you have shifted in
5 your position. My recollection is that in the beginning you
6 were an advocate of top down and weren't too sure about the
7 need from the bottom up.

8 MR. ZUBER: No. The top down gives you the
9 roadmap. I could not even start from -- if I know the
10 problem I can solve it from something. If you start
11 something which is really kind of -- look, people said you
12 cannot first devise a methodology and I could read you
13 letters. I didn't bring them here but I could read letters
14 that this is the most stupid thing to propose, to do a
15 scaling methodology for severe accidents. Well, it can be
16 done.

17 You have to do it two-tier. You have to address
18 top down to tell you what is important to provide you this
19 scaling rationale, hierarchy, and they you use bottom. We
20 did the same thing on the LOCA on uncertainty. The concept
21 is not new. We use it before, except we applied it to the
22 scaling.

23 MR. SIESS: I tried to understand the scope of
24 applicability. The document I have is headed integral
25 structure and scaling methodology for severe accident

1 technical issue resolution which is certainly a long title.
2 There must be some other limits on it. It is limited only
3 to thermal hydraulic issues? I can't quite picture how to
4 apply this to questions of containment integrity for
5 example, which to me is a severe accident technical issue
6 resolution.

7 MR. ZUBER: Let me say, I show you how the
8 pressure changes due to all these factors. You can now
9 quantify experiments --

10 MR. SIESS: I'm sorry --

11 MR. ZUBER: How the pressure changes. I give you
12 the rate of pressure --

13 MR. SIESS: I am interested in the integrity of
14 the containment, the structural engineering issue.

15 MR. ZUBER: This will be a different conservation
16 equation. You can do the same methodology you can apply it.
17 The same thinking. I applied it here was to metallurgy
18 because we have different composites, to heat transfer, mass
19 transfer and chemical reactions. This is what governs the
20 rate of pressure change.

21 If you want I will address another. Structural
22 aspects, these can be also done by pie groups but this was
23 not the --

24 MR. SIESS: I have been doing things wrong all my
25 life them.

1 MR. ZUBER: No, look. There are different ways to
2 skin a cat. One can approach it in this way also.

3 Actually, people use dimension groups in structures.

4 MR. WILKINS: You have still to conserve energy.

5 MR. ZUBER: That's right. You have to --

6 MR. CATTON: I think that you will find scale sets
7 that some of these things you can trash.

8 MR. WILKINS: Of course, and that's exactly what
9 his top down method tells you how to identify.

10 MR. ZUBER: But you have the -- the thing is that
11 you have to express it in terms of time ratio. Then you
12 have the same meter to measure everything. I think this is
13 the -- then you establish the hierarchy and you can argue
14 why should I preserve this, why are my experiments in this
15 way. It tells you that you cannot put half of the water
16 without really thinking what are the consequences. It gives
17 you a rationale how to justify every step in your
18 experimentation and analysis. MR. CATTON: Thank you,

19 Novak. I look forward to getting the report.

20 MR. ZUBER: I am sure you will.

21 MR. SHERON: Thank you. I am Brian Sheron, from
22 Office of Research. What I would like to talk about very
23 briefly is the use of the SASM approach that Novak has
24 developed in our severe accident research program and the
25 role in severe accident issue resolution. I think there is

1 a little bit of a difference of terminology here when we
2 talk about what a severe accident issue is.

3 [Slide.]

4 There is issues and there are issues, okay? If
5 one is talking about the question of how can I accurately
6 calculate the pressurization of containment due to direct
7 containment heating using a validated computer code, that is
8 an issue. That is a technical issue. We have used the word
9 severe accident issue in the sense of should this agency do
10 something about direct containment heating and, if so, what
11 is it that should be done. That is a more global issue
12 which involves a much broader set of questions than what
13 SASM would address.

14 MR. CATTON: Isn't there an equivalent issue in
15 how does the Sandia experiment direct this in both codes or
16 the experiments?

17 MR. SHERON: I am going to touch on this, so let
18 me go --

19 MR. CATTON: There are both of them -- I don't
20 think you should separate them.

21 MR. SHERON: They are not separable.

22 [Slide.]

23 I think Ivan said you weren't really sure about
24 how all this came about. Back when I took over the severe
25 accident area which was in June of 1988, we were concerned -

1 - not just myself but Mr. Beckjord, Dr. Speis and a number
2 of other people -- about the scaling rationale for in
3 particular the SURTSEY test that were being run. We weren't
4 sure that, for example, the proper mass was being used in
5 the experiments with the initial energy of the thermite melt
6 was properly scaled in a sense that when and if one takes
7 your computer code and validates it against the experiment,
8 what confidence did we have that we could extrapolate up and
9 apply that code confidently to a large plant.

10 Quite honestly, I didn't feel I got a very good
11 answer from the contractors or the like with regard to the
12 scaling rationale. That is not to say that a scaling
13 rationale was not done, but I think it was not done at the
14 proper depth or understanding. I think there was a much
15 more classical approach taken in terms of perhaps the usual
16 dimension was types of groups and numbers and so forth.

17 Based on that I asked Novak, who had just finished
18 up the CSAU method to -- again, that was basically a scaling
19 exercise I think which was how can we quantify the
20 uncertainty in our computer codes which involves computer
21 codes which are validated against scaled experiments. We
22 were trying to scale them up to a large plant and estimate
23 the uncertainty in the answer.

24 My question to Novak was to look at the problem
25 and first to determine if a general scaling methodology for

1 severe accident experiments could be developed, and second,
2 if he concluded that one could develop such a methodology to
3 indeed go ahead and do it. The objective was obviously to
4 make this methodology available to all of the people around
5 the country involved in severe accident experiments, in
6 particular our contractors, so that they could use it as
7 guidance for when they were developing their experiments.

8 As you know, Novak formed a technical program
9 group. He pulled together I think it was 17 experts from
10 various fields relating to scaling and severe accidents, so
11 there was a pretty broad spectrum of expertise on the group.
12 As I said before, the experiments that prompted my real
13 concern in this area were the SURTSEY experiments on the
14 direct containment heating. Because I had sort of looked
15 into that, I thought that since that was pretty much my
16 primary concern at the time was should I continue doing
17 experiments in that facility or not, I told Novak that I
18 thought that DCH would serve as a very good example on
19 demonstrating the applicability of the general methodology
20 that he was to develop.

21 The charter of his group, the TPG, was to develop
22 a general methodology with an example use of that
23 methodology, keeping in mind that we still had many
24 experiments going on around the country and we would
25 certainly expect each of those experimenters running those

1 experiments to be responsible for developing the particular
2 scaling analysis for their experiment. I still -- the
3 accident evaluation branch which manages the severe accident
4 research program would still be primarily responsible for
5 the review and approval of contractor tests and the basis
6 for those tests.

7 [Slide.]

8 Sandia, for the SURTSEY facility, they are still
9 in fact responsible and I hold them responsible for all
10 facets of the testing which includes the basis for the
11 tests, the scaling rationale that would form the basis for
12 the tests, conducting the tests and associated environmental
13 safety and health which basically means that when they run
14 these tests they are responsible for making sure that they
15 don't blow something up or the like.

16 Although Novak's group as you just saw developed
17 an example scaling group for DCH, Sandia is currently
18 developing their own scaling groups to support the proposed
19 SURTSEY tests. This is not to mean that there is something
20 that greatly different here. Sandia participated very
21 extensively in the TPG and we told them they were to be
22 utilizing the methodology developed by the TPG as it evolved
23 in developing the scaling factors for SURTSEY.

24 The plan is to review the SNL scaling report when
25 we receive it. We are supposed to have a draft in on Monday

1 experiments to be responsible for developing the particular
2 scaling analysis for their experiment. I still -- the
3 accident evaluation branch which manages the severe accident
4 research program would still be primarily responsible for
5 the review and approval of contractor tests and the basis
6 for those tests.

7 [Slide.]

8 Sandia, for the SURTSEY facility, they are still
9 in fact responsible and I hold them responsible for all
10 facets of the testing which includes the basis for the
11 tests, the scaling rationale that would form the basis for
12 the tests, conducting the tests and associated environmental
13 safety and health which basically means that when they run
14 these tests they are responsible for making sure that they
15 don't blow something up or the like.

16 Although Novak's group as you just saw developed
17 an example scaling group for DCH, Sandia is currently
18 developing their own scaling groups to support the proposed
19 SURTSEY tests. This is not to mean that there is something
20 that greatly different here. Sandia participated very
21 extensively in the TPG and we told them they were to be
22 utilizing the methodology developed by the TPG as it evolved
23 in developing the scaling factors for SURTSEY.

24 The plan is to review the SNL scaling report when
25 we receive it. We are supposed to have a draft in on Monday

1 I was told now. We will ask the staff -- I want Novak to
2 take a look at it as well as people in Farouk's branch to
3 look at it, as well as asking some selected outside experts
4 which would most likely come from the TPG group to take a
5 look at this report and give us their comments. Based on
6 the comments that we receive, we will get back to Sandia and
7 try to resolve any difficulties or differences and
8 hopefully, we will be able to provide them with an approval
9 to start the DCH testing again in SURTSEY.

10 If everything goes according to plan, SNL said
11 they would be ready to start testing in March of 1991 with
12 the actual scale DCH test. Novak told you the schedule for
13 the SASM methodology report. The TPG is basically going to
14 hopefully stay together until that is finished, and that
15 group would be dissolved. We expect completion hopefully by
16 the end of the year. Novak told you what the schedules is.

17 MR. CATTON: You are going to hold it together
18 until January --

19 MR. SHERON: I will hold it together until they
20 have done their final whatever is necessary to complete the
21 report. MR. CATTON: Good.

22 MR. SHERON: When Sandia runs the first tests in
23 SURTSEY hopefully in March, obviously, we are going to have
24 to take a look at them very close to determine whether the
25 scaling analysis is indeed adequate and whether we have to

1 make any adjustments to the tests inn terms of the future
2 tests.

3 We will also be running separate effects tests
4 which we are trying to get done hopefully in the first half
5 of 1991. These have to be factored into the overall scaling
6 analysis. What these separate effects tests are that in the
7 SURTSEY facility when you run the discharge into the
8 simulated cavity, you cannot measure the entrainment, de-
9 entrainment and fragmentation during the process, during the
10 blowdown process. In fact, the way you try and come up with
11 a correlation for the entrainment and the fragmentation and
12 the like is to, after the test is over you go in and measure
13 the oxidation, the hydrogen, you look at the particle sizes
14 of the material and try and infer what those parameters were
15 and see if there is an entrainment model in the literature
16 that gives you reasonable agreement with the test results.

17 The question is, you may be able to do that but
18 there is a big question regarding scale up. So, what we
19 would like to do is run some separate effects tests to try
20 and get a better handle on entrainment, de-entrainment and
21 fragmentation process. We do have RFP's out right now and
22 are soliciting proposals to do those tests.

23 MR. KERR: Brian, in what sense can one determine
24 the adequacy of scaling after the test; what is it about the
25 test that will permit you to determine the adequacy of

1 scaling?

2 MR. SHERON: I think you can look at the processes
3 that took place. As Novak pointed out, you can neglect
4 certain processes. If you believe the equations that are
5 written down you can neglect certain processes. If that's
6 the case, then you should be able to look at the results and
7 somehow infer that you indeed picked the right pie groups
8 for example.

9 MR. KERR: Okay, I see what you mean.

10 MR. SHERON: Novak, I think you wanted to add
11 something to that?

12 MR. ZUBER: What one can do is this, for example,
13 you run in a given geometry let's say SURTSEY, you run a
14 test and change in the systematic way the amount of water or
15 amount of temperature in the energy of the debris and see
16 whether the results predict -- forcing that. Then you can
17 perform for example, one test without any water and you put
18 effect of water in the step way to see how this contributes.

19 This really forcing the general point of view.
20 The second thing what would be really good then is to
21 perform similar tests with initial scale conditions in two
22 geometries; one in SURTSEY and one somewhere else or maybe
23 we can get the foreign -- the NRC may get a foreign facility
24 and do this.

25 Then you have a different initial conditions and

1 initial scale. In my judgment -- I mentioned this at this
2 last meeting of the Subcommittee last spring was -- in that
3 approach if you coordinate the effort on three scales or two
4 scales and really specify the conditions around this testing
5 parallel, my judgment was that this problem could be put to
6 rest in one year. I accept bets in terms of bottles of rum.
7 I would really bet a bottle of rum that this could be done
8 in this way.

9 Thank you.

10 MR. SHERON: In fact, we are running different
11 scale tests at Argonne National Laboratory. Sandia tests
12 are one-tenth linear scale. The tests at Argonne are one-
13 thirtieth scale using thermite. The objective is to run
14 tests at two different scales using the same scaling
15 parameters and rationale, and to see if indeed we get the
16 right results so that we can at least confidently
17 extrapolate up from the one-thirtieth to the one-tenth
18 scale.

19 MR. KERR: Thank you.

20 MR. SHERON: Let me talk a little bit about how we
21 use SASM in the resolution of DCH as a severe accident
22 issue. Number one, DCH is a complex and multi-faceted
23 issue. It is not just a matter of ejecting high pressure
24 melt into the containment. They are just one facet of the
25 whole issue. As I said before the overall issue is, what is

1 the risk associated with direct containment heating
2 phenomena and what, if any, plant modification should be
3 made to reduce this risk.

4 This is the real question that we are trying to
5 address with the research. SASM only provides the basis for
6 assuring that the experimental data that we get from our
7 experiments is meaningful. For example, in other words,
8 that it is at the proper scale, that the appropriate initial
9 boundary conditions have been chosen. In fact, when we do
10 get the data we can confidently apply it to validate our
11 codes and then extrapolate these codes up to the large
12 plant.

13 Right now for DCH I think the only fix -- if I can
14 use that term -- is intentional depressurization. This is
15 where the operator would intentionally open a relief valve
16 to reduce the pressure so that at the time of lower head
17 failure you would not have a very high pressure steam
18 driving the melt into the containment which produces the
19 strong interactions in the containment, the heat transfers
20 and the hydrogen which produce the loads -- temperature and
21 pressure loads which ultimately fail a containment.

22 MR. CATTON: When you get down to 40 percent of
23 the core, DCH is not a problem, is it? I thought it was,
24 only for higher fractions?

25 MR. SHERON: Well, again, this gets into the

1 question of -- if the codes can be validated and then if the
2 codes can show us that 40 percent doesn't really produce a
3 large pressurize in the containment that would challenge the
4 containment, then you are correct. Right now the
5 indications are that that's true.

6 MR. CATTON: We may not need a fix.

7 MR. SHERON: We still have the question of
8 understanding the in-vessel core melt progression.

9 MR. CATTON: I understand.

10 MR. SHERON: There is an uncertainty associated
11 with that. Forty percent is not a clean number. There is
12 an uncertainty on that.

13 MR. CATTON: I read Sal's report, and it has
14 assumptions, no question.

15 MR. SHERON: Right now no operating PWR's call for
16 the operators to intentionally depressurize the primary
17 system when no AC power is available. This is very
18 important. I called up all three vendors and they all
19 confirmed that this was indeed the case. The real question
20 that we are trying to answer is, is intentional
21 depressurization a cost beneficial and practical fix for
22 direct containment heating. That is, should we require
23 intentional depressurization.

24 MR. KERR: Indeed, it's probably illegal for them
25 to depressurize -- I'm sorry, that's depressurizing the

1 reactor vessel.

2 MR. SHERON: Yes. Currently the approach that we
3 would like to take in addressing this overall issue is one,
4 to establish the likelihood of accidents that proceed to
5 core melt at high pressure. I think 1150 gives us real good
6 insights into this, and there's really not much more effort
7 that needs to be done right now.

8 The second piece of the puzzle here is to
9 establish the likelihood that the system would be
10 depressurized prior to lower vessel head failure at high
11 pressure. That is, what is the probability that the primary
12 system will be pressurized during this high pressure melt
13 down process due to such things as a stuck open safety or
14 relief valve, keeping in mind that this thing is opening and
15 closing all the time under conditions that are not within
16 the design base. There is, in fact, a likelihood that
17 during this cycling this valve could stick open, in which
18 case you would get a depressurization.

19 You could also get a pump seal failure which would
20 produce a depressurization. The operators could, in fact,
21 ever though they don't have specific procedures right now in
22 a severe accident, could indeed intentionally depressurize
23 the primary system.

24 MR. CARROLL: Let me comment on that, Brian.
25 Actually, initiating of feed and bleed on PWR's is based on

1 dry steam generators.

2 MR. SHERON: They will not initiate feed and bleed
3 if no AC power is available. That is the difference. They
4 will initiate feed and bleed if they have confirmation of AC
5 power being available. What they say is that right now the
6 philosophy is that if I bleed without AC I am depleting the
7 inventory faster. Therefore, I will lead to a core melt.

8 MR. CARROLL: Okay. The last item is the creep
9 rupture failure of the primary piping. That is that once
10 you start to uncover the core you get very hot gases coming
11 out of the core which will migrate to the colder surfaces
12 just due to the buoyancy differences. We have done a number
13 of calculations, and there is a lot of evidence that says
14 that the surge line will probably heat up and at most likely
15 at 2,500 pounds of pressure, would experience a creep
16 rupture failure.

17 There is experiments at Westinghouse, one-seventh
18 scale to validate the natural circulation calculations that
19 we are doing. The overall effort is to say taking this as
20 an integral type of approach, what is the likelihood to come
21 up with a number that the system would be depressurized
22 prior to lower head failure.

23 Last is where SASM comes in, is to establish the
24 likelihood that high pressure melt injection will in fact
25 lead to containment pressures in excess of the ultimate

1 pressure capability of the containment.

2 The other pieces of this whole puzzle here is one,
3 is then we would have to show that the reduction in
4 containment failure probability, if intentional
5 depressurization were to be required, we would have to show
6 that probability reduction for containment failure and
7 establish what the cost benefit would be before we would
8 consider going to the Commission with such a requirement on
9 the industry.

10 Of course, as you know, we would have to somehow
11 address the generic applicability of these analyses to all
12 the plants keeping in mind, as you know, there are six CE
13 plants that do not even have a PORV. Lower head failure
14 mechanisms would be different because CE plants do not have
15 lower head penetrations, whereas the Westinghouse plants do.

16 MR. CARROLL: Not true.

17 MR. SHERON: Not true?

18 MR. SHAWMON: True for many of them, but not true
19 for all of them.

20 MR. SHERON: Some do but some don't. In other
21 words, there are plants that don't have lower head
22 penetrations. As I said before, item three would be
23 determined through the use of code analyses using codes
24 validated against applicable experiments. This is where
25 SASM really will be applied, in ensuring that these

1 experiments can be used for extrapolation to the large
2 plants. That's my presentation. Are there any questions?

3 MR. CATTON: The big question is the in-vessel
4 melt progression. Can you address that, and what the
5 experiments ought to be?

6 MR. SHERON: Yes. As a matter of fact, we would
7 like to --

8 MR. SIESS: Excuse me. Ivan, I am hearing the
9 answers to your questions but I am not hearing the
10 questions.

11 MR. CATTON: I'm sorry.

12 MR. SIESS: I have been figuring them out, but I'm
13 tired.

14 MR. CATTON: I am not sure that I can remember the
15 question. The in-vessel melt progression and use of a
16 scaling approach to try to establish what the experiments
17 ought to be or how you ought to run the ones that you plan.

18 MR. SHERON: We do have an ongoing program on in-
19 vessel melt progression as you know, and it's probably more
20 difficult than this area because of the need to scale -- in
21 other words, the scale itself, you can't do a whole core
22 obviously. We are doing smaller scales. The melt
23 progression, as you know for PWR, one would predict forming
24 a -- obviously you need something that is large, so we are
25 looking at small chunks of this.

1 We are right now in the process of putting
2 together a complete review of the in-vessel core melt
3 research program. What we would like to do would be better
4 define what more is needed, whether we have done enough in
5 certain areas like the early phase, whether we should
6 concentrate more on the late phase, whether the experiments
7 that are going on right now will indeed adequately address
8 the issues which I think gets to your question.

9 MR. CATTON: That is what I am getting at.

10 MR. SHERON: We want to put together a group of
11 experts in this area that will help us look at this whole
12 thing in a big picture, and try to put together then a
13 comprehensive research program on in-vessel core melt such
14 that everybody would have confidence that by carrying out
15 this program we would, at the end, have computer codes that
16 have been validated against experiments that are defensible
17 and as Novak said, auditable and whatever.

18 Obviously, we have different experiments to look
19 at BWR progression versus the PWR.

20 MR. SHEWMON: As you know, there is a fair amount
21 of evidence that whether you have PORV's or not, that you
22 are going to have a rupture of the containment before you go
23 through the bottom of the vessel, whether it is tubing in
24 the steam generator or something else just from heat
25 transfer up there.

1 MR. SHERON: Yes.

2 MR. SHEWMON: Is that still part of your program,
3 or you wouldn't like it because that's not a controlled --

4 MR. SHERON: I think that was the --

5 MR. SHEWMON: It could have been. I ducked out.

6 MR. SHERON: If you look at this viewgraph, item
7 two right here, we have a comprehensive program looking at
8 where the primary system might fail due to the creep rupture
9 failure due to this high temperature circulation.

10 MR. SHEWMON: Fine.

11 MR. CATTON: The Westinghouse one-seventh scale
12 doesn't include a steam generator, does it?

13 MR. SHERON: It does.

14 MR. CATTON: The scaling of the hot plenum and
15 cold plenum of the steam generator become very important to
16 the tubes, diameters and all sorts of things. I would think
17 that you would want to run it through one of these scaling
18 type exercises before you really get too far along.

19 MR. SHERON: I actually think there was a scaling
20 analysis done on that. Remember, these tests were sponsored
21 by EPRI. These are not our tests.

22 MR. CATTON: At that time we had a grant from
23 EPRI. I recollect the early scaling that was done by Squire
24 -- David Squire. Beyond that, I don't know of any scaling
25 that was done. At that time the concern was strictly the

1 core. There was not as much concern for the steam generator
2 tubes at that time. I don't know -- if there has been a
3 subsequent scaling and we are running out of time, I would
4 like to see it.

5 MR. SHERON: I would like -- Bob, do you have
6 something?

7 MR. WRIGHT: Bob Wright, Action Evaluation Branch.
8 At Westinghouse they did a rather extensive scaling job on
9 those experiments including the steam generator section and
10 recirculation, scaling the reduced number of tubes to give
11 the right thermal hydraulic property. I am not on top of
12 the results, but it was a careful job. There have been some
13 reviews, but also some questions.

14 MR. CATTON: I would like to see that scaling
15 analysis.

16 MR. SHERON: That area right now, the whole
17 natural circulation is with Dr. Shotkin's branch. I would
18 volunteer the --

19 MR. CATTON: He works for you, and I assume that
20 you could get it for us.

21 MR. SHERON: I am volunteering that he will come
22 down if you would like to a Subcommittee meeting --

23 MR. CATTON: What I would like to have is the --

24 MR. SHERON: Would you like us to provide you with
25 the document?

1 MR. CATTON: Provide me with the document first.

2 MR. SHERON: Let me see what we can do.

3 MR. CATTON: I would also be interested in your
4 schedule for looking at the in-core melt progression.

5 MR. SHERON: When are we supposed to get a group
6 together, Farouk? We are supposed to have a draft report in
7 the end of December. Are there any other questions?

8 [No response.]

9 MR. CATTON: I don't see any. Thank you, Brian.
10 I will give it back to you, Mr. Chairman.

11 MR. MICHELSON: Okay, gentlemen. The next agenda
12 item is the preparation of ACRS reports.

13 [Whereupon, at 4:10 p.m., the transcribed portion
14 of the meeting concluded.]

15

16

17

18

19

20

21

22

23

24

25

REPORTER'S CERTIFICATE

This is to certify that the attached proceedings before the United States Nuclear Regulatory Commission

in the matter of:

NAME OF PROCEEDING: 368th ACRS General Meeting

DOCKET NUMBER:

PLACE OF PROCEEDING: Bethesda, Maryland

were held as herein appears, and that this is the original transcript thereof for the file of the United States Nuclear Regulatory Commission taken by me and thereafter reduced to typewriting by me or under the direction of the court reporting company, and that the transcript is a true and accurate record of the foregoing proceedings.

Mary C. Larkin

Official Reporter
Ann Riley & Associates, Ltd.

NRR STAFF PRESENTATION TO THE ACRS

1

SUBJECT: HYDROGEN GAS BUILDUP IN CHARGING SYSTEM
AUGUST 22, 1990
(INTRODUCTION AND FOLLOWUP ACTIONS)

DATE:
DECEMBER 7, 1990

PRESENTER:

M.A. CARUSO

PRESENTER'S TITLE/BRANCH/DIV:

SECTION CHIEF, REACTOR SYSTEMS BRANCH, NRR

PRESENTER'S NRC TEL. NO.:

492-3235

SUBCOMMITTEE:

NRR STAFF PRESENTATION TO THE ACRS

SUBJECT: HYDROGEN GAS BUILDUP IN CHARGING SYSTEM
AUGUST 22, 1990
(EVENT PRESENTATION)

DATE: DECEMBER 7, 1990

PRESENTER:
DAVID C. FISCHER

PRESENTER'S TITLE/BRANCH/DIV:
SECTION CHIEF, EVENTS ASSESSMENT BRANCH, NRR

PRESENTER'S NRC TEL. NO.:
492-1154

SUBCOMMITTEE:

SEQUOYAH UNITS 1 & 2
HYDROGEN GAS BUILDUP IN THE CHARGING SYSTEM
AUGUST 22, 1990

PROBLEM

THE LICENSEE IDENTIFIED HYDROGEN GAS BUILDUP IN THE CHARGING AND RHR CROSSOVER PIPING IN EXCESS OF THE AMOUNT IDENTIFIED IN THE WESTINGHOUSE LETTER TO THE LICENSEE.

CAUSE

LICENSEE ATTRIBUTED CAUSE TO:

- (1) INADEQUATE REVIEW OF IN 88-23, "POTENTIAL FOR GAS BINDING OF HIGH PRESSURE SAFETY INJECTION PUMPS DURING A LOCA,"
- (2) INADEQUATE REVIEW OF WESTINGHOUSE LETTER, TVA-88-825, "POTENTIAL GAS BINDING OF SI PUMPS," AND
- (3) LICENSEE DID NOT FULLY UNDERSTAND THE MECHANISMS IN WHICH HYDROGEN GAS MAY COME OUT OF SOLUTION.

DISCUSSION


- o AUGUST 22, 1990, UNIT 2 AT 70% POWER, CCP "A" OPERATING, CCP "B" IN STANDBY. T/S SURVEILLANCE BEING PERFORMED.
- o WHEN "B" PUMP WAS STARTED, OPERATOR OBSERVED FLUCTUATION IN PUMP'S FLOW AND AMPERAGE. SUSPECTED GAS BINDING. PUMP STOPPED, VENTED, AND RESTARTED.
- o LATER, LICENSEE IDENTIFIED GAS BUILDUP IN SUCTION PIPING OF IDLE CHARGING TRAIN (B-TRAIN) OF APPROXIMATELY 10 CU FT.
- o GAS BUILDUP ALSO EXISTED IN RHR CROSSOVER PIPING, BUT LICENSEE WAS NOT ABLE TO VENT THIS GAS BUILDUP (4.75 CU FT.).

- o LICENSEE HAD CONSULTED WESTINGHOUSE, AND DETERMINED THAT CONTINUED OPERATION WAS ACCEPTABLE PROVIDED GAS ACCUMULATION DOES NOT EXCEED 6 CUBIC FEET IN THE SUCTION PIPING TO THE CCP'S.
- o LICENSEE ANALYZED THE GAS TO BE 98% HYDROGEN.
- o LICENSEE CALCULATED THAT VENTING WAS REQUIRED EVERY 8 HRS. TO MAINTAIN HYDROGEN ACCUMULATION BELOW 6 CF WHILE AT POWER.
- o ON SEPT. 6, 1990, UNIT 1 EXPERIENCED NEAR-IDENTICAL EVENT, GAS WAS ALSO ACCUMULATING IN CCP SUCTION AND RHR CROSSOVER PIPING.
- o LICENSEE STATED THAT GAS FORMATION WAS A RESULT OF GAS STRIPPING BY THE CCP MINIFLOW ORFICES.
- o LICENSEE CONCLUDED THAT PROCEDURAL AND PLANT MODIFICATIONS WOULD BE NEEDED TO PREVENT THE ACCUMULATION OF HYDROGEN IN THE CHARGING AND RHR CROSSOVER SYSTEMS.

FOLLOWUP

- o IN 88-23, SUPPLEMENT 3, "POTENTIAL FOR GAS BINDING OF HIGH-PRESSURE SI PUMPS DURING A LOCA," TO BE ISSUED.
- o RSB HAS LEAD TO DETERMINE SAFETY SIGNIFICANCE AND ANY FURTHER GENERIC ACTION THAT MAY BE NEEDED.

Charging Pumps and RHR Crossover for SQN Units 1 & 2



NRR STAFF PRESENTATION TO THE ACRS

SUBJECT: HYDROGEN GAS BUILDUP IN CHARGING SYSTEM
AUGUST 22, 1990
(TECHNICAL EVALUATION)

DATE: DECEMBER 7, 1990

PRESENTER:
STEVEN M. MIRSKY

PRESENTER'S TITLE/BRANCH/DIV:
NRC CONTRACTOR, SAIC

PRESENTER'S NRC TEL. NO.:

SUBCOMMITTEE:

NRR STAFF PRESENTATION TO THE ACRS

SUBJECT: MSIV CLOSURE AT FULL POWER
AUGUST 19, 1990

DATE: DECEMBER 7, 1990

PRESENTER: G. A. BELISLE

PRESENTER'S TITLE/BRANCH/DIV:

CHIEF, TEST PROGRAMS SECTION, ENGINEERING BRANCH, RII
AIT LEADER

PRESENTER'S NRC TEL. NO.:

FTS 841-5596

SUBCOMMITTEE:

BRUNSWICK 2
MSIV CLOSURE AT FULL POWER (AIT)
AUGUST 19, 1990

PROBLEM

SCRAM WITH DEGRADED PERFORMANCE OF SEVERAL VALVES (SRVs, RCIC, FW).

CAUSE

VIOLATION OF PLANT PROCEDURE; ISOLATED INSTANCE.

SAFETY SIGNIFICANCE

UNNECESSARY CHALLENGE TO PLANT SAFETY SYSTEMS.

DISCUSSION

- ON 8/19/90, WHILE AT 100% POWER, A SINGLE TECHNICIAN WAS TESTING THE PRIMARY CONTAINMENT ISOLATION SYSTEM ALTHOUGH TWO TECHNICIANS WERE REQUIRED. SUBSEQUENTLY ANOTHER TECHNICIAN PROVIDED FALSE VERIFICATION OF THE WORK.
- CHANNEL B2 WAS TRIPPED BY THE TECHNICIAN BEFORE CHANNEL A2 WAS RESET BY THE CONTROL ROOM OPERATORS CAUSING THE MSIVs TO CLOSE.
- REACTOR PRESSURE REACHED 1133 PSIG. HIGH PRESSURE AND LOW LEVEL SCRAM SIGNALS WERE GENERATED AND THE REACTOR SCRAMMED.
- LOW REACTOR VESSEL WATER LEVEL ALSO CAUSED AN ATWS SIGNAL WHICH TRIPPED THE RECIRCULATION PUMPS.
- FIVE SRVs DID NOT OPEN AND ONE FAILED TO INDICATE OPEN. THREE WERE OUTSIDE THE 1% PRESSURE BAND.

- THE FEEDWATER STARTUP LEVEL CONTROL VALVE WAS NOT OPERATED PROPERLY.
- THE RCIC THROTTLE VALVE WAS OPENED AND CLOSED SEVERAL TIMES EXCEEDING ITS DUTY CYCLE AND FAILED ON THERMAL OVERLOAD.

AIT CONCLUSION

- REACTOR SCRAM RESULTED FROM INTENTIONAL DEPARTURE FROM STEP BY STEP PROCEDURAL COMPLIANCE/VERIFICATION EXACERBATED BY LACK OF COMMAND AND CONTROL BY OPERATIONS PERSONNEL.
- REACTOR TRANSIENT COMPLICATED BY
 - ° EQUIPMENT FAILURES
 - ° POOR PROCEDURAL AIDS
 - ° NEGATIVE TRAINING ON THE SIMULATOR

CORRECTIVE ACTION

- TECHNICIANS TERMINATED
- RE-PERFORMED SURVEILLANCE TEST
- NEW MAINTENANCE PRE- AND POST-JOB BRIEFING REQUIREMENTS
- PLANT MANAGER CONDUCTED PERSONAL MEETINGS WITH ALL PLANT WORK GROUPS
- FORMALIZED COMMUNICATIONS TRAINING ONGOING
- STANDARDS OF EXCELLENCE ADOPTED BY MAINTENANCE
- PROCEDURES UPGRADED
 - ° OPERATOR AIDS
 - ° OPERATING PROCEDURES
- SIMULATOR REMODELED
 - ° STARTUP LEVEL CONTROL VALVE
 - ° 5-SECOND HOLD FOR RCIC TRIP AND THROTTLE VALVE

NRR STAFF PRESENTATION TO THE ACRS

SUBJECT: LOSS OF OFFSITE POWER
 JUNE 17, 1989

DATE: DECEMBER 7, 1990

PRESENTER: R. O. KARSCH

PRESENTER'S TITLE/BRANCH/DIV:

 REACTOR SYSTEM ENGINEER, EVENTS ASSESSMENT BRANCH, NRR

PRESENTER'S NRC TEL. NO.:

 492-1178

SUBCOMMITTEE:

BRUNSWICK UNIT 2
LOSS OF OFFSITE POWER
JUNE 17, 1989

PROBLEM

THREE HUMAN ERRORS LED TO LOCKOUT OF THE STARTUP TRANSFORMER, TRIP OF THE REACTOR AND A SUBSEQUENT LOSS OF OFFSITE POWER.

SAFETY SIGNIFICANCE

A LOSS OF OFFSITE POWER CHALLENGED THE EMERGENCY POWER SYSTEM.

DISCUSSION

- o UNIT 2 WAS AT 100% POWER, A GROUND FAULT ALARM WAS RECEIVED IN THE CONTROL ROOM.
- o THE RELAY CREW INITIATED TROUBLE SHOOTING IN THE SWITCHYARD.
- o THE PLANT MANAGER (CALLED AT HOME) ADVISED THE OPERATORS TO REDUCE POWER IN CASE THERE WAS A TRANSFORMER LOCKOUT. HIS INTENT WAS TO DRIVE RODS IN TO MINIMIZE INSTABILITY/CORE OSCILLATIONS IF RECIRC PUMPS WERE LOST DUE TO A TRANSFORMER LOCKED.
- o THE OPERATORS, NOT UNDERSTANDING THE REASON FOR THE POWER REDUCTION, REDUCED POWER TO 73% BY REDUCING RECIRCULATION PUMP FLOW RATHER THAN ROD LINE ADJUSTMENT.
- o THE RELAY CREW CAUSED A PHASE TO GROUND SHORT BY IMPROPER TROUBLESHOOTING PROCEDURES. THIS LOCKED OUT THE STARTUP TRANSFORMER.
- o RECIRCULATION PUMPS TRIPPED.
- o THE REACTOR WAS MANUALLY TRIPPED TO PREVENT POSSIBLE INSTABILITIES/CORE OSCILLATIONS AS ADDRESSED IN NRC BULLETIN 88-07.

BRUNSWICK UNIT 2
JUNE 17, 1989

-2-

- o A NINE HOUR LOSS OF OFFSITE POWER ENSUED.
- o THE UNIT 2 EDG's OPERATED SATISFACTORILY.
- o PER EMERGENCY PROCEDURES, SOME LIMITED LOADS ON THE EMERGENCY DUSES COULD HAVE BEEN REPOWERED VIA A CROSSTIE FROM UNIT 1 AT ANY TIME IF NEEDED.

NRR STAFF PRESENTATION TO THE ACRS

SUBJECT: FEEDWATER SYSTEM MALFUNCTION AND RCIC FAILURE
SEPTEMBER 2, 1990

DATE: DECEMBER 7, 1990

PRESENTER: R. O. KARSCH

PRESENTER'S TITLE/BRANCH/DIV:
REACTOR SYSTEM ENGINEER, EVENTS ASSESSMENT BRANCH, NRR

PRESENTER'S NRC TEL. NO.:

492-1178

SUBCOMMITTEE:

PILGRIM
FEEDWATER SYSTEM MALFUNCTION
AND RCIC FAILURE
SEPTEMBER 2, 1990

PROBLEM

- o FEEDWATER CONTROL WAS LOST AND AFTER THE PLANT WAS MANUALLY TRIPPED THE RCIC FAILED TO RUN.
- o SEVERAL FAILURES OR MALFUNCTIONS OF NON-SAFETY GRADE EQUIPMENT COMPLICATED OPERATOR RESPONSE TO THE EVENT.

CAUSE

COMPONENT FAILURE IN THE FEEDWATER SYSTEM WITH CONTRIBUTION FROM MAINTENANCE OVERSIGHTS AND A DEFECTIVE PROCEDURE COMBINED TO CAUSE THIS EVENT.

SAFETY SIGNIFICANCE

REACTOR SCRAM WITH COMPLICATIONS

DISCUSSION

- o THE REACTOR WAS AT 100% POWER WHEN A PRESSURE SWITCH FAILURE RESULTED IN THE FEEDWATER REGULATING VALVES OPENING/OVERFEEDING THE REACTOR VESSEL.
- o PER LOSS OF FEEDWATER CONTROL PROCEDURE THE FEEDWATER CONTROL SYSTEM WAS PLACED IN MANUAL CONTROL. MINIMAL RESPONSE TO MANUAL CONTROL WAS NOTED BY OPERATORS DUE TO THE COMPONENT FAILURE. SOME LEVEL CONTROL WAS ACHIEVED BY DIVERTING FEED FLOW TO THE CONDENSER.
- o LATER, THE OPERATORS TRIPPED ONE OF THREE MAIN FEED PUMPS TO PREVENT OVERFEED. LEVEL THEN DECREASED. OPERATORS THEN TRIPPED THE REACTOR WHEN IT BECAME OBVIOUS THAT FEEDWATER CONTROL DID NOT EXIST.
- o THE PLANT WAS OPERATED FOR APPROXIMATELY 30 MINUTES BETWEEN THE TIME OF THE INITIAL HIGH LEVEL ALARM UNTIL THE MANUAL TRIP AND MAIN FEED ISOLATION AT 99% POWER.

- o AFTER THE TRIP THE OPERATORS ATTEMPTED TO MANUALLY START RCIC TO PROVIDE FEED. THE RCIC TURBINE STARTED THEN TRIPPED ON OVERSPEED BECAUSE THE MANUAL START PROCEDURE WAS FLAWED.
- o TWO ATTEMPTS WERE MADE TO RESTART RCIC. THE TURBINE COULD NOT BE KEPT RUNNING BECAUSE OF DAMAGE TO THE OVERSPEED TRIP ASSEMBLY POSSIBLY CAUSED BY PREVIOUS REPETITIVE OVERSPEED TRIPS, AND INADEQUATE MAINTENANCE. AS A RESULT RCIC WAS CONSIDERED INOPERABLE.
- o THE OPERATORS THEN ATTEMPTED TO USE THE STARTUP FEED SYSTEM. THE STARTUP FEED REGULATING VALVE FAILED TO THE FULL OPEN POSITION DUE TO A DEGRADED BOOSTER RELAY IN THE CONTROL AIR SYSTEM.
- o VESSEL LEVEL WAS CONTROLLED BY DIRECTING FLOW THROUGH THE FULLY OPEN START UP FEEDWATER REGULATION VALVE AND CYCLING THE MAIN FEED PUMPS INDIVIDUALLY.
- o A MSIV CLOSURE OCCURRED 47 MINUTES AFTER THE REACTOR TRIP.
- o HPCI WAS STARTED TO INJECT INTO THE VESSEL. HOWEVER, HPCI EVENTUALLY TRIPPED ON HIGH LEVEL.
- o AFTER THE ISOLATION, SRVs AND HPCI RUNNING IN THE TEST MODE CONTROLLED PRESSURE.
- o THE MSIV CLOSURE WAS LATER RESET. WITH THE MSIVs REOPENED NORMAL DEPRESSURIZATION VIA THE MAIN CONDENSER WAS ESTABLISHED.
- o THE LEVEL WAS LATER CONTROLLED USING THE CONDENSATE PUMPS OR CONTROL ROD DRIVE PUMPS AND REACTOR WATER CLEAN UP SYSTEM PUMPS.
- o RHR WAS ISOLATED BRIEFLY DUE TO A SUCTION SIDE PRESSURE SPIKE DURING LINEUP OF SHUTDOWN COOLING.
- o SUBSEQUENT TO THE EVENT IT WAS DETERMINED THAT RCIC SUCTION PIPING WAS PRESSURIZED FOR APPROXIMATELY 50 SECONDS DURING THE SECOND RCIC START ATTEMPT. THE PEAK PRESSURE WAS BETWEEN 600-800 PSI. AN ENGINEERING ANALYSIS CONDUCTED BY THE LICENSEE ASSUMED 900 PSI.

SEQUOYAH UNITS 1 & 2
HYDROGEN GAS BUILDUP IN THE CHARGING SYSTEM

NRC STAFF FOLLOW-UP

- INFORMATION NOTICE 88-23 SUPPLEMENT 3 TO BE ISSUED DECEMBER 10, 1990 DESCRIBING SEQUOYAH EVENTS
- STAFF DEVELOPING GENERIC COMMUNICATION WHICH REQUESTS:
 - EVALUATE AND INSPECT PIPING SYSTEMS TO DETERMINE EXTENT OF PROBLEM, IF ANY
 - IMPLEMENT APPROPRIATE SHORT AND LONG TERM CORRECTIVE ACTIONS, IF NOT ALREADY COMPLETED


**Technical Evaluation of
PWR ECCS
Centrifugal Charging Pump (CCP)
Operability With
Hydrogen in the Crossover Piping**

**Steven M. Mirsky
ACRS Meeting
December 7, 1990**

PLANT DESCRIPTION

- o 3 Loop PWR
- o 3 HHSI Centrifugai Charging Pumps (CCP)
With 11 Stages And 0.8 Cubic Foot Internal
Volume Per Pump
- o 2 LHSI RHR Pumps
- o "A" RHR Pump - To - CCP Crossover Pipeline
Includes A Long (>150 Ft) Horizontal Run Above
Pump And VCT Elevation
- o "A" Crossover Line is Filled With 62.5 Cubic Feet
of Hydrogen

ELEV (FT)



**RHR Pump and Centrifugal Charging Pump
Simplified Elevation and Flow Diagram**

SEQUENCE OF EVENTS

- o Small Break LOCA (1 Inch \leq Break Dia. \leq 4 inches)
- o RWST Inventory Depleted
- o RCS Pressure $>$ RHR Pump Shutoff Head (~ 150 psia)
- o Switchover From Injection to Recirculation Phase
- o RHR Pump Suction Aligned to Containment Sump
- o RHR Pump Discharge Aligned to CCP Suction Through Crossover Line
- o RHR Pumps Startup (T = 0.0)

TRANSIENT HYDRAULIC RESPONSE

- o Detailed Time Sequence Analysis
- o RHR Pump Discharge Pressure Shuts Check Valve on RWST Line
- o RHR Flow Through Crossover Line Characterized by High (>0.7) Froude Number (Inertial/Gravity Forces)
 - Columnar Fluid Flow
 - Hydrogen Pushed Through Crossover Pipe As a Uniform Unmixed Volume
 - Hydrogen Volume Compressed to 23 Cubic Feet
- o 85% Hydrogen Void Fraction Two-Phase Mixture Enters CCP "A" at $T \approx 6.0$ Seconds

ANALYSIS RESULTS

- o CCP "A" Stalls At $T \simeq 6.5$ Seconds
(0.5 Sec. After H_2 Mixture Enters CCP !)
- o Last 2 CCP Stages Are Filled With Water
- o First 9 CCP Stages Are Filled With Hydrogen

CONCLUSIONS

- o Charging Pump Fails Within Seconds

Failure Mechanisms:

- Pump Seizure Due To:
 - Interstage Bushing Contact,
 - Wear Ring Contact,
 - Balancing Drum Contact
(0.01 to 0.015 Inch Clearance)
 - Inboard Mechanical Seal Failure
 - Catastrophic Pump Shaft Deflection From
Pressure Swing or Hydraulic Unbalance
- o Results Are Plant and Sequence Specific

(4)

UNITED STATES
NUCLEAR REGULATORY COMMISSION
OFFICE OF NUCLEAR REACTOR REGULATION
WASHINGTON, D.C. 20555

December 10, 1990

NRC INFORMATION NOTICE NO. 88-23, SUPPLEMENT 3: POTENTIAL FOR GAS BINDING OF HIGH-PRESSURE SAFETY INJECTION PUMPS DURING A LOSS-OF-COOLANT ACCIDENT

Addressees:

All holders of operating licenses or construction permits for pressurized-water reactors (PWRs).

Purpose:

This information notice supplement is intended to alert addressees to the potential for common-mode failure caused by hydrogen gas binding of the high-head safety injection pumps (charging pumps) during a loss-of-coolant accident (LOCA). It is expected that recipients will review the information for applicability to their facilities and consider actions, as appropriate, to avoid similar problems. However, suggestions contained in this information notice supplement do not constitute NRC requirements; therefore, no specific action or written response is required.

Description of Circumstances:

On August 22, 1990, Unit 2 of the Sequoyah Nuclear Power Plant was at 70-percent power (in coastdown). The licensee was attempting to switch operation of the charging pumps from the "A" to "B" pump in order to perform surveillance (see Attachment 1). Upon start of the "B" charging pump, the licensee observed fluctuation of the pump's motor amperage and rate of flow. The licensee suspected that gas was accumulating on the suction-side of the "B" pump and secured the pump. Further investigation and analysis by the licensee revealed that hydrogen gas was accumulating in the suction piping of the "B" pump and in the RHR crossover piping to the charging header. The licensee was able to vent approximately 5.3 cubic feet of gas. An additional 4.75 cubic feet of gas could not be vented from the RHR crossover piping.

On September 6, 1990, with Unit 1 at 100-percent power, the licensee identified the presence of a hydrogen gas bubble on the suction-side of the charging pumps in Unit 1. The gas was collecting in the piping between the "A" residual heat removal (RHR) pump and the charging pumps. The licensee calculated that hydrogen was accumulating at a rate of 0.5 cubic feet per hour. The gas came out of solution (in part) due to localized reductions in pressure because of piping elevation differences and eccentric pipe reducers (see Attachment 1). Immediate corrective action taken by the licensee for both units included venting the suction piping of the idle charging train every 8 hours.

9012040239

Discussion:

These events at Sequoyah are significant because hydrogen gas accumulation in the suction piping to the charging pumps has the potential to affect multiple trains of pumps in the emergency core cooling system (ECCS). Loss of all high-pressure recirculation capability at Sequoyah during a small-break LOCA is the dominant risk contributor to the core damage frequency as identified in Section 5, Sequoyah Plant Results, NUREG-1150, Volume 1, "Severe Accident Risks: An Assessment For Five U.S. Nuclear Power Plants."

During a LOCA, suction of the ECCS pumps must be switched from the refueling water storage tank (RWST) to the containment sump before the RWST is depleted. If the reactor coolant system (RCS) has not yet depressurized to the point that the low-pressure injection pumps (i.e., RHR pumps) can inject into the vessel, then the discharge of the RHR pumps must be directed to the suction of the centrifugal charging pumps (CCPs) and the safety injection (SI) pumps. Successful recirculation of water from the containment sump (with the RCS at high pressure) requires operation of one RHR pump and one of the high head pumps. At Sequoyah, the "A" RHR pump supplies the suction of both CCPs and the "A" SI pump. The "B" RHR pump supplies the suction to the "B" SI pump.

Noncondensable gases accumulating in the piping between the "A" RHR pump and the charging pump suction header creates the potential for gas binding of both charging pumps during the switchover from high-pressure injection to high-pressure recirculation. In addition, because the valves isolating the "A" RHR and "A" SI pumps from the charging pump suction header are periodically stroke-time tested, gas may also enter sections of piping normally isolated from this header. Thus, the gas accumulation in the charging pump suction header potentially affects three of the four high-pressure pumps.

In recent NRC information notices, the staff addressed gas binding of ECCS pumps. Information Notice (IN) 88-23, "Potential For Gas Binding of High-Pressure Safety Injection Pumps During A Loss-Of-Coolant-Accident (LOCA)," addressed gas-binding problems in the high-pressure safety injection system at the Farley Nuclear Power Plant. The staff issued two supplements to that information notice to address gas accumulation affecting ECCS pumps because of various root causes. IN 90-64, "Potential For Common-mode Failure Of High Pressure Safety Injection Pumps Or Release Of Reactor Coolant Outside Containment During A Loss-Of-Coolant Accident," discusses another mechanism that could lead to gas binding of both CCPs.

The two gas-binding events at Sequoyah had root causes that were attributed by the licensee, in part, to inadequate review of IN 88-23. Although most gas accumulation in ECCS systems has been hydrogen, in at least one instance, a mixture of air and hydrogen was found. It is important to consider all potential sources of gas intrusion to the ECCS suction piping, such as leaking bladders on the pulsation dampeners for positive displacement charging pumps, ineffective check valves in highpoint venting systems that lead back to the air space in the volume control tank (VCT), any flow restrictions (e.g., orifices)

which may cause gases to come out of solution, and improper venting and filling operations following maintenance of ECCS flowpaths. Since most plants have no technical specification surveillance requirement for periodic venting of ECCS suction piping (only pump casings and discharge piping), gas may accumulate and remain undetected for extended periods of time, subjecting the plant to a possible common mode failure of the ECCS pumps.

This information notice requires no specific action or written response. If you have any questions about the information in this notice, please contact the technical contact listed below or the appropriate NRR project manager.




Charles E. Rossi, Director
Division of Operational Events Assessment
Office of Nuclear Reactor Regulation

Technical Contact: John Thompson, NRR
(301) 492-1171

Attachments:

1. Charging Pumps and RHR Crossover for SQN Units 1 and 2
2. List of Recently Issued NRC Information Notices

Charging Pumps and RHR Crossover for SQN Units 1 & 2



ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

NEW STANDARD TECHNICAL SPECIFICATIONS (STS)

MARK REINHART
(301) 492-3139
SENIOR OPERATIONS ENGINEER
TECHNICAL SPECIFICATIONS BRANCH
DIVISION OF OPERATIONAL EVENTS ASSESSMENT
OFFICE OF NUCLEAR REACTOR REGULATION

FRIDAY, DECEMBER 7, 1990

1:00 - 2:30 P.M.

INFORMATION BRIEFING ON NEW STANDARD TECHNICAL SPECIFICATIONS (STS)

- OVERVIEW OF PROGRAM AND PROGRESS TODAY
- RELEASE FINAL DRAFT FOR YOUR INFORMATION JAN 91

CHRONOLOGY: STANDARD TECHNICAL SPECIFICATIONS (STS)

• BACKGROUND

COMMISSION'S INTERIM POLICY STATEMENT

FEB 87

"SPLIT REPORT"

MAY 88

OWNERS GROUPS PROPOSED NEW STS

MAR 89

TO

JUN 89

STAFF'S REVIEW AND DISCUSSIONS WITH OWNERS GROUPS

APR 89

TO

DEC 90

• PROGRESS

STAFF TO ISSUE FINAL DRAFT NEW STS AND THEIR BASES

JAN 91

OWNERS GROUPS' AND NRC STAFF'S FINAL REVIEW

• FUTURE

APPLY LESSONS LEARNED FROM LEAD PLANT CONVERSIONS TO NEW STS

ISSUE NEW STS AND THEIR BASES

SPRING 91

EXTENT OF PARTICIPATION IN PROGRAM

- INDUSTRY PARTICIPATION (30 PERSONS)
 - NUMARC
 - NSSS OWNERS GROUPS
 - LEAD PLANT LICENSEES
 - OTHER LICENSEES

- NRC STAFF PARTICIPATION (65 PERSONS)
 - TECHNICAL SPECIFICATIONS BRANCH
 - NRR TECHNICAL BRANCHES (INCLUDING RISK AND HUMAN FACTORS)
 - PROJECTS
 - REGIONS
 - TECHNICAL TRAINING CENTER

- NRC CONTRACTORS (25 PERSONS)
 - LAWRENCE LIVERMORE NATIONAL LABORATORY
 - IDAHO NATIONAL ENGINEERING LABORATORY
 - PACIFIC NORTHWEST LABORATORIES
 - SCIENCE APPLICATIONS INTERNATIONAL CORPORATION

LEAD PLANT CONVERSIONS TO NEW STS

NORTH ANNA 1 AND 2	WESTINGHOUSE
CRYSTAL RIVER 3	BABCOCK AND WILCOX
SAN ONOFRE 2 AND 3	COMBUSTION ENGINEERING
HATCH 2	GE BWR-4
GRAND GULF 1	GE BWR-6

CONTENTS OF NEW STS

1.0 USE AND APPLICATION

- 1.1 DEFINITIONS
- 1.2 LOGICAL CONNECTORS
- 1.3 COMPLETION TIMES
- 1.4 FREQUENCY
- 1.5 OPERABILITY

2.0 SAFETY LIMITS

LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

- 3.0 APPLICABILITY
- 3.1 REACTIVITY CONTROL SYSTEMS
- 3.2 POWER DISTRIBUTION LIMITS
- 3.3 INSTRUMENTATION
- 3.4 REACTOR COOLANT SYSTEM
- 3.5 EMERGENCY CORE COOLING SYSTEMS
- 3.6 CONTAINMENT
- 3.7 PLANT SYSTEMS
- 3.8 ELECTRICAL
- 3.9 REFUELING
- 3.10 SPECIAL OPERATIONS (BWR'S)

4.0 DESIGN FEATURES

5.0 ADMINISTRATIVE CONTROLS

HIGHLIGHTS OF CHANGES

- TECHNICAL CHANGES

- RELOCATED 40% OF REQUIREMENTS TO LICENSEE CONTROLLED DOCUMENTS
 - LICENSEES TO PROVIDE CONTROLS FOR RELOCATED REQUIREMENTS
 - REDUCED SURVEILLANCE TESTING
 - LINE ITEM IMPROVEMENTS

- RISK INSIGHTS

- SPLIT (3 CRITERIA + RISK INSIGHTS)
 - TOPICAL REPORTS ON INSTRUMENTATION COMPLETION TIMES AND SURVEILLANCE FREQUENCIES
 - SAIC EVALUATION

- HUMAN FACTORS

- WRITERS GUIDE

SUMMARY OF IMPROVEMENTS

- FOCUSED ON OPERATIONAL SAFETY
- MORE OPERATOR ORIENTED
- STREAMLINED LCO'S AND SR'S
- HIGH DEGREE OF CONSISTENCY WITHIN EACH AND AMONG ALL STS
- BASES PROVIDE
 - REASONS FOR LCO AND SR REQUIREMENTS
 - LINK WITH SAFETY ANALYSIS
- PROMOTE BETTER UNDERSTANDING OF TECHNICAL SPECIFICATIONS
- ALLOW MORE EFFICIENT USE OF NRC AND INDUSTRY RESOURCES

6

**AN INTEGRAL STRUCTURE AND SCALING METHODOLOGY
FOR
SEVERE ACCIDENT TECHNICAL ISSUE RESOLUTION**

Developed by: Technical Program Group

Presented by: Novak Zuber

ACRS COMMITTEE MEETING

Bethesda, Maryland

December 7, 1990

Technical Program Group

B. Boyack	(LANL)
A. Dukler	(UH)
P. Griffith	(MIT)
J. Healzer	(SLI)
R. Henry	(FAI)
M. Ishii	(Purdue)
J. Lehner	(BNL)
S. Levy	(SLI)
F. Moody	(GE)
M. Pilch	(SNL)
B. Sehgal	(EPRI)
B. Spencer	(ANL)
T. Theofanis	(UCSB)
J. Valente	(BNL)
W. Wulff	(BNL)
N. Zuber	(NRC)


TOPICS

Topics that will be covered in this presentation include:

- o OVERVIEW OF INTEGRATED STRUCTURE FOR TECHNICAL ISSUE RESOLUTION (ISTIR)
- o BRIEF DESCRIPTION OF ISTIR COMPONENTS
- o OVERVIEW OF SEVERE ACCIDENTS SCALING METHODOLOGY (SASM)
- o BRIEF DESCRIPTION OF SASM COMPONENTS
- o OVERVIEW OF THE TWO-TIER SCALING ANALYSIS
- o APPLICATION TO DCH TRANSIENTS
- o CONTENT OF REPORT

1. OVERVIEW OF
ISTIR AND SASM

INTEGRATED STRUCTURE FOR TECHNICAL ISSUE RESOLUTION



1-2



THE MAJOR ATTRIBUTES OF THE ISTIR ARE:

- - **OBJECTIVE: PROVIDE SEVERE ACCIDENT TECHNICAL ISSUE RESOLUTION HAVING:**
 - * - **PROPER BALANCE OF ANALYSIS WITH EXPERIMENTS**
 - * - **TECHNICAL SUFFICIENCY**
 - * - **PROGRAM EFFICIENCY**

- - **STRUCTURE: INTEGRATES THE FIVE COMPONENTS OF TECHNICAL ISSUE RESOLUTION:**
 - * - **TECHNICAL ISSUE SPECIFICATION (COMPONENT I)**
 - * - **SCALING OF EXPERIMENTS (COMPONENT II)**
 - * - **SPECIAL RESOLUTIONS DIRECTLY FROM EXPERIMENTAL DATA (COMPONENT III)**
 - * - **COMPUTER CODE DEVELOPMENT (COMPONENT IV)**
 - * - **TECHNICAL ISSUE RESOLUTION WITH FROZEN CODES (COMPONENT V)**


COMPONENT I, SAFETY ISSUE ACCIDENT SPECIFICATION & PHENOMENA EVALUATION, IS FOUNDATION OF ISTR

- - OBJECTIVE: PROVIDE A WELL DEFINED PROBLEM IN THE CONTEXT OF THE TECHNICAL ISSUE, PLANT, SCENARIO & RELATIVE IMPORTANCE OF PHENOMENA
- - STRUCTURE: CONSISTS OF FIVE STEPS TO SPECIFY THE ABOVE KEY ELEMENTS.
 - * - REQUIRES DEFINITION OF CRITERIA FOR SUCCESSFUL TECHNICAL ISSUE RESOLUTION
 - * - PLAUSIBLE PHENOMENA & RELATIVE IMPORTANCE DETERMINED VIA TOP-DOWN APPROACH



COMPONENT II, SEVERE ACCIDENT SCALING METHODOLOGY, ADDRESSES THE PARTICULARLY IMPORTANT ELEMENT OF WELL SCALED EXPERIMENTAL DATA

- - OBJECTIVE: PROVIDE SCALING RATIONALE & CRITERIA, FACILITY DESIGN & TEST SPECIFICATION REVIEWS, & ASSESSMENT OF SCALE DISTORTIONS
- - STRUCTURE: METHODOLOGY CONSISTS OF 11 STEPS GROUPED IN 3 KEY ELEMENTS RELATED TO REQUIREMENTS, EVALUATION, TESTING, & DOCUMENTATION OF EXPERIMENTS




ISTIR


1-5

COMPONENT III, TECHNICAL ISSUE RESOLUTION WITH EXPERIMENTAL DATA, SPECIAL MODELS & UNCERTAINTY QUANTIFICATION, PROVIDES FOR POSSIBILITY OF ISSUE RESOLUTION DIRECTLY FROM EXPERIMENTAL DATA

- - INVOLVES INNOVATIVE APPROACHES
- - ACCOMMODATES "FLASHES" OF INSIGHT
- - REQUIRES MATURE SOLUTIONS EFFECTED BY TESTING, VALIDATION AND TECHNICAL COMMUNITY PEER REVIEW & ACCEPTANCE
- - PROCESS CAN BE PRESCRIBED, BUT DETAILS MUST REMAIN FLEXIBLE



ISTIR




COMPONENT III

1-7


COMPONENT IV, CODE DEVELOPMENT IS ONE OF TWO PRIMARY SUPPORTS TO ANALYTICAL TECHNICAL ISSUE RESOLUTION (COMPONENT V)

- - OBJECTIVE: PROVIDE CODES THAT ARE:
 - * - ABLE TO ADDRESS TECHNICAL ISSUES
 - * - APPLICABLE TO FULL SCALE REACTORS

- - STRUCTURE: CONSISTS OF SIX STEPS THAT:
 - * - ESTABLISH CODE REQUIREMENTS EARLY BASED ON PHENOMENA
 - * - PROVIDE V & V OF CODE (TRACEABILITY & AUDITIBILITY)



ISTIR




COMPONENT IV

8-1

COMPONENT V, TECHNICAL ISSUE RESOLUTION WITH FROZEN CODE & UNCERTAINTY QUANTIFICATION CAN BE EXPECTED TO BE PREFERRED METHOD

- - OBJECTIVE: TO DETERMINE CODE APPLICABILITY & UNCERTAINTY IN THE CONTEXT OF PROVIDING TECHNICAL ISSUE RESOLUTIONS HAVING PRUDENT SAFETY MARGINS
- - STRUCTURE: COMPONENT ANALYSIS BASED ON THE CODE SCALING, APPLICABILITY & UNCERTAINTY (CSAU) METHODOLOGY DOCUMENTED IN NUREG/CR-5249



ISTIR

1-9

2. OVERVIEW

OF


THE TWO-TIER SCALING METHODOLOGY

TOPICS THAT WILL BE COVERED IN THIS PRESENTATION
INCLUDE:

- o OBJECTIVES
- o FLOW DIAGRAM FOR THE TWO-TIER SCALING ANALYSIS
- o CHARACTERISTICS OF SEVERE ACCIDENTS SCENARIOS
- o A HIERARCHICAL POINT OF VIEW
- o SYSTEM DECOMPOSITION AND HIERARCHY
- o CHARACTERISTIC SPATIAL SCALES
- o CHARACTERISTIC TEMPORAL SCALES
- o CHARACTERISTIC TIME RATIOS
- o SCALE DISTORTIONS
- o CONCLUSIONS

OBJECTIVES

1. TO ENSURE THE PROTOTYPICALITY OF THE EXPERIMENTAL DATA.
2. TO PROVIDE A SCALING METHODOLOGY THAT IS SYSTEMATIC AND PRACTICAL, AUDITABLE AND TRACEABLE.
3. TO PROVIDE THE SCALING RATIONALE AND SIMILARITY CRITERIA
4. TO PROVIDE A PROCEDURE FOR CONDUCTING COMPREHENSIVE REVIEWS OF FACILITY DESIGN, OF TEST SPECIFICATION AND RESULTS, AND
5. TO QUANTIFY BIASES DUE TO SCALE DISTORTIONS OR DUE TO NON-PROTOTYPICAL CONDITIONS



FLOW DIAGRAM FOR THE TWO-TIERED SCALING ANALYSIS

CHARACTERISTICS OF SEVERE ACCIDENTS (SA) SCENARIOS

- o SA SCENARIOS ARE CHARACTERIZED BY TRANSIENT PROCESSES ASSOCIATED WITH INTERACTING AND REACTING MEDIA, CONSISTING OF MANY CONSTITUENTS, OF DIFFERENT PHASES EXCHANGING MASS, ENERGY AND MOMENTUM
- o EACH SYSTEM COMPONENT HAS ITS OWN CHARACTERISTIC RESPONSE TIME AND GEOMETRY.
- o PHYSICAL AND CHEMICAL INTERACTIONS ARE PROCESSES CHARACTERIZED BY PARTICULAR SCALES FOR GEOMETRY AND TIME.
- o THEREFORE, THE PROBLEM IS ONE OF MULTIPLE SPATIAL AND TEMPORAL SCALES.
- o SYNERGETIC EFFECTS NECESSITATE GLOBAL CONSIDERATIONS.
- o THIS SUGGESTS A HIERARCHICAL APPROACH TO THE PROBLEM TO MAKE IT TRACTABLE.

A HIERARCHICAL POINT OF VIEW

- o CENTRAL TO THE APPROACH IS THE CONCEPT THAT A HIERARCHY, (ORGANIZATION) CAN BE ESTABLISHED FROM DIFFERENCES IN TEMPORAL AND SPATIAL SCALES.
- o PROCESSES CAN BE GROUPED INTO CLASSES WITH SIMILAR TIME SCALES. IF CLASSES ARE SUFFICIENTLY DISTINCT THEY CAN BE DECOUPLED ONE FROM ANOTHER RESULTING IN A HIERARCHICAL ORGANIZATION.
- o LEVELS IN A HIERARCHY RE ISOLATED FROM EACH OTHER BECAUSE THEY OPERATE AT DISTINCTLY DIFFERENT TIME SCALES.
- o A LOWER LEVEL IN THE HIERARCHY COMMUNICATES ONLY ITS AVERAGE TO THE HIGHER LEVEL (LESS DETAILED INFORMATION IS NEEDED AT HIGHER LEVELS).
- o LARGER CHARACTERISTIC SPATIAL SCALES ARE ASSOCIATED WITH CHARACTERISTIC LONGER TIME SCALES.
- o EACH LOWER LEVEL PROVIDES MORE DETAILED INFORMATION (SPECIFICITY)

A HIERARCHICAL POINT OF VIEW (CON'T)

- o A HIERARCHICAL (STRUCTURED) APPROACH TO SCALING WAS DEVELOPED. STARTING FROM A GLOBAL, TOP VIEWPOINT, COMPLEXITY AND DETAIL ARE INTRODUCED AT EACH LOWER LEVEL.
- o THE RESULT IS A TWO-TIER APPROACH.

THE TOP-DOWN SYSTEM APPROACH

- o PROVIDES A SCALING HIERARCHY BASED ON RELATIVE IMPORTANCE OF VARIOUS TRANSFER PROCESSES.
- o PROVIDES THE ORDER IN WHICH TO MAINTAIN SIMILARITY BETWEEN TEST AND PLANT CONDITIONS.
- o IDENTIFIES IMPORTANT PROCESSES WHICH NEED TO BE EXAMINED IN MORE DETAIL.

THE BOTTOM-UP PROCESS APPROACH

- o PROVIDES A DETAILED SCALING ANALYSIS OF IMPORTANT PROCESSES.


IMPORTANT FEATURES

- o THE TOP-DOWN SYSTEM SCALING PROVIDES THE EFFICIENCY WHEREAS THE BOTTOM-UP PROCESS SCALING ENSURES THE SUFFICIENCY OF THE ANALYSIS.
- o TOGETHER, THE TWO APPROACHES PROVIDE A SCALING METHODOLOGY THAT IS PRACTICAL.


SYSTEM DECOMPOSITION AND HIERARCHY

THE BASIC PARADIGM:

- o EACH SYSTEM CAN BE DIVIDED INTO (INTERACTING) SUBSYSTEMS.
- o EACH SUBSYSTEM CAN BE DIVIDED IN (INTERACTING) MODULES.
- o EACH MODULE CAN BE DIVIDED IN (INTERACTING) CONSTITUENTS (MATERIALS).
- o EACH CONSTITUENT CAN BE DIVIDED IN (INTERACTING) PHASES.
- o EACH PHASE CAN BE CHARACTERIZED BY ONE OR MORE GEOMETRICAL CONFIGURATIONS.
- o EACH GEOMETRICAL CONFIGURATION CAN BE DESCRIBED BY THREE CONSERVATION EQUATIONS.
- o EACH FIELD CAN BE CHARACTERIZED BY SEVERAL PROCESSES.




**SYSTEM DECOMPOSITION AND HIERARCHY
PROCESSES**



**SYSTEM DECOMPOSITION AND HIERACHY
LENGTH, TIME AND CONCENTRATION CHARACTERISTICS**

VOLUMETRIC CONCENTRATIONS

- * VOLUMETRIC CONCENTRATIONS SCALE (ACCOUNT FOR) THE RELATIVE AMOUNT OF A CONSTITUENT, OF A PHASE AND OF A PARTICULAR GEOMETRY IN THE CONTROL VOLUME



Hierarchy for volume fraction of geometric configuration G in control volume V_{CV} .

CHARACTERISTIC SPATIAL SCALES

- o A TRANSFER AREA IS ASSOCIATED WITH EACH TRANSFER PROCESS.
- o CONSEQUENTLY, THE CHARACTERISTIC SPATIAL SCALE FOR A PARTICULAR TRANSFER PROCESS IS ITS AREA CONCENTRATION.

CHARACTERISTIC SPATIAL SCALES

CONSIDER DIFFERENT CONSTITUENTS (PHASES) ARE PRESENT IN THE CONTROL VOLUME

DEFINE VOLUME FRACTION OCCUPIED BY CONSTITUENT C

$$\alpha_c = \frac{V_c}{V_{cv}}$$

AREA CONCENTRATION FOR CONSTITUENT C

$$\frac{A_{ic}}{V_{cv}} = \frac{V_c}{V_{cv}} \frac{A_{ic}}{V_c} = \alpha_c \frac{1}{L_c}$$

α_c CHARACTERIZES THE AMOUNT (PRESENCE) OF CONSTITUENT C IN CONTROL VOLUME

$$\frac{A_{ic}}{V_c} = \frac{1}{L_c}$$

CHARACTERIZES THE GEOMETRY FOR TRANSFER FROM CONSTITUENT C

FOR SPHERES:

$$\frac{A_{ic}}{V_c} = \frac{6}{d}$$

FOR FILMS:

$$\frac{A_{ic}}{V_c} = \frac{1}{\delta}$$

CONTROL VOLUME:

V_{CV}

$$\frac{A_{Cf}}{V_{CV}} = \alpha_c \alpha_{Cf} \left[\frac{\alpha_{CfF}}{L_{CfF}} + \frac{\alpha_{CfD}}{L_{CfD}} \right]$$

CONSTITUENTS:

Constituent c

$$V_c = \alpha_c V_{CV}$$

gas

liquid

PHASES:

$$[V_{cG} = \alpha_{cG} V_c]$$

$$[V_{cL} = \alpha_{cL} V_c]$$

GEOMETRICAL CONFIGURATIONS:

films

drops

$$[V_{cLF} = \alpha_{cLF} V_{cL}]$$

$$[V_{cLD} = \alpha_{cLD} V_{cL}]$$

SPECIFIC TRANSFER AREA CONCENTRATIONS:

$$\left[\frac{1}{L_{cLF}} = \frac{1}{\delta_{cLF}} \right]$$

$$\left[\frac{1}{L_{cLD}} = \frac{6}{d_{cLD}} \right]$$

SYNTHESIS

ANALYSIS

Total transfer area concentration (A_{Cf} / V_{CV}) for liquid of constituent C in control volume V_{CV} .

CHARACTERISTIC SPATIAL SCALES (CONT'D)

NOTE:

- A) VOLUMETRIC CONCENTRATIONS ACCOUNT FOR THE EFFECTS OF VARIOUS CONSTITUENTS AND/OR PHASES.

- B) THE EFFECTS OF DIFFERENT GEOMETRIES ARE DIRECTLY ACCOUNTED FOR IN THE AREA OF CONCENTRATION.

CHARACTERISTIC TIME SCALES

A. TIME SCALE FOR CONTROL VOLUMES

CONSIDER A CONTROL VOLUME V_{CV} , WITH A FLOW AREA A_f AND A VOLUME FLOW RATE Q .

THEN THE RESIDENCE TIME IN THE CONTROL VOLUME IS:

$$\tau_{CV} = \frac{V_{CV}}{Q}$$

NOTE:

$$\frac{1}{\tau_{CV}} = \frac{Q}{V_{CV}} = \omega_{CV} = \textit{frequency}$$

$\omega_{CV} =$ NUMBER OF CONTROL VOLUMES CHANGED PER SECOND

IT SCALES SOURCE STRENGTH AND SYSTEM VOLUME (GEOMETRY)

CHARACTERISTIC TIME SCALES (CONT'D.)

B. PROCESS TIME SCALE

CONSIDER PROPERTY Ψ PER UNIT VOLUME:

$$\psi = \rho, \rho v, \rho u, \rho k \dots$$

THEN

$$\psi_r V_{CV} = \text{total amount of } \psi_r \text{ in control volume } V_{CV}$$

CONSIDER A PROCESS IN WHICH Ψ IS BEING TRANSFERED ACROSS THE AREA A_T . FOR A GIVEN FLUX j_Ψ , THEN

$$j_\Psi A_T = \text{total transfer rate of } \psi$$

CHARACTERISTIC TIME SCALE (CONT'D.)


THEN

$$\frac{j_{\psi} A_T}{\psi_r V_{CV}} = \omega_{\psi} = \frac{1}{\tau_{\psi}} =$$

ω_{ψ} = CHARACTERISTIC FREQUENCY FOR A PARTICULAR TRANSFER PROCESS

NOTE:

ω_{ψ} = NUMBER OF TIMES THE (REFERENCE)
AMOUNT OF ψ_r , IN CONTROL VOLUME V_{CV} ,
HAS CHANGED PER SECOND



Hierarchy for the characteristic frequency ω_{ψ} of the transfer process j_{ψ} in control volume V_{CV} .

CHARACTERISTIC TIME SCALES (CONT'D)

NOTE:

- A) THE EFFECTS OF A PARTICULAR RATE PROCESS ON THE SYSTEM CANNOT BE PROPERLY SCALED WITHOUT CONSIDERING THE PRESENCE OF OTHER CONSTITUENTS AND/OR PHASES (ACCOUNTED FOR BY VOLUMETRIC CONCENTRATIONS).
- B) THE IMPACT OF A PARTICULAR RATE PROCESS IS BEING ATTENUATED/MODIFIED AT EACH HIGHER LEVEL OF THE HIERARCHY.

CHARACTERISTIC TIME RATIOS

FOR A GIVEN CONTROL VOLUME V_{CV} , AND GIVEN INPUT/OUTPUT VOLUMETRIC FLOW RATE Q , THE SYSTEM CHARACTERISTIC (RESIDENCE) TIME IS

$$\tau_{CV} = \frac{V_{CV}}{Q}$$

EACH PROCESS IS CHARACTERIZED BY A FREQUENCY:

$$\omega_P = \frac{j_\psi A_T}{\psi_r V_{CV}} = \frac{1}{\tau_P}$$

THE RATIO τ_{CV}/τ_P MEASURES (SCALES) THE RELEVANCE OF THE PROCESS.

CHARACTERISTIC TIME RATIOS (CONT'D)

NOTE:

$$\Pi_{\tau} = \frac{\tau_{CV}}{\tau_P} = \omega_P \tau_{CV}$$

Π_{τ} = THE TOTAL CHANGE OF REFERENCE
AMOUNT ($\Psi_r V_{CV}$) DURING RESIDENCE
TIME τ_{CV}

FOR CONSTITUENTS K:

$$\Pi_{\tau K} = \frac{\tau_{CV}}{\tau_{PK}} = \omega_{PK} = \frac{\alpha_K j_P}{L_{PK} \Psi_r} \tau_{CV}$$

CHARACTERISTIC TIME RATIOS (CONT'D)

NOTE:

- A) FOR EACH PROCESS AND CONSTITUENT, THE CHARACTERISTIC TIME RATIO INCORPORATES THE CHARACTERISTIC TEMPORAL AND SPATIAL SCALES OF THE SYSTEM AND OF THE PROCESS.

- B) EACH PROCESS IS EVALUATED IN TERMS OF THE SYSTEM (CONTROL VOLUME) RESPONSE, I.E., EACH PROCESS IS MEASURED BY THE SAME YARDSTICK.

- C) FOR A PROCESS TO BE SIMILAR IN TWO FACILITIES, THE CHARACTERISTIC TIME RATIO MUST BE PRESERVED.

- D) THE CHARACTERISTIC TIME RATIO COMBINES THE SYSTEM AND PROCESS VIEW POINTS.

CHARACTERISTIC TIME RATIOS (CONT'D)

- E) THE CHARACTERISTIC TIME RATIOS PROVIDE A CRITERION FOR EVALUATING THE IMPORTANCE OF A PARTICULAR PROCESS:

$$\Pi = \omega_p \tau_{CV}$$

$$\Pi_1 > \Pi_2 \text{ more important}$$

$$\Pi_1 < \Pi_2 \text{ less important}$$

CONSEQUENTLY: THE CHARACTERISTIC TIME RATIOS Π PROVIDE THE TOOL FOR PRIORITY DISCRIMINATION AND RANKING

CHARACTERISTIC TIME RATIOS (CON'T)

NOTE:

- o THE PROPOSED CHARACTERISTIC RATIOS CAN BE DERIVED DIRECTLY FROM THE GENERAL BALANCE EQUATION.

CONSEQUENTLY:

- o ALL PROCESSES MODELED IN THE CONSERVATION EQUATIONS (MASS, MOMENTUM, ENERGY) CAN BE EXPRESSED AND THEREFORE EVALUATED IN TERM OF A SINGLE MEASURE (CRITERION), THAT IS, IN TERMS OF TIME.
- o WITH A SINGLE MEASURE TO EVALUATE ALL PROCESSES, THE CHARACTERISTIC TIME RATIOS CAN BE USED TO ESTABLISH A SCALING HIERARCHY.

NOTE:

- o AT EACH LEVEL OF THE SCALING HIERARCHY, THE FUNCTION OF EACH ELEMENT (TRANSFER PROCESS) CAN BE EXAMINED AND ASSESSED.

CONSEQUENTLY:

- o THE FIRST TIER OF THE PROPOSED METHODOLOGY, THAT IS, THE TOP-DOWN OR SYSTEM SCALING APPROACH, PROVIDES FOR AN ANALYSIS THAT IS COMPREHENSIVE YET PRACTICAL, AUDITABLE AND TRACEABLE.

NOTE:

THE SCALING HIERARCHY HAS TWO IMPORTANT FUNCTIONS:

- 1) TO PROVIDE A TECHNICALLY JUSTIFIABLE RATIONALE FOR ESTABLISHING THE ORDER IN WHICH SIMILARITY BETWEEN TEST AND PLANT CONDITIONS SHOULD BE PRESERVED, AND
- 2) TO IDENTIFY IMPORTANT PROCESSES WHICH NEED TO BE ADDRESSED IN GREATER DETAIL BY CONDUCTING A BOTTOM-UP/PROCESS SCALING ANALYSIS.

CONSEQUENTLY:

- o THE SECOND TIER OF THE PROPOSED SCALING METHODOLOGY, THAT IS, THE BOTTOM-UP/PROCESS APPROACH ENSURES THE SUFFICIENCY OF THE ANALYSIS.

EFFECTS OF DISTORTIONS

$$\Pi_p = \omega_r \tau_{CV}$$

= THE RATE AT WHICH A PARTICULAR RATE PROCESS CHANGES A REFERENCE QUANTITY DURING THE RESIDENCE TIME

$$D = \frac{\Pi_p - \Pi_m}{\Pi_p}$$

= THE % DIFFERENCE A PARTICULAR RATE PROCESS CHANGES A REFERENCE QUANTITY DURING THE TRANSIT TIME IN THE PROTOTYPE AND THE MODEL.

3. APPLICATION
TO
DCH TRANSIENTS

TOPICS

- APPLICATION OF ISTIR: COMPONENT I
 - SCENARIO
 - PLANT
 - ACCIDENT PATH
 - PROCESS IDENTIFICATION AND RANKING
- APPLICATION OF SASM
 - FLOW DIAGRAM
 - RPV FAILURE CONDITIONS
 - RPV DISCHARGE PHENOMENA
 - REACTOR CAVITY PHENOMENA

APPLICATION OF IST!R: COMPONENT I

**THE 1ST COMPONENT OF THE ISTIR HAS BEEN APPLIED TO A
DCH TRANSIENT (1 OF 3)**

TECHNICAL ISSUE: DETERMINE POTENTIAL FOR CONTAINMENT OVERLOAD


**SUCCESS CRITERIA: ESTABLISH CONTAINMENT PRESSURE, TEMPERATURE &
CONTAMINATION RESPONSE AT 95% PROBABILITY
LEVEL**

SCENARIO: DIRECT CONTAINMENT HEATING IN THE CONTAINMENT

NPP: REFERENCE PLANTS - ZION, SURRY & WATTS BAR

THE 1ST COMPONENT OF THE ISTIR HAS BEEN APPLIED TO A DCH TRANSIENT (2 OF 3)

ACCIDENT PATH:



**THE 1ST COMPONENT OF THE ISTIR HAS BEEN APPLIED TO A
DCH TRANSIENT (3 OF 3)**

- - NPP HAS BEEN PARTITIONED INTO LOGICAL COMPONENTS TO AID IN IDENTIFICATION OF PLAUSIBLE PHENOMENA:

* - RPV

* - CONTAINMENT SUBCOMPARTMENTS

* - REACTOR CAVITY

* - UPPER CONTAINMENT

- - PLAUSIBLE PHENOMENA HAVE BEEN IDENTIFIED & RANKED FOR RELATIVE IMPORTANCE TO OVERLOAD, BY SCENARIO PHASE & COMPONENT

Table 2-2 Summary of Ranking^a of the importance of plausible phenomena to containment loads during a DCH transient

Component/Phenomena	Initial TPG Ranking by Transient Phase		
	Corium Discharge	Multiphase Discharge	Phase-1 Discharge
RPV:			
Hole ablation	H	H	--
Flow through hole	H	H	H
Depressurization	L	--	--
Gas blowthrough	H	--	--
Oxidation reactions	--	L	--
Reactor Cavity:			
Corium distribution	H	H	H
Concrete ablation	L	--	--
Concrete decomposition	L	M	--
Oxidation reactions	M	H	H
Debris/water HT	M	H	H
Debris/gas HT	L	H	H
Debris/structures HT	M	L	L
Gas/structures HT	L	L	L
Hydrogen combustion	L	L	L
Containment Subcompartments:			
Hydrogen mixing	--	M	M
Oxygen content	--	M	M
Hydrogen combustion	--	M	M
Other combustibles	--	M	M
3D dispersed flow	H	H	H
Oxidation reactions	--	H	H
Debris/gas HT	--	H	H
Debris/structures HT	--	H	H
Debris/water HT	--	H	H
Concrete decomposition	--	H	H
Gas/structure HT	--	M	M
Upper Containment:			
Hydrogen mixing & combustion	--	H	H
Other combustibles	--	L	L
Oxidation reactions	--	L	L
Debris/gas HT	--	H	H
Debris/structures HT	--	L	L
Gas/structures HT	--	L	L

a. L = Low importance M = Medium importance H = High importance


-- = Insignificant importance or not active during phase.

APPLICATION OF SASM

APPLICATION TO DCH

THE TWO-TIER SCALING METHODOLOGY ONE
BASED ON THE SYSTEM (TOP-DOWN) APPROACH THE
OTHER ON THE PROCESS (BOTTOM-UP) APPROACH WAS
APPLIED TO THE DCH PROBLEM.

THE TOPICS ADDRESSED IN THE REPORT ARE
LISTED IN THE FIGURES THAT FOLLOW



FLOW DIAGRAM AND TOPICS ADDRESSED IN APPLYING SASM TO DCH

REACTOR PRESSURE VESSEL

FAILURE CONDITIONS

Appendix

AMOUNT OF MATERIAL INVOLVED IN DIRECT CONTAINMENT HEATING
DURING A PRESSURIZED WATER REACTOR STATION BLACKOUT

Prepared for

Technical Program Group (TPG)
Severe Accident Scaling Methodology (SASM)

Prepared by

Salomon Levy*
S. Levy Incorporated


November 1989

Updated April 1990

* The author wishes to acknowledge the detailed comments and suggestions received on this report by T. Heames and J. E. Kelly from Sandia National Laboratories.

TABLE OF CONTENTS

Section	Page
Summary	E.2-1
Introduction	E.2-2
Reactor System Behavior	E.2-4
Progression of Core Damage	E.2-8
Debris Relocation into Bottom Head of Vessel	E.2-11
Heat Transfer to and Failure of Bottom Head	E.2-16
Composition of Ejected Material	E.2-23
Suggested Initial Conditions for DCH	E.2-28
Synthesized DCH Initial Conditions for Vessel Creep Failure	E.2-30
Synthesized DCH Initial Conditions for Penetration Failure	E.2-33
Depressurized DCH Conditions	E.2-35
Conclusions About DCH Initial Conditions	E.2-35
References	E.2-37



INITIAL CONDITIONS			
TIME OF FAILURE	-3 HOURS	-4 HOURS	-10 HOURS
EJECTED KGS	-40,000	-70,000	-80,000
MOLTEN KGS	-40,000	-40,000	-40,000
OXIDIZED ZR	-40%	-40-50%	-60-70%
EJECTED METALLIC CONTENT	-30-40%	-40-60%*	-50-70%*
TEMPERATURE	-2500 K	-2500 K	-2500 K

*INCREASED METALLIC CONTENT DUE TO MOLTEN STEEL


Fig. 3.2.2 Initial material conditions for direct containment heating.

TOP-DOWN/SYSTEM SCALING
OF
REACTOR DAVITY PHENOMENA

RATE OF PRESSURE CHANGE

Prepared by

NOVAK ZUBER AND WULFGANG WULFF



FLOW DIAGRAM AND TOPICS ADDRESSED IN TOP-DOWN/SYSTEM SCALING

PRESSURE RATE OF CHANGE EQUATION

FORMULATION BASED ON:


MASS CONSERVATION EQUATIONS:

- STEAM
- WATER LIQUID
- HYDROGEN
- DEBRIS

ENERGY CONSERVATION EQUATIONS

- GAS (STEAM-HYDROGEN) MIXTURE
- WATER LIQUID
- DEBRIS

MASS AND ENERGY BALANCES AT PHASE INTERFACES



$$\dot{m}_V = \dot{m}_L$$

$$\dot{m}_V h_g - q''_{GL} = \dot{m}_L h_f - q''_L + q''_{DL}$$

Mass and energy balance at the vapor-liquid interface.

Pressure Rate-of-Change Equation (1 of 2):

$$\frac{V_g}{\gamma_m - 1} \frac{dP}{dt} = [W_{wg} H_{wg}^{\|1\|} + W_h H_h]_i - [W_{wg} H_{wg}^{\|2\|} + W_h H_h]_e$$

$$- h_{gs} [T_g^{\|3\|} - T_s] A_{gs} + h_{dg} [T_d^{\|4\|} - T_g] A_{dg}$$

$$+ [\dot{m}_h'' H_h - \dot{m}_{wg}'' H_{wg}] A_{zr}$$

$$+ [\dot{m}_v'' H_v - h_{gl}^{\|6\|} (T_g - T_v)] A_{gl}$$

$\|7\|$

$$+ \frac{P}{\gamma_m - 1} \left[\frac{1}{\rho_{wl}} \frac{dM_{wl}}{dt} + \frac{1}{\rho_d} \frac{dM_d}{dt} \right]$$

$\|8\|$

$$+ P V_g \frac{C_{v,wg} C_{v,h} (\gamma_h - \gamma_{wg})}{R_m^2} \frac{dC}{dt}$$

Pressure Rate-of-Change Equation (2 of 2):

$$\gamma_m = \frac{C_{p,m}}{C_{v,m}} = \frac{(1-C)C_{p,wg} + CC_{p,h}}{(1-C)C_{v,wg} + CC_{v,i}} \quad 2$$

$$R_m = (1-C)R_{wg} + CR_h = C_{p,r} - C_{v,m} \quad 3$$

$$V_g = \alpha_g V_{cv} = (\alpha_w \alpha_{wg} + \alpha_h) V_{cv} \quad 4$$

PROCESSES MODELED IN THE PRESSURE RATE
OF CHANGE (PRC) EQUATION

<u>TERM NO.</u>	:	<u>MODELS THE EFFECTS OF:</u>
1	:	RATE OF STEAM/HYDROGEN ENTHALPY INFLOW
2	:	RATE OF STEAM/HYDROGEN ENTHALPY OUTFLOW
3	:	HEAT TRANSFER RATE - GAS TO STRUCTURES
4	:	HEAT TRANSFER RATE - DEBRIS TO GAS
5	:	ENTHALPY FLOWS DUE TO ZIRCONIUM OXIDATION
6	:	ENTHALPY AND HEAT TRANSFER RATES DUE TO WATER EVAPORATION
7	:	RATE OF WORK TO CHANGE THE AMOUNTS OF WATER LIQUID AND OF DEBRIS
8	:	RATE OF CHANGE OF HYDROGEN MASS CONCENTRATION IN THE MIXTURE

PRC EQUATION (CONT'D)

- * THE PRESSURE RATE OF CHANGE (PRC) EQUATION WAS EXPRESSED IN NON-DIMENSIONAL FORM BY USING INITIAL CONDITIONS AND THE INITIAL GAS ENTHALPY FLOW FROM VESSEL.

- * THE RESULTING Π (TIME-RATIO) GROUPS WERE THEN USED TO ASSESS THE IMPORTANCE OF THE PROCESSES MODELED IN THE PRC EQUATION.

- * SOME OF THESE Π GROUPS ARE SHOWN IN THE FOLLOWING FIGURES.

Effect of Heat Transfer - Gas to Structures:

$$\Pi_{gs} = \frac{h_{gs} [T_{go} - T_{so}]}{W_{go} H_{go}} A_s \quad 1$$

$$= \omega_{gs} \tau_o \quad 2$$

where

$$\omega_{gs} = \frac{h_{gs} [T_{go} - T_{so}]}{\rho_{go} H_{go}} \frac{1}{L_s} \quad 3$$

and

$$\tau_o = \frac{V_{cv}}{Q_{go}} \quad 4$$

$$\frac{A_s}{V_{cv}} = \frac{1}{L_s} \quad 5$$

Effect of Water Liquid:

Assuming: $q_{gl} > q_l$; $q_{dl} \equiv 0$

Then

$$\Pi_{w-1} = \frac{6h_{gl}}{d_{wdo}} \left[\frac{T_{go} - T_{vo}}{W_{go}H_{go}} \right] \frac{H_f}{H_{fg}} [\alpha_w \alpha_{wl} \alpha_{wld}]_o V_{cv} \quad 1$$

If heat transfer is dominated by convection, then

$$\Pi_{w-1} = K_g \frac{6}{d_{wdo}^2} Nu \left[\frac{T_{go} - T_{vo}}{W_{go}H_{go}} \right] \frac{H_f}{H_{fg}} [\alpha_w \alpha_{wl} \alpha_{wld}]_o V_{cv} \quad 2$$

$$= \omega_w \tau_o = \omega_w \frac{V_{co}}{Q_{go}} \quad 3$$

Where

$$\omega_w = a_{go} \frac{6}{d_{wdo}^2} Nu \left[\frac{T_{go} - T_{vo}}{T_{go}} \right] \frac{H_f}{H_{fg}} [\alpha_w \alpha_{wl} \alpha_{wld}]_o \quad 4$$

$$\Pi_{w-2} = \frac{P_\infty}{\gamma_o - 1} \frac{1}{\rho_{wl} H_{fg}} \Pi_{w-1} \quad 5$$

Effect of Zircalloy Oxidation:

Assuming

$$a) \quad \dot{m}_{zrO_2}''' \Delta H V_d = \dot{m}_{zrO_2}'' \Delta H A_{dg}$$

b) parabolic rate equation

Then

$$\Pi_{ch} = 12 \frac{D}{d_{mdo}^2} e^{-\frac{E}{RT_{do}}} \frac{\rho_d \Delta H}{W_{go} H_{go}} [\alpha_d \alpha_{dm} \alpha_{dmd} \alpha_{zr}]_o V_{cv} \quad 1$$

$$= \omega_{ch} \tau_o \quad 2$$

where

$$\omega_{ch} = 12 \frac{D}{d_{mdo}^2} e^{-\frac{E}{RT_{do}}} \frac{\rho_d \Delta H}{\rho_{go} H_{go}} [\alpha_d \alpha_{dm} \alpha_{dmd} \alpha_{zr}]_o \quad 3$$

$$\tau_o = \frac{V_{cv}}{Q_{go}} \quad 4$$

Effect of Heat Transfer - Debris to Gas:

$$\Pi_{dg} = \frac{h_{dg} [T_{do} - T_{go}]}{W_{go} H_{go}} \frac{6}{d_{mdo}} [\alpha_d \alpha_{dm} \alpha_{dmd}]_o V_{cv} \quad 1$$

Assuming heat transfer is dominated by convection, then

$$\begin{aligned} \Pi_{dg} &= 6 \frac{K_g}{d_{mdo}^2} Nu \frac{[T_{do} - T_{go}]}{W_{go} H_{go}} [\alpha_d \alpha_{dm} \alpha_{dmd}]_o V_{cv} \quad 2 \\ &= \omega_{dg} \tau_o \end{aligned}$$

where


$$\omega_{dg} = 6 \frac{a_{go}}{d_{wdo}^2} Nu \frac{[T_{do} - T_{go}]}{T_{go}} [\alpha_d \alpha_{dml} \alpha_{dmd}]_o \quad 3$$

Relative Temperature - Oxidation vs Heat Transfer:

$$\frac{\Pi_{ch}}{\Pi_{dg}} = 2De^{-\frac{E}{RT_{do}}} \frac{1}{Nu} \frac{\rho_d \Delta H \alpha_{zr}}{K_g [T_{do} - T_{go}]} \quad 1$$

$$= 2 \frac{D}{a_{go}} e^{-\frac{E}{RT_d}} \frac{1}{Nu} \frac{\rho_d \Delta H \alpha_{zr}}{c_{p,go} \rho_{go} [T_{do} - T_{go}]} \quad 2$$

BOTTOM-UP/PROCESS SCALING
OF
REACTOR CAVITY PHENOMENA



FLOW DIAGRAM AND TOPICS ADDRESSED IN BOTTOM-UP/PROCESS SCALING OF REACTOR CAVITY PHENOMENA

APPENDIX
SCALING STUDY OF CORIUM DISPERSION IN DCH

Prepared by

Mamoru Ishii*
Purdue University

August 31, 1990

* This work was performed under the Consultant Agreement with Brookhaven National Laboratory (Contract No. 3825) in support of the Nuclear Regulatory Commission.

Table 1. Sample calculations for various parameters in corium dispersion

Case Studied	Jet Disintegration							Impingement	Film Spreading						
	v_{ff}	ϕ	2ϕ	d	d_{max}	d_d	$\frac{v_{ff}^2}{\sigma}$		We_{cr}	We_{im}	δ_i	δ_{min}	δ_{max}	δ_{cavi}	v_f
	(m/s)	(m)	(m)	(mm)	(mm)	(mm)		$\times 10^4$		(cm)	(cm)	(cm)	(cm)	(m/s) $\times 10^3$	
Corium-Steam Full Scale 1000 psi	139.0	17.9	2.00	4.10	12.8	1.45	0.24	192	2.09	5.0	0.4	41.4	9.0	3.20	19.60
Corium-Steam 1/10 Scale 1000 psi	139.0	12.5	0.85	1.30	4.10	1.45	0.24	19.2	1.87	0.5	0.04	4.14	0.9	3.20	10.96
Water-Air Full Scale 1000 psi, 20C	116.5	1.2	0.41	0.07	0.23	1.68	1.28	4.36	1.36	5.0	0.4	41.4	9.0	9.20	23.0
Water-Air 1/10 Scale 200 psi, 20C	50.0	0.6	0.20	0.08	0.26	1.6	0.55	0.4	0.28	0.5	0.04	4.14	0.9	4.00	11.00
Woods metal-Air 1/10 Scale 200 psi, 75C	17.9	1.6	0.56	1.92	6.01	1.11	0.09	17.2	1.13	0.5	0.04	4.14	0.9	1.44	11.00

2-32

APPENDIX

DEBRIS DISPERSAL FROM REACTOR CAVITY DURING LOW
TEMPERATURE SIMULANT TESTS OF DIRECT CONTAINMENT HEATING*

Prepared by

*Salomon Levy***

S. Levy Incorporated

August 31, 1990

* This work was sponsored by Brookhaven National Laboratory under Purchase Order No. 402034 in support of the Nuclear Regulatory Commission Severe Accident Scaling Methodology (SASM).

** The author would like to recognize the extensive help received from Dr. J. Heizer who performed all the test data reduction and their plotting.

TABLE OF CONTENTS

Section	Page
SUMMARY	G.2-1
1.0 INTRODUCTION	G.2-2
2.0 SUMMARY OF SMALL-SCALE LOW TEMPERATURE TESTS WITH NO CHEMICAL REACTIONS	G.2-4
3.0 ENTRAINMENT MECHANISM AND EXISTING CORRELATIONS	G.2-11
3.1 Existing Correlations	G.2-11
3.2 Modifications of Katoaka-Ishii Entrainment Rate for Application to Winfrith Tests	G.2-13
3.3 Correlation of Winfrith Constant Reservoir Pressure Tests	G.2-16
3.4 Application to Blowdown Tests	G.2-23
4.0 INCEPTION OF ENTRAINMENT	G.2-35
5.0 COMPARISON TO BROOKHAVEN CORRELATIONS	G.2-39
6.0 APPLICATION TO NUCLEAR PLANTS	G.2-44
7.0 CONCLUSIONS	G.2-48
8.0 REFERENCES	G.2-49

Entrainment Tests at 1/25 Scale
Various Gases & Liquids





Figure 6
Winfrith Reactor Cavity Entrainment Tests
With Constant Gas Flow Rates

Figure 15

Zion 1/10 Scale Blowdown Tests with 38 mm Orifice



4. CONTENT OF THE REPORT

CONTENTS

VOLUME 1

AN INTEGRATED STRUCTURE AND SCALING METHODOLOGY FOR SEVERE ACCIDENT TECHNICAL ISSUE RESOLUTION

ABSTRACT	
ACKNOWLEDGMENTS	
EXECUTIVE SUMMARY	
ACRONYMS	
INTRODUCTION	

PART A - INTEGRATED STRUCTURE FOR TECHNICAL ISSUE RESOLUTION (ISTIR) FOR SEVERE ACCIDENTS

1. INTRODUCTION	
2. SAFETY ISSUE ACCIDENT SPECIFICATION AND PHENOMENA EVALUATION	
2.1 Specify Issue and Success Criteria	
2.2 Specify Scenario	
2.3 Specify NPP	
2.4 Specify Accident Path	
2.5 Provide PIRT	
3. SEVERE ACCIDENT SCALING METHODOLOGY (SASM).....	
3.1 Experimental Requirements Element	
3.1.1 Specify Experimental Objectives (Step 1)	
3.2 Evaluation and Specification for Experiments, and Testing Element	
3.2.1 Perform Scaling Analyses (Step 2)	
3.2.2 Perform Exploratory Experiment (Step 3)	
3.2.3 Identify Similarity Criteria (Step 4)	
3.2.4 Specify SET Facility and Experiments (Step 5)	
3.2.5 Develop Models and/or Closure Relations (Step 6).....	
3.2.6 Evaluate Scale-up Capability (Step 7)	
3.2.7 Specify IET Facility and Experiments (Step 8)	
3.2.8 Evaluate Effects of Distortions (Step 9)	
3.3 Establish and Document Data Base Element	
3.3.1 Establish Experimental Data Base and Quantify Its Uncertainties (Step 10)	
3.3.2 Provide Documentation (Step 11)	
3.4 A Hierarchical Approach to Scaling	
3.4.1 Needs and Objectives	
3.4.2 Overview	
3.4.3 Characteristics of Severe Accident Scenarios	
3.4.4 A Hierarchical Point of View	
3.4.5 System Decomposition and Hierarchy	
3.4.6 Characteristic Spatial Scales	
3.4.7 Characteristic Time Scales	
3.4.8 Characteristic Time Ratios	
3.4.9 Scale Distortions	
3.4.10 Discussion	
3.4.11 Conclusions	
3.5 Success Criteria for SASM Application	
3.6 Lessons Learned	
3.7 Evaluation Questions for Proposed Severe Accident Experimental Programs	
4. SUMMARY OF THE SASM CAPABILITIES	
5. REFERENCES	

VOLUME 1
AN INTEGRATED STRUCTURE AND SCALING METHODOLOGY
FOR SEVERE ACCIDENT TECHNICAL ISSUE RESOLUTION
[Continued]

PART B - AN APPLICATION TO DIRECT CONTAINMENT HEATING FOR A PWR

- 1. INTRODUCTION
- 2. COMPONENT I - DCH SAFETY ISSUE ACCIDENT SPECIFICATION
AND PHENOMENA EVALUATION
- 2.1 Specify Issue and Success Criteria
- 2.2 Specify Scenario
- 2.3 Specify NPP
- 2.4 Specify Accident Path
- 2.5 Provide PIRT
- 3. COMPONENT II - SEVERE ACCIDENT SCALING METHODOLOGY
APPLICATION TO DCH
- 3.1 Introduction
- 3.2 RPV Failure Conditions (Initial and Boundary Conditions).....
- 3.3 RPV Discharge Phenomena
- 3.3.1 Corium (Solid and Melt) Discharge Phase
- 3.3.2 Multiphase (Corium and Steam) Discharge Phase
- 3.3.3 Single-phase (Steam) Discharge Phase
- 3.4 Reactor Cavity Phenomena.....
- 3.4.1 Top-down/System Scaling Approach
- 3.4.1.1 Rate of Pressure Change
- 3.4.1.2 Evaluation of Scaling Groups
- 3.4.2 Bottom-up/Process Approach
- 3.4.2.1 Corium Discharge and Dispersion
- 3.4.2.2 Debris Dispersal from Reactor Cavity
- 4. SUMMARY OF DCH APPLICATION
- 5. REFERENCES

SUMMARY AND CONCLUSIONS

VOLUME 2
AN INTEGRATED STRUCTURE AND SCALING METHODOLOGY
FOR SEVERE ACCIDENT TECHNICAL ISSUE RESOLUTION

SUPPORTING INFORMATION FOR METHODOLOGY DEVELOPMENT

- APPENDIX A--ADDITIONAL DESCRIPTION OF THE INTEGRATED PROGRAM
STRUCTURE FOR TECHNICAL ISSUE RESOLUTION
(Compiled by G. E. Wilson)
- APPENDIX B--LESSONS LEARNED SUPPORTING INFORMATION
(Compiled by G. E. Wilson)
- APPENDIX C--SUPPORTING INFORMATION FOR EVALUATION QUESTIONS FOR
PROPOSED SEVERE ACCIDENT EXPERIMENTAL PROGRAMS
(Compiled by G. E. Wilson)
- APPENDIX D--A HIERARCHICAL APPROACH TO SCALING
(Prepared by N. Zuber)

DCH PHENOMENA IDENTIFICATION AND RANKING

- APPENDIX E--CONFIRMATION OF DCH PHENOMENA RANKING USING THE
AHP METHODOLOGY
(Prepared by G. E. Wilson and M. Pilch)

REACTOR PRESSURE VESSEL FAILURE CONDITIONS

- APPENDIX F--TYPICAL INITIAL AND BOUNDARY CONDITIONS FOR SURRY PLANT .
(Prepared by M. Pilch)
- APPENDIX G--AMOUNT OF MATERIAL INVOLVED IN DCH CONTAINMENT DURING
A PWR STATION BLACKOUT TRANSIENT
(Prepared by S. Levy)

REACTOR PRESSURE VESSEL DISCHARGE PHENOMENA

- APPENDIX H--CORIUM DISCHARGE PHENOMENA
(Prepared by F. Moody)
- APPENDIX I--HOLE ABLATION
(Prepared by F. Moody)
- APPENDIX J--SOLID DEBRIS RETENTION IN VESSEL
(Prepared by P. Griffith)
- APPENDIX K--SINGLE PHASE (STEAM) DISCHARGE
(Prepared by W. Wulff)

REACTOR CAVITY PHENOMENA

- APPENDIX L--RATE OF PRESSURE CHANGE
(Prepared by N. Zuber and W. Wulff)
- APPENDIX M--EVALUATION OF SCALING GROUPS
(Prepared by J. Valente)
- APPENDIX N--SCALING STUDY OF CORIUM DISPERSION IN DCH
(Prepared by M. Ishii)
- APPENDIX O--DEBRIS DISPERSAL FROM REACTOR CAVITY DURING LOW
TEMPERATURE TESTS OF DCH
(Prepared by S. Levy)

5. CONCLUSIONS

CONCLUSIONS

IN THIS PRESENTATION WE HAVE OUTLINED RATHER BRIEFLY, THE RESULTS OF THE WORK PERFORMED TO DATE, BY THE TPG ON DEVELOPING A SEVERE ACCIDENT SCALING METHODOLOGY. IN PARTICULAR:

- 1) WE OUTLINED THE **ISTIR** METHODOLOGY FOR INTEGRATING EXPERIMENTS, ANALYSIS, AND UNCERTAINTY QUANTIFICATION TO ENSURE THEREBY, A COST-EFFECTIVE AND TIMELY RESOLUTION OF A TECHNICAL ISSUE.

THE **ISTIR** METHODOLOGY IS SYSTEMATIC, COMPREHENSIVE, AUDITABLE, AND PRACTICAL AS NEEDED BY A REGULATORY AGENCY.

- 2) WE DISCUSSED **SASM** DEVELOPED BY THE TPG TO ENSURE THAT EXPERIMENTAL DATA, SPECIAL MODELS, AND/OR COMPUTER CODES USED TO RESOLVE A TECHNICAL ISSUE, HAVE THE CAPABILITY TO SCALE-UP PROCESSES TO CONDITIONS RELEVANT TO NUCLEAR POWER PLANT OPERATION.

CONCLUSIONS (CONT'D)

- 3) WE DISCUSSED A HIERARCHICAL APPROACH, THAT IS, A TWO-TIER SCALING METHODOLOGY TO PROVIDE FOR SUFFICIENCY AND EFFICIENCY. ONE APPROACH IS BASED ON TOP-DOWN (SYSTEM) SCALING THE OTHER ON THE BOTTOM-UP (PROCESS) SCALING.
- 4) WE REVIEWED THE RESULTS OBTAINED BY APPLYING ISTIR AND SASM TO THE DCH PROBLEM.
- 5) THE CHARACTERISTIC TIME RATIOS:

$$\Pi_P = \omega_P \tau_{CV}$$

INCORPORATE THE CHARACTERISTIC TEMPORAL AND SPATIAL SCALES OF THE SYSTEM (CONTROL VOLUME / AND OF A PARTICULAR RATE PROCESS.

CONSEQUENTLY, THEY COMBINE THE SYSTEM AND PROCESS VIEW POINTS.

CONCLUSIONS (CONT'D)

6. THE CHARACTERISTIC TIME RATIOS TAKE DIRECTLY INTO ACCOUNT THE EFFECTS OF:
 - A) INITIAL CONDITIONS
 - B) BOUNDARY CONDITIONS
 - C) PRESENCE OF OTHER CONSTITUENTS AND/OR PHASES.

7. THE SAME YARDSTICK IS USED TO EVALUATE (MEASURE) THE IMPORTANCE OF VARIOUS RATE PROCESSES.

YARDSTICK:

SYSTEM RESPONSE: τ_{CV}

AND INITIAL CONDITIONS

CONCLUSIONS (CONT'D)

8. THE CHARACTERISTIC TIME RATIOS PROVIDE A HIERARCHICAL STRUCTURE FOR:
 - A) RANKING VARIOUS PROCESSES, AND
 - B) PRIORITY DISCRIMINATION

- 9) THE DIMENSIONLESS GROUPS PROVIDE A TECHNICALLY JUSTIFIABLE RATIONALE FOR:
 - A) ESTABLISHING THE ORDER IN WHICH THE SIMILARITY BETWEEN PHENOMENA IN TEST FACILITY AND **NPP** SHOULD BE PRESERVED,

 - B) SPECIFYING FACILITY DESIGN AND TEST CONDITIONS (INITIAL AND BOUNDARY), AND

 - C) IDENTIFYING WHICH PHENOMENA AND/OR PROCESSES NEED TO BE EXAMINED IN MORE DETAIL (AT A LOWER HIERARCHICAL LEVEL) AND IN WHAT ORDER.

CONCLUSIONS (CONT'D)

- 10) THE CHARACTERISTIC TIME RATIOS PROVIDE A PHYSICALLY BASED FRAMEWORK FOR SENSITIVITY CALCULATIONS AND UNCERTAINTY QUANTIFICATION.

- 11) THE PROPOSED SCALING METHODOLOGY IS
 - SYSTEMATIC
 - COMPREHENSIVE
 - AUDITABLE
 - TRACEABLE
 - WITHOUT ARM WAVING

USE OF SASM IN THE SEVERE ACCIDENT
RESEARCH PROGRAM AND THE ROLE
OF SASM IN SEVERE ACCIDENT ISSUE RESOLUTION

BRIAN W. SHERON, DIRECTOR
Division of Systems Research
Office of Nuclear Regulatory Research

Presented to the Advisory Committee on
Reactor Safeguards

December 7, 1990

- o IN LATTER PART OF 1988, RES OFFICE DIRECTOR AND DSR DIVISION DIRECTOR WERE CONCERNED THAT SOUND SCALING RATIONALE DID NOT EXIST FOR ONGOING SEVERE ACCIDENT EXPERIMENTS
- o DIVISION DIRECTOR ASKED N. ZUBER TO LOOK INTO PROBLEM AND DETERMINE IF A GENERAL SCALING METHODOLOGY FOR SEVERE ACCIDENT EXPERIMENTS COULD BE DEVELOPED, AND IF SO, TO DEVELOP SUCH A METHODOLOGY
- o OBJECT WAS TO MAKE METHODOLOGY AVAILABLE TO SEVERE ACCIDENT EXPERIMENTERS FOR GUIDANCE IN DEVELOPING SCALING RATIONALE FOR SPECIFIC EXPERIMENTS
- o ZUBER FORMED HIS SEVERE ACCIDENT SCALING METHODOLOGY (SASM) TECHNICAL PROGRAM GROUP (TPG) CONSISTING OF 17 EXPERTS FROM VARIOUS FIELDS RELATED TO SCALING AND SEVERE ACCIDENTS
- o EXPERIMENTS THAT PROMPTED DIVISION DIRECTOR'S CONCERN WERE SURTSEY DCH EXPERIMENTS AT SNL. ZUBER TOLD HE COULD USE DCH AS AN EXAMPLE TO DEMONSTRATE METHODOLOGY
- o CHARTER OF GROUP WAS TO DEVELOP METHODOLOGY WITH EXAMPLE APPLICATION; EACH EXPERIMENTER WAS STILL RESPONSIBLE FOR DEVELOPING SCALING BASIS FOR SPECIFIC EXPERIMENTS, AND AEB STAFF WAS STILL RESPONSIBLE FOR REVIEW AND APPROVAL OF TESTS AND TESTING BASIS

- o SNL IS RESPONSIBLE FOR ALL FACETS OF SURTSEY TESTING, INCLUDING BASIS AND SCALING RATIONALE FOR TESTS, CONDUCT OF TESTS AND ASSOCIATED ES&H
- o ALTHOUGH SASM TPG DEVELOPED EXAMPLE SCALING GROUPS FOR DCH, SNL CHOSE TO DEVELOP ITS OWN SCALING GROUPS TO SUPPORT PROPOSED SURTSEY TESTS
- o HOWEVER, SNL PARTICIPATED EXTENSIVELY IN TPG, AND WAS INSTRUCTED TO UTILIZE TPG-DEVELOPED METHODOLOGY AS IT EVOLVED IN DERIVING SCALING FACTORS FOR SURTSEY.
- o PLAN IS FOR STAFF TO REVIEW SNL SCALING REPORT, WITH INPUT FROM SELECTED OUTSIDE EXPERTS. STAFF APPROVAL WILL AUTHORIZE SNL TO COMMENCE DCH TESTING
- o EXPECT TO COMMENCE TESTING IN MARCH, 1991
- o SASM METHODOLOGY REPORT NOT YET COMPLETED. TPG WILL BE DISSOLVED WHEN METHODOLOGY REPORT COMPLETED. EXPECT COMPLETION BY END OF YEAR.
- o ADEQUACY OF SCALING WILL BE REVIEWED AFTER FIRST TEST, AND ADJUSTMENTS IN TESTING MATRIX AND CONDITIONS WILL BE MADE AS APPROPRIATE.
- o SEPARATE EFFECTS TESTS WILL ALSO BE RUN THAT WILL CONTRIBUTE TO OVERALL SCALING EVALUATION.

- o USE OF SASM IN RESOLUTION OF DCH AS A SEVERE ACCIDENT ISSUE
 - DCH ISSUE IS COMPLEX AND MULTIFACETED. EXPERIMENTS ON HIGH PRESSURE MELT EJECTION ARE ONE FACET OF THE ISSUE
 - OVERALL ISSUE IS "WHAT IS THE RISK ASSOCIATED WITH THE DIRECT CONTAINMENT HEATING PHENOMENA, AND WHAT, IF ANY, PLANT MODIFICATIONS SHOULD BE MADE TO REDUCE THIS RISK?"
 - SASM ONLY PROVIDES THE BASIS FOR ASSURING THAT EXPERIMENTAL DATA IS MEANINGFUL (E.G., PROPER SCALE, APPROPRIATE INITIAL AND BOUNDARY CONDITIONS) AND CAN BE CONFIDENTLY APPLIED TO VALIDATE CODES FOR USE IN CALCULATING LARGE PLANT PERFORMANCE

- o CURRENTLY, THE ONLY "FIX" FOR DCH IS INTENTIONAL DEPRESSURIZATION
- o ALSO, CURRENTLY, NO OPERATING PWRS CALL FOR OPERATORS TO INTENTIONALLY DEPRESSURIZE THE PRIMARY SYSTEM WHEN NO AC POWER IS AVAILABLE
- o THE QUESTION WE ARE TRYING TO ANSWER IS, "IS INTENTIONAL DEPRESSURIZATION A COST-BENEFICIAL AND PRACTICAL FIX FOR DCH (I.E., SHOULD WE REQUIRE INTENTIONAL DEPRESSURIZATION)?"
- o CURRENTLY, STAFF APPROACH IS AS FOLLOWS:
 - (1) ESTABLISH LIKELIHOOD OF ACCIDENTS THAT PROCEED TO CORE MELT AT HIGH PRESSURE (NUREG-1150 GIVES US GOOD INSIGHTS INTO THIS LIKELIHOOD)
 - (2) ESTABLISH LIKELIHOOD THAT SYSTEM WILL BE DEPRESSURIZED PRIOR TO LOWER VESSEL HEAD FAILURE AT HIGH PRESSURE (I. E., WHAT IS THE LIKELIHOOD THE PRIMARY SYSTEM WILL DEPRESSURIZE DUE TO STUCK OPEN S/RV, PUMP SEAL FAILURE, INTENTIONAL OPERATOR ACTION, OR CREEP RUPTURE FAILURE OF PRIMARY PIPING)
 - (3) ESTABLISH LIKELIHOOD THAT HIGH PRESSURE MELT EJECTION WILL LEAD TO CONTAINMENT PRESSURES IN EXCESS OF ULTIMATE PRESSURE CAPABILITY

(4) SHOW REDUCTION IN CONTAINMENT FAILURE PROBABILITY IF INTENTIONAL DEPRESSURIZATION IS REQUIRED AND ESTABLISH COST/BENEFIT

(5) DETERMINE GENERIC APPLICABILITY OF ANALYSES

ITEM (3) WILL BE DETERMINED THROUGH USE OF CODE ANALYSES, USING CODES VALIDATED AGAINST APPLICABLE EXPERIMENTS. SASM IS APPLIED TO ENSURE EXPERIMENTS ARE APPLICABLE.