



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

October 18, 1982

JAMES P. McGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Broken Fire Barrier
Penetrations
Reference: LER 82-083/03 L-0
AECM-82/485

During cold shutdown, as required by a planned maintenance activity for routing additional electrical conduit, nine fire barrier penetrations were broken. This report is being submitted per T.S.3.7.7. and 6.9.1.13.b. The penetrations are located in the Auxiliary Building and Control Building. Attached is LER 82-083/03 L-0.

Yours truly,

JPM:sap
Attachment

- cc: Mr. N. L. Stampley (w/a)
- Mr. R. B. McGehee (w/o)
- Mr. T. B. Conner (w/o)
- Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

8210220278 821018
PDR ADOCK 05000416
S PDR

Member Middle South Utilities System

OFFICIAL COPY

TE 22

82 OCT 19 AID: 0
REGION II
ATLANTA, GEORGIA