



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

VIRGINIA ELECTRIC AND POWER COMPANY

DOCKET NO. 50-281

SURRY POWER STATION, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 145
License No. DPR-37

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Virginia Electric and Power Company (the licensee) dated September 14, 1990, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 3.B of Facility Operating License No. DPR-37 is hereby amended to read as follows:


9012120296 901204
PDR ADOCK 05000281
P PIC

(B) Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 145, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Herbert N. Berkow, Director
Project Directorate II-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: December 4, 1990

ATTACHMENT TO LICENSE AMENDMENT

AMENDMENT NO. 145 FACILITY OPERATING LICENSE NO. DPR-37

DOCKET NO. 50-281

Revise Appendix A as follows:

Remove Pages

TS 4.4-2

Insert Pages

TS 4.4-2

- b. The leakage rate test will be performed at a pressure of at least 39.2 psig (P_a).
 - c. The measured leakage rate L_{am} shall not exceed 75% of the design basis accident leakage rate (L_a) of 0.1 weight percent per 24 hours at pressure P_a .
2. Type B and C tests will be performed at a pressure of at least 39.2 psig (P_a) in accordance with the provisions of Appendix J, Section III.B and C.*† Also, within 72 hours after use of the personnel airlock, the seals will be tested at least at the peak calculated accident pressure to verify that they are properly sealed.

C. Acceptance Criteria

Type A, B, and C tests will be considered to be satisfactory if the acceptance criteria delineated in Appendix J, Sections III.A.5(b), III.B.3, and III.C.3 are met.

D. Retest Schedule

The retest schedules for Type A, B, and C tests will be in accordance with Section III.D of Appendix J.*†

E. Inspection and Reporting of Tests

Inspection and reporting of tests will be in accordance with Section V of Appendix J.

* Type C testing for Unit 1 can be deferred beyond the 2 year Appendix J requirement until the end of Operating Cycle 10 but the deferral shall expire no later than December 31, 1990 in accordance with the NRC exemption received on June 22, 1990.

† Type C testing for Unit 2 can be deferred beyond the 2 year Appendix J requirement until the end of Operating Cycle 10 but the deferral shall expire no later than April 30, 1991 in accordance with the NRC exemption dated September 26, 1990.