



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

OMAHA PUBLIC POWER DISTRICT

DOCKET NO. 50-285

FORT CALHOUN STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 135
License No. DPR-40

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by the Omaha Public Power District (the licensee) dated September 28, 1990, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, Facility Operating License No. DPR-40 is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 3.B. of Facility Operating License No. DPR-40 is hereby amended to read as follows:

B. Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 135, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. The license amendment is effective as of its date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Theodore R. Quay, Director
Project Directorate IV-1
Division of Reactor Projects - III,
IV, V and Special Projects
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: December 3, 1990

ATTACHMENT TO LICENSE AMENDMENT NO. 135

FACILITY OPERATING LICENSE NO. DPR-40

DOCKET NO. 50-285

Revise Appendix "A" Technical Specifications as indicated below. The revised page is identified by amendment number and contains vertical lines indicating the area of change.

REMOVE PAGE

3-55

INSERT PAGE

3-55

3.0 SURVEILLANCE REQUIREMENTS

3.6 Safety Injection and Containment Cooling Systems Tests (Continued)

(3) Containment Recirculating Air Cooling and Filtering System

- a. Emergency mode damper, automatic valve, fan, fusible link automatic damper, and raw water backup valve operation will be checked for operability during each refueling outage.
- b. Each fan and remotely operated damper required to function during accident conditions will be exercised at intervals not to exceed three months.
- c. Each air filtering circuit will be operated at least 10 hours every month.
- d. A visual examination of the HEPA and charcoal filters will be made during each refueling outage to insure that leak paths do not exist.
- e. Measurement of pressure drop across the combined HEPA and charcoal adsorber banks shall be performed at least once per plant operating cycle to verify a pressure drop of less than 6 inches of water at system design flow.
- f. Fans shall be shown to operate within +/-10% design flow during each refueling outage.