

December 10, 1990

Docket No. 50-344

Mr. James E. Cross
Vice President, Nuclear
Portland General Electric Company
121 S.W. Salmon Street
Portland, Oregon 97204

Dear Mr. Cross:

SUBJECT: UNIMPLEMENTED GENERIC SAFETY ISSUES AT TROJAN NUCLEAR PLANT

On April 25, 1990, the staff issued Generic Letter 90-04 which requested information concerning the implementation status of certain generic safety issues (GSIs) at your facility. Based on your response to this Generic Letter, dated July 13, 1990, our own records and discussions with your staff, we have updated our database on GSI implementation status. The results of this effort were presented to the Commission at a meeting on October 25, 1990.

The enclosure to this letter summarizes the staff's understanding of the current status of those GSIs which remain unimplemented at the Trojan Nuclear Plant. We appreciate the assistance you provided in responding to Generic Letter 90-04 and we encourage your timely completion of those GSIs listed in the enclosure.

Please contact me if you have any questions or comments about the enclosed information.

Sincerely,

Roby B. Bevan, Project Manager
Project Directorate V
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

Enclosure:
As stated

cc w/enclosure:
See next page

DISTRIBUTION

Docket File NRC & Local PDRs PD5 Reading BBoger MVirgilio
DFoster RBevan OGC ACRS (10) RZimmerman, RV

9012120332 901210
PDR ADOCK 05000344
P PDC

DF01
11

OFC	:LA/PD5/DRP345	:PM/PD5/DRP345	:D/PD5/DRP345	:	:
NAME	:DFoster	:RBevan:sg	:DM	:	:
DATE	:12/6/90	:12/6/90	:12/10/90	:	:

Mr. James E. Cross
Portland General Electric Company

Trojan Nuclear Plant

cc:
Senior Resident Inspector
U.S. Nuclear Regulatory Commission
Trojan Nuclear Plant
Post Office Box 0
Rainier, Oregon 97048

Mr. Michael J. Sykes, Chairman
Board of County Commissioners
Columbia County
St. Helens, Oregon 97501

Mr. David Stewart-Smith
Oregon Department of Energy
Salem, Oregon 97310

Regional Administrator, Region V
U.S. Nuclear Regulatory Commission
1450 Maria Lane, Suite 210
Walnut Creek, California 94596

ENCLOSURE

UNIMPLEMENTED GSIs AT TROJAN NUCLEAR PLANT

<u>GSI NO.</u>	<u>TITLE</u>	<u>PROJECTED IMPLEMENTATION DATE</u>	<u>REMARKS</u>
43	Reliability of Air Systems	06/30/91	Will be com- pleted during Refuel 6
51	Improving the Reliability of Open-Cycle Service Water Systems	03/31/92	Procedures under development
67.3.3	Improved Accident Monitoring	TBD	Neutron flux monitoring issue under appeal
75	Salem ATWS Item 2.2.2, Vendor Interface for Safety-Related Components	12/31/90	Program changes under development
99	RCS/RHR Suction Line Valve Interlock on PWRs	06/30/91	Interlocks to be removed during Refuel 6