NRC FORM 356 (12-81) APPROVED BY OMB 3150-0011 EXPIRES 4-30-82 U.S. NUCLEAR REGULATORY COMMISSION LICENSEE EVENT REPORT CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION) 0 - 0 0 0 0 - 0 0 3 4 1 1 1 0 4 LICENSE NUMBER 25 LICENSE TYPE 30 CV 1 (2) 0 1 CS 01 CON'T REPORT L 6 0 5 0 0 0 3 9 5 7 0 9 1 6 8 2 8 1 0 1 5 8 2 9 SOURCE 10 DOCKET NUMBER 10 1 6 8 2 8 1 0 1 5 8 2 9 0 1 EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10) 0 2 The Action Statement of Technical Specification 3.7.9.2(e) was entered as a result of smoke detectors associated with the Preaction Sprinkler System on Control 0 3 [Euilding 400' elevation being removed so that welding could be performed in the 0 4 Jarea without affecting the Sprinkler System. There were no adverse consequences 0 5 since the Tech. Spec. Action Statement was met with no redundant equipment in the 0 6 same area, and a one hour fire watch patrol implemented. 0 7 0 8 80 VALVE CAUSE COMP. CODE CAUSE COMPONENT CODE (12) (13) Z 0 9 B X Z Х SEQUENTIAL CODE REPORT REVISION NC. EVENT YEAR LER/RO REPORT NUMBER (17) 8 2 0 0 5 0 3 L 0 SUBMITTED COMPONENT METHOD SUPPLIER FUTURE EFFECT NPRD-4 ACTION (26) (22) HOURS TAKEN ACTION ON PLAN Y 23 N 24 Z 25 18 X 19 Z 20 Z (21) 0 0 0 0 Z 9 9 9 X CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27) <sup>1</sup> <sup>0</sup> Due to welding being performed in the area, the smoke detectors were removed to avoid tripping the Sprinkler System deluge valve. Corrective action was to 1 1 comply with Tech. Spec. Action Statement by having a one hour fire watch patrol 2 implemented for areas which do not have redundant equipment. The detectors were 3 subsequently reinstalled and the Sprinkler System verified to be functional. 4 1 METHOD OF FACILIT (30) OTHER STATUS DISCOVERY DESCRIPTION (32) STATUS B 28 0 0 0 29 Z 31 N/A 12 ACTIVITY CONTENT (35) LOCATION OF RELEASE (36) AMOUNT OF ACTIVITY Z 33 Z 34 6 N/A 1 N/A 80 DESCRIPTION (39) 0 0 37 Z 38 0 N/A 80 11 12 PERSONNEL INJURIES NUMBER 0 0 0 0 N/A 1 8 80 11 12 LOSS OF OR DAMAGE TO FACILITY B210220346 B21015 PDR ADOCK 05000395 Z (42) 9 N/A PDR PUBLICITY ISSUED DESCRIPTION 45 NRC USE ONLY 2 0 N 44 N/A PHONE: (803) 345-5209 NAME OF PREPARER A. R. Koon, Jr.

1