



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

October 18, 1982

JAMES P. McGAUGHY, JR.  
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Region II  
101 Marietta St., N.W., Suite 3100  
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station  
Unit 1  
Docket No. 50-416  
License No. NPF-13  
File 0260/L-835.0  
Secondary Containment  
Integrity - Three Secondary  
Containment Penetrations  
Opened for Cable Routing  
Reference: LER 82-085/03 L-0  
AECM-82/486

While performing work under Design Change Package 82-4145 issued on September 24, 1982 for completion of the original construction of the heat tracing portion of the Drywell Monitoring System, three secondary containment penetrations were opened for cable routing. This report is being submitted per T.S.6.9.1.13.b and T.S.3.7.7. Attached is LER 82-085/03 L-0.

Yours truly,

JPM:sap  
Attachment

cc: Mr. N. L. Stampley (w/a)  
Mr. R. B. McGehee (w/o)  
Mr. T. B. Conner (w/o)  
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Document Control Desk (w/a)  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

8210220428 821018  
PDR ADOCK 05000416  
S PDR

Member Middle South Utilities System

OFFICIAL COPY

IE 22

02 OCT 19 10:00  
REGION II  
ATLANTA, GEORGIA