

USNRC REGION II
ATLANTA, GEORGIA

82 AUG 30 AIO: 03

August 19, 1982
L-82-362

Mr. James P. O'Reilly
Regional Administrator, Region II
U.S. Nuclear Regulatory Commission
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

Re: St. Lucie Unit 1
Docket No. 50-335
IE Inspection Report 82-17
Additional Information

In response to a telephone conversation on August 2, 1982, between your Mr. E. Girard and Mr. R. Stevens of this office, the following information is submitted.

1. NRC Concern: The ISI report submitted with the Annual Report was no-readable. Please resubmit.

Response: Attached is an original computer printout of the ISI report.

2. NRC Concern: The response refers to the Annual Report and the steam generator report. Why wasn't the ISI report submitted within the required 90 days?

Response: Florida Power & Light has not in the past submitted reports of Inservice Inspections on St. Lucie Unit 1 because Technical Specification 4.4.10 specifies reporting of any abnormal degradation, but does not specify the 90 day report required per Section XI IWA 6000. Furthermore, Technical Specification 4.4.10 requires inspections to be performed per the applicable requirements of Section XI interpreted to mean Subsection IWB for Class 1, IWC for Class 2, and IWD for Class 3. We will, however, in the future, submit reports of Inservice Inspection at St. Lucie Unit 1 within 90 days of completion of the inspection outage.

3. NRC Concern: Does corrective action to prevent recurrence also apply to the ISI reports?

Response: Yes. The ISI report has also been placed on the operations department tracking system.

4. NRC Concern: Are reports of previous Inservice Inspections available on site for inspection?

8210220451 820819
PDR ADOCK 05000335
G PDR


IE01

Re: St. Lucie Unit 1
Docket No. 50-335
IE Inspection Report 82-17
Additional Information

Response: Yes. Reports of previous Inservice Inspections are available on site for inspection with the exception of the St. Lucie 1 Steam Generator eddy current tests which were conducted during the November 1981 and May 1982 outages. These reports are undergoing final review and are available in draft form at the corporate offices.

In reference to your letter of August 13, 1982, the above additional information is our supplemental response to Inspection Report 82-17. However, on August 13, 1982, our Mr. Stevens informed your Mr. Girard that the completed response would not be submitted on August 12, 1982, but rather the week of August 16, 1982.

Very truly yours,



Robert E. Uhrig
Vice President
Advanced Systems and Technology

REU/RJS/pw

Attachment

cc: Harold F. Reis, Esquire