



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

October 8, 1982

JAMES P. McGAUGHY, JR.
ASSISTANT VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Smoke Detector Inadvertant
Alarm
Reference: LER 82-073/03 L-0
AECM-82/469

92 OCT 12 10:00

USNRC REGION II
ATLANTA, GEORGIA

On September 9, 1982 at 1600 hours, the Auxiliary Building zone 2-6 smoke detectors alarmed with no fire present. The smoke detectors were deactivated and an hourly fire patrol established pursuant to T.S.3.3.7.9. Attached is LER 82-073/03 L-0.

Yours truly,

J.P. McGaughey
for J.P. McGaughey

JPM:sap
Attachment

cc: Mr. N. L. Stampley (w/a)
Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

8210220458 821008
PDR ADOCK 05000416
S PDR

OFFICIAL COPY

IE 22