

November 30, 1990

Docket No. 50-265

Mr. Thomas J. Kovach
Nuclear Licensing Manager
Commonwealth Edison Company-Suite 300
OPUS West III
1400 OPUS Place
Downers Grove, Illinois 60515

Dear Mr. Kovach:

SUBJECT: CONTAINMENT INTEGRATED LEAK RATE TEST - QUAD CITIES, UNIT 2

By letter dated July 26, 1990, you requested our review and approval of the Type A test schedule for Quad Cities, Unit 2, as required by 10 CFR Part 50, Appendix J, and the Technical Specifications (TS). We reviewed your proposal to schedule the next Unit 2 Type A test for the fall of 1991. Since this represents the next refueling outage after the last two consecutive Unit 2 Type A test failures, we conclude that your schedule complies with the requirements of Appendix J, Section III.A.6 and applicable TS.

Sincerely,

Original Signed By:

Leonard N. Olshan, Project Manager
Project Directorate III-2
Division of Reactor Projects III/IV/V
Office of Nuclear Reactor Regulation

cc: See next page

DISTRIBUTION

Docket File

PDIII-2 r/f

JZwolinski

LOlshan

EJordan

PDIII-2 Plant File

NRC & Local PDRs

BBoger

CMoore

OGC

ACRS(10)

WShafer, RIII

| | | | | | | |
|------|------------|------------|------------|---|---|---|
| OFC | PDIII-2/LA | PDIII-2/PM | PDIII-2/RO | : | : | : |
| NAME | CMoore | LOlshan:tg | RBarrett | : | : | : |
| DATE | 11/20/90 | 11/29/90 | 11/30/90 | : | : | : |

OFFICIAL RECORD COPY

Document Name: CONTAINMENT LEAK RATE TEST

9012130175 901130
PDR ADOCK 05000265
P PNU

DF01
110

Mr. Thomas J. Kovach
Commonwealth Edison Company

Quad Cities Nuclear Power Station
Unit Nos. 1 and 2

cc:

Mr. Stephen E. Shelton
Vice President
Iowa-Illinois Gas and
Electric Company
P. O. Box 4350
Davenport, Iowa 52808

Michael I. Miller, Esq.
Sidley and Austin
One First National Plaza
Chicago, Illinois 60690

Mr. Richard Bax
Station Manager
Quad Cities Nuclear Power Station
22710 206th Avenue North
Cordova, Illinois 61242

Resident Inspector
U. S. Nuclear Regulatory Commission
22712 206th Avenue North
Cordova, Illinois 61242

Chairman
Rock Island County Board
of Supervisors
1504 3rd Avenue
Rock Island County Office Bldg.
Rock Island, Illinois 61201

Illinois Department of Nuclear Safety
Office of Nuclear Facility Safety
1035 Outer Park Drive
Springfield, Illinois 62704

Regional Administrator, Region III
U. S. Nuclear Regulatory Commission
799 Roosevelt Road, Bldg. #4
Glen Ellyn, Illinois 60137

Robert Neumann
Office of Public Counsel
State of Illinois Center
100 W. Randolph
Suite 11-300
Chicago, Illinois 60601