

December 11, 1990

Mr. Ted C. Feigenbaum
President and Chief Executive Officer
New Hampshire Yankee Division
Public Service Company of New Hampshire
Post Office Box 300
Seabrook, New Hampshire 03874

Dear Mr. Feigenbaum:

SUBJECT: UNIMPLEMENTED GENERIC SAFETY ISSUES AT SEABROOK STATION, UNIT 1

On April 25, 1990 the staff issued Generic Letter 90-04 which requested information concerning the implementation status of certain generic safety issues (GSIs) at your facility. Based on your response to this Generic Letter, dated July 13, 1990, our own records and discussions with your staff, we have updated our database on GSI implementation status. The results of this effort were presented to the Commission at a meeting on October 25, 1990.

The enclosure to this letter summarizes the staff's understanding of the current status of those GSIs which remain unimplemented at Seabrook. We appreciate the assistance you provided in responding to Generic Letter 90-04 and we encourage your timely completion of those GSIs listed in the enclosure.

Please contact me if you have any questions or comments about the enclosed information.

Sincerely,

Original signed by:

Eric J. Leeds, Acting Project Manager
Project Director: I-3
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosure:
As stated

cc w/enclosure:
See next page

LA:PDIA
MRushbrook

12/10/90

PM:PDI-3(A)
EJLeeds:mes

12/11/90

D:PDI-3
RHWessman

12/11/90

OFFICIAL RECORD COPY
Document Name: SE GSI LETTER

9012130355 901211
PDR ADOCK 05000443
PDC

DF01
41

Mr. Ted C. Feigenbaum

cc:

Thomas Dignan, Esq.
John A. Ritscher, Esq.
Ropes and Gray
225 Franklin Street
Boston, Massachusetts 02110

Dr. Murray Tye, President
Sun Valley Association
209 Summer Street
Haverhill, Massachusetts

Barbara J. Saint Andres, Esquire
Kopelman & Paige, P.C.
Counsel for Amesbury, Newburyport &
Salisbury
77 Franklin Street
Boston, Massachusetts 02110

Robert Backus, Esq.
Backus, Meyer and Solomon
116 Lowell Street
Manchester, New Hampshire 03106

Diane Curran, Esq.
Harmon and Weiss
2001 S Street, N.W.
Suite 430
Washington, DC 20009

Mr. Peter Brann
Assistant Attorney General
State House, Station #6
Augusta, Maine 04333

Seacoast Anti-Pollution League
5 Market Street
Portsmouth, New Hampshire 03801

Resident Inspector
U.S. Nuclear Regulatory Commission
Seabrook Nuclear Power Station
Post Office Box 1149
Seabrook, New Hampshire 03874

Mr. T. L. Harpster
Public Service Company of New Hampshire
Post Office Box 300
Seabrook, New Hampshire 03874

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

Ashod N. Amirian, Esq.
145 Main Street,
P.O. Box 38
Bradford, Massachusetts 03801

Paul McEachern, Esquire
25 Maplewood Avenue,
P.O. Box 60
Portsmouth, New Hampshire 03801

Mr. Alfred V. Sargent
Chairman
Board of Selectmen
Salisbury, Massachusetts 01960

Senator Gordon J. Humphrey
U.S. Senate
ATTN: Tom Burack
Washington, D.C. 20510

Durham Board of Selectmen
Town of Durham
Durham, New Hampshire 03824

Board of Selectmen
Town of Hampton Falls
Drinkwater Road
Hampton Falls, New Hampshire 03844

Chairman, Board of Selectmen
RFD 2
South Hampton, New Hampshire 01950

R. Scott Hill-Whilton, Esquire
Lagoulis, Clark, Hill-Whilton
& Rotondi
79 State Street
Newburyport Massachusetts 01950

Board of Selectmen
Town of Amesbury
Town Hall
Amesbury, Massachusetts

Mr. Ted C. Feigenbaum

cc:

Town of Exeter
10 Front Street
Exeter, New Hampshire 03823

Gerald Garfield, Esq.
Day, Berry and Howard
City Place
Hartford, Connecticut 06103-3499

Mr. J. F. Opeka
Northeast Utilities
P.O. Box 270
Hartford, Connecticut 06141-0270

Mr. R. M. Kacich
Northeast Utilities Service Company
P. O. Box 270
Hartford, Connecticut 06141-0270

Jane Spector
Federal Energy Regulatory Commission
825 North Capital Street, N.E.
Room 8105
Washington, D.C. 20426

Mr. Rob Sweeney
Three Metro Center
Suite 610
Bethesda, Maryland 20814

Mr. George L. Iverson, Director
New Hampshire Office Of Emergency
Management
State Office Park South
107 Pleasant Street
Concord, New Hampshire 03301

Adjudicatory File (2)
Atomic Safety and Licensing Board
Panel Docket
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Congressman Nicholas Mavroules
U.S. House of Representatives
70 Washington Street
Salem, Massachusetts 01970

Mr. Leon Maglathlin
Public Service Company of New Hampshire
100 Elm Street
Manchester, New Hampshire 03105

Mr. Jack Dolan
Federal Emergency Management Agency
Region I
J.W. McCormack Post Office &
Courthouse Building, Room 442
Boston, Massachusetts 02109

Mr. J. M. Peschei
Public Service Company of New Hampshire
P.O. Box 300
Seabrook, New Hampshire 03874

G. Paul Bollwerk, III
Atomic Safety & Licensing
Appeal Board
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Howard A. Wilber
Atomic Safety and Licensing Board
Panel
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Atomic Safety and Licensing Board
Panel
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Atomic Safety and Licensing Appeal
Panel
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Thomas S. Moore, Chairman
Atomic Safety & Licensing
Appeal Board
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Mr. Ted C. Feigenbaum

cc:

Ivan W. Smith, Chairman (2)
Administrative Judge
Atomic Safety and Licensing Board
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Richard F. Cole
Administrative Judge
Atomic Safety and Licensing Board
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Kenneth A. McCollom
Administrative Judge
1107 West Knapp Street
Stillwater, Oklahoma 74075

Alan S. Rosenthal
Atomic Safety & Licensing
Appeal Board
U.S. Nuclear Regulatory Commission
Washington, DC 20555

ENCLOSURE

UNIMPLEMENTED GSIs AT SEABROOK STATION, UNIT 1

<u>GSI NO.</u>	<u>TITLE</u>	<u>PROJECTED IMPLEMENTATION DATE</u>	<u>REMARKS</u>
51	Improving the Reliability of Open-Cycle Service Water Systems	Prior to 1st refueling restart	Approximate completion date 09/91
67.3.3	Improved Accident Monitoring	Prior to 1st refueling restart	Approximate completion date 09/91
75	Salem ATWS Item 2.2.2, Vendor Interface for Safety-Related Components	06/30/91	
89	RCS/RHR Suction Line Valve Interlock on PWRs	Prior to 1st re- fueling restart	Approximate completion date 09/91

DISTRIBUTION:

Docket File 50-443

NRC PDR

Local PDR

PDI-3 Reading

S. Varga

E. Greenman

M. Rushbrook

R. Wessman

E. Leeds

D. Miller

R. Scholl

OGC - 15 B18

E. Jordan - MNBB 3701

ACRS (10) P - 315

J. Johnson, Region I

H. Berkow