

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (1)

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

8 9 P A B V S 1 (2) 0 0 - 0 0 0 0 0 0 - 0 0 (3) 4 1 1 1 1 (4) _____ (5)

8 9 REPORT SOURCE L (6) 0 5 0 0 0 0 3 3 4 (7) 0 9 1 9 8 2 (8) 1 0 1 0 8 2 (9)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
0 2 | On 9/19/82 the alarm status lights and visual display on the core cooling
0 3 | monitor were found extinguished although power to the monitor remained
0 4 | available. When initial troubleshooting failed, the monitor was
0 5 | declared inoperable per T.S.3.3.3.8. Approximately 40 minutes later
0 6 | the monitor returned to normal operation. On 9/20/82 the problem
0 7 | reoccurred. Public health and safety was not adversely affected
0 8 | since other means for measuring the subcooling margin were available.

8 9 SYSTEM CODE I E (11) CAUSE CODE B (12) CAUSE SUBCODE A (13) COMPONENT CODE E L E C T R O N (14) COMP. SUBCODE Z (15) VALVE SUBCODE Z (16)
17 LER/RO REPORT NUMBER 8 2 (18) 19 (20) SEQUENTIAL REPORT NO. 0 4 0 (21) OCCURRENCE CODE 0 3 (22) REPORT TYPE L (23) REVISION NO. 0 (24)
ACTION TAKEN X (25) FUTURE ACTION X (26) EFFECT ON PLANT Z (27) SHUTDOWN METHOD Z (28) HOURS 0 0 0 0 (29) ATTACHMENT SUBMITTED Y (30) NRD-4 FORM SUB. N (31) PRIME COMP. SUPPLIER N (32) COMPONENT MANUFACTURER W 3 5 1 (33)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
1 0 | The cause was a loose connection, repaired while troubleshooting the mon-
1 1 | itor on 9/20/82. Thorough tests and an inspection of the monitor will
1 2 | be made in conjunction with the future installation of a field change
1 3 | kit under design by Westinghouse. It addresses a previously identified
1 4 | generic problem with the installed temperature sensing circuits.

8 9 FACILITY STATUS E (28) % POWER 1 0 0 (29) OTHER STATUS N/A (30) METHOD OF DISCOVERY B (31) DISCOVERY DESCRIPTION Operating Surveillance Test (32)

8 9 ACTIVITY CONTENT RELEASED OF RELEASE Z (33) Z (34) AMOUNT OF ACTIVITY N/A (35) LOCATION OF RELEASE N/A (36)

8 9 PERSONNEL EXPOSURES NUMBER 0 0 0 (37) TYPE Z (38) DESCRIPTION N/A (39)

8 9 PERSONNEL INJURIES NUMBER 0 0 0 (40) DESCRIPTION N/A (41)

8 9 LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) DESCRIPTION N/A (43) 8210260226 821014 PDR ADOCK 05000334 5 PDR

8 9 PUBLICITY ISSUED N (44) DESCRIPTION N/A (45) NRC USE ONLY