

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | N | C | B | E | P | 2 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | _____ | 5
 7 8 9 14 15 25 26 30 57 58
 LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT 58

CON'T
 0 1 | L | 6 | 0 | 5 | 0 | - | 0 | 3 | 2 | 4 | 7 | 0 | 9 | 2 | 1 | 8 | 2 | 8 | 1 | 0 | 1 | 4 | 8 | 2 | 9
 7 8 60 61 68 69 74 75 80
 REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | While performing an operability test of the Radwaste Building fire detection system, |
 0 3 | Fire Protection group personnel discovered fire hose station RW-49, located on the |
 0 4 | -3' elevation of the Radwaste Building, was inoperable due to a disconnected fire |
 0 5 | hose. This event did not affect the health and safety of the public. |
 0 6 | _____ |
 0 7 | _____ |

Technical Specifications 3.7.7.4, 6.9.1.9b

0 9 | A | B | 11 | A | 12 | X | 13 | X | X | X | X | X | X | 14 | Z | 15 | Z | 16 |
 7 8 9 10 11 12 13 18 19 20
 SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE
 17 | 8 | 2 | 21 | 22 | - | 23 | 1 | 0 | 8 | 24 | 26 | / | 27 | 0 | 3 | 28 | 29 | L | 30 | - | 31 | 0 | 32 |
 7 8 9 21 22 23 24 26 27 28 29 30 31 32
 LER/RO REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.
 ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NRPD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER
 X | 18 | G | 19 | Z | 20 | Z | 21 | 0 | 0 | 0 | 0 | 37 | Y | 23 | N | 24 | L | 25 | A | 1 | 6 | 7 | 26 |
 33 34 35 36 37 40 41 42 43 44 47
 CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | It is not known why or by whom the fire hose was disconnected. The hose, Model |
 1 1 | No. SYN149, was reconnected and the hose station returned to service within five |
 1 2 | minutes of the event discovery. The plant general employee and annual retraining |
 1 3 | programs will be revised by January 1, 1983, to instruct against utilizing plant fire |
 1 4 | fighting equipment for any purpose other than fire fighting |

1 5 | H | 28 | 0 | 0 | 0 | 29 | NA | 30 | A | 31 | Plant Technician Surveillance |
 7 8 9 10 12 13 44 45 46 80
 FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION
 1 6 | Z | 33 | Z | 34 | NA | 35 | NA | 36 |
 7 8 9 10 11 44 45 80
 ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE
 1 7 | 0 | 0 | 0 | 37 | Z | 38 | NA | 39 |
 7 8 9 11 12 13 80
 PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION
 1 8 | 0 | 0 | 0 | 40 | NA | 41 |
 7 8 9 11 12 80
 PERSONNEL INJURIES NUMBER DESCRIPTION
 1 9 | Z | 42 | _____ | 43 |
 7 8 9 10 80
 LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION
 2 0 | N | 44 | _____ | 45 |
 7 8 9 10 80
 PUBLICITY ISSUED DESCRIPTION
 8210260318 821014
 PDR ADOCK 05000324
 S PDR

NAME OF PREPARER: M. J. Pastva, Jr. PHONE: 919-457-9521

LER ATTACHMENT - RO #2-82-103

Facility: BSEP Unit No. 2

Event Date: September 21, 1982

During the performance of an operability test of fire detection equipment in the Radwaste Building, it was discovered that fire hose station RW-49, located on the -3' elevation of the Radwaste Building, was inoperable due to a disconnected fire hose. Interviews were conducted with 12 contract personnel known to be working in the vicinity of the subject hose station during the time of this discovery. However, these interviews were inconclusive in determining those responsible for the disconnected hose. In addition, a review of the Radwaste auxiliary operator's log showed the subject fire hose station was visually checked as operable approximately 11 hours before the event discovery.

Within five minutes of the event discovery, the fire hose was reconnected and the subject fire hose station was returned to service. As a result of this event, the plant general employee and annual retraining programs will be revised by January 1, 1983, to provide for instruction against utilizing plant fire fighting equipment for any purpose other than fire fighting.