

ADMINISTRATIVE CONTROLS

Unit Staff (Continued)

- b. At least one licensed Operator shall be in the control room when fuel is in the reactor. In addition, while the Unit is in MODE 1, 2, 3 or 4, at least one licensed Senior Operator shall be in the control room;
- c. An individual from the Health Physics Groups, qualified in radiation protection procedures, shall be on site when fuel is in the reactor;
- d. ALL CORE ALTERATIONS shall be observed and directly supervised by either a licensed Senior Operator or licensed Senior Operator Limited to Fuel Handling who has no other concurrent responsibilities during this operation;
- e. A site Fire Brigade of at least 5 members* shall be maintained onsite at all times. The Fire Brigade shall not include the Shift Supervisor, and the two other members of the minimum shift crew necessary for safe shutdown of the Unit and any personnel required for other essential functions during a fire emergency; and
- f. Administrative procedures shall be developed and implemented to limit the working hours of Unit Staff who perform safety-related functions; e.g., Senior Operators, Operators, Health Physicists, Auxiliary operators, and key maintenance personnel.

The amount of overtime worked by Unit Staff members performing safety-related functions shall be limited in accordance with the NRC Policy Statement on working hours (Generic Letter No. 82-12).

Assistant Manager Operations

- 9. The ~~Supervisor Operations~~ or Manager Operations shall hold a senior reactor operator license.

*May be less than the minimum requirements for a period of time not to exceed 2 hours in order to accommodate unexpected absence provided immediate action is taken to fill the required positions.