

December 4, 1990

Docket No. 50-213

Mr. Edward J. Mroczka
Senior Vice President
Nuclear Engineering and Operations
Connecticut Yankee Atomic Power Company
Northeast Nuclear Energy Company
P. O. Box 270
Hartford, Connecticut 06141-0270

Dear Mr. Mroczka:


SUBJECT: ISSUANCE OF AMENDMENT (TAC NO. 77044)

The Commission has issued the enclosed Amendment No. 133 to Facility Operating License No. DPR-61 for the Haddam Neck Plant, in response to your application dated June 14, 1990.

The amendment will add an exception to the requirements of Technical Specification (TS) 4.0.4 for performing the E-bar surveillance (TS Table 4.4-4, Item 3) prior to entry into Mode 1. In addition, the amendment will correct typographical errors in Section 3/4.3.3 of the INDEX and ACTION items 54 and 55 of Table 3.3-11 to reference ACTION 53 instead of ACTION 48.

A copy of the related Safety Evaluation is also enclosed. The Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,



Alan B. Wang, Project Manager
Project Directorate I-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. ¹³³ to DPR-61
2. Safety Evaluation

cc w/enclosures:
See next page

OFC	: PDI-4/LA:DRP	: PM/PDI-4:DRP	: PD/PDI-4:DRP	: OGC	: <i>Handwritten initials</i>	:	:
NAME	: <i>SN6PRTS</i>	: ABWang	: JStolz	: <i>Handwritten initials</i>	: <i>Handwritten initials</i>	:	:
DATE	: 11/27/90	: 11/27/90	: 12/4/90	: 11/30/90	:	:	:

OFFICIAL RECORD COPY
Document Name: AMEND TAC 77044

9012140042 901204
PDR ADOCK 05000213
P PNU

DF01
11

Mr. Edward J. Mroczka
Connecticut Yankee Atomic Power Company

Haddam Neck Plant

cc:

Gerald Garfield, Esquire
Day, Berry and Howard
Counselors at Law
City Place
Hartford, Connecticut 06103-3499

R. M. Kacich, Manager
Generation Facilities Licensing
Northeast Utilities Service Company
Post Office Box 270
Hartford, Connecticut 06141-0270

W. D. Romberg, Vice President
Nuclear Operations
Northeast Utilities Service Company
Post Office Box 270
Hartford, Connecticut 06141-0270

D. O. Nordquist
Director of Quality Services
Northeast Utilities Service Company
Post Office Box 270
Hartford, Connecticut 06141-0270

Kevin McCarthy, Director
Radiation Control Unit
Department of Environmental Protection
State Office Building
Hartford, Connecticut 06106

Regional Administrator
Region I
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

Bradford S. Chase, Under Secretary
Energy Division
Office of Policy and Management
80 Washington Street
Hartford, Connecticut 06106

Board of Selectmen
Town Hall
Haddam, Connecticut 06103

J. P. Stetz, Nuclear Station Director
Haddam Neck Plant
Connecticut Yankee Atomic Power Company
RFD 1, Post Office Box 127E
East Hampton, Connecticut 06424

J. T. Shedlosky, Resident Inspector
Haddam Neck Plant
c/o U. S. Nuclear Regulatory Commission
Post Office Box 116
East Haddam Post Office
East Haddam, Connecticut 06423

G. H. Bouchard, Nuclear Unit Director
Haddam Neck Plant
Connecticut Yankee Atomic Power Company
RFD 1, Post Office Box 127E
East Hampton, Connecticut 06424

DISTRIBUTION:

Docket File

NRC & Local PDR

Plant File

S. Varga (14E4)

E. Greenman (14A2)

S. Norris

A. Wang

OGC

D. Hagan (MNBB 3302)

E. Jordan (MNBB 3302)

G. Hill (4) (P1-137)

W. Jones (P-130A)

J. Calvo (11F23)

ACRS (10)

GPA/PA

OC/LFMB