



Nebraska Public Power District

GENERAL OFFICE
P.O. BOX 499, COLUMBUS, NEBRASKA 68602-0499
TELEPHONE (402) 564-8561
FAX (402) 563-5551

NLS9000559

December 10, 1990

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Subject: 30-Day Response to Generic Letter 89-10, Supplement 3
Cooper Nuclear Station
NRC Docket No. 50-298, DFR-46

Reference: Generic Letter 89-10, Supplement 3, "Consideration of the Results
of NRC-Sponsored Tests of Motor-Operated Valves," dated
October 25, 1990


Gentlemen:

The Nebraska Public Power District (District) hereby provides its response to the 30-day reporting requirements contained in Generic Letter 89-10, Supplement 3 (Reference). As requested in the referenced letter, the District has performed a site specific safety assessment for Cooper Nuclear Station (CNS) which has determined that the generic safety assessments performed by the Boiling Water Reactor Owners' Group and the NRC Staff are applicable to CNS. This site specific safety assessment is available for NRC review.

Supplement 3 also requested licensees to notify the NRC whether they believe there are motor-operated valves (MOVs) with deficiencies of greater safety significance than the Generic Issue 87 valves, namely the isolation valves for the Reactor Core Isolation Cooling System, the High Pressure Coolant Injection System and the Reactor Water Cleanup System. The District has evaluated this issue, and as documented in the site-specific safety assessment, has determined that at CNS, there exist no MOVs with deficiencies of greater safety significance than the Generic Issue 87 valves.

In accordance with 10 CFR 50.54(f), and as requested in Generic Letter 89-10, Supplement 3, this response is provided under oath.

Please contact me if you have any questions.


G. R. Horn
Nuclear Power Growth Manager

GRH/mjb

cc: NRC Regional Office
Region IV
Arlington, TX

NRC Resident Inspector
Cooper Nuclear Station 000008

901214 071 901210
PDR ADOCK 05000298
PDC


Powerful Pride in Nebraska

AD64

U. S. Nuclear Regulatory Commission
December 10, 1990
Page 2 of 2


STATE OF NEBRASKA)
)
PLATTE COUNTY)

G. R. Horn, being first duly sworn, deposes and says that he is an authorized representative of the Nebraska Public Power District, a public corporation and political subdivision of the State of Nebraska; that he is duly authorized to submit this response on behalf of Nebraska Public Power Distr'ct; and that the statements contained herein are true to the best of his knowledge and belief.



G. R. Horn

Subscribed in my presence and sworn to before me this 10th day of
December, 1990.



NOTARY PUBLIC

